



Proactive Rental Housing Inspection Program Violations Report - 120 Days Non- Compliant

Updated: 4/1/2019

Address	Owner	Total Violations
1735 E 10TH ST 90813	10TH STREET PARTNERS LLC,	16
Violations:		
<ul style="list-style-type: none">- The water heater temperature and pressure relief valve outlet is not piped to the outside of the building. Provide approved piping from the valve outlet to the outside of the building and terminating no more than 2 feet nor less than 6 inches above the ground.- No work shall be done on any part of the building or structure beyond the point indicated each successive inspection without first obtaining the written approval of the building official. There shall be a final inspection and approval on all buildings when completed and ready for occupancy. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: REQUEST AND OBTAIN ALL THE SUCCESSIVE AND REQUIRED INSPECTIONS AND WRITTEN APPROVALS ON ALL WORK AND OBTAIN WRITTEN APPROVAL PRIOR TO OCCUPANCY.- Repair deteriorated entry door framing and/or jamb.- Repair/replace deteriorated/non-operational entry door lock/knob.- A. General. No person shall erect, construct, enlarge, alter, repair, remodel, move or demolish any building or part of a building or structure, or change the character or occupancy or use of any building or structure, or part of a building or structure or perform site grading in the city without first obtaining a permit covering such work from the building official. Whenever a building permit is required to abate a substandard condition as defined in LBMC 18.08.200S, code enforcement fees shall be paid in addition to the permit fees. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: OBTAIN BUILDING PERMITS FROM THE DEVELOPMENT SERVICES DEPARTMENT FOR THE CODE ENFORCEMENT DIVISION FOR ALL UNPERMITTED CONSTRUCTION, REMODELING, OR OCCUPANCY CHANGE INCLUDING, BUT NOT LIMITED TO, THE FOLLOWING ITEMS OR DESCRIBED WORK:<ul style="list-style-type: none">- Repair/repaint/seal exterior wood trim/surfaces where damaged and/or where paint is peeling/missing.- Repair/Repaint all deteriorated laundry room walls and/or ceilings. Seal all holes, including holes at pipe penetrations, and paint all unpainted surfaces.- Plans, engineering calculations, diagrams and other data shall be submitted in one or more sets with each application for a permit. The building official may require plans, computations and specifications to be prepared and designed by an engineer or architect licensed by the state of California to practice as such. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE THREE SETS OF PLANS, SPECIFICATIONS OR OTHER DETAILS AS REQUIRED BY THE DEPARTMENT OF DEVELOPMENT SERVICES WITH THE APPLICATION FOR THE REQUIRED PERMIT.- The underfloor supporting structural frame members are deteriorated. Replace the deteriorated mudsills, foundation cripples, piers, posts and girders to adequately support structure.- Caulk perimeter of tub/shower at floor/flooring where caulking/grout is deteriorated/missing. Remove all old/deteriorated caulking at floor/flooring.- Caulk perimeter of tub/shower at enclosure walls where caulking/grout is deteriorated/missing. Remove all old/deteriorated caulking/grout at enclosure walls.- Obtain all required permits and inspections and provide approved unit heater capable of heating unit to 70 degrees Fahrenheit, measured three feet above the floor. NOTE: Space heaters are not approved for permanent use.- Provide 1/4 inch hardware mesh on all foundation vent openings for rodent proofing.		

- Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause to believe that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS. NOTE: PROPERTY OWNER / MANAGEMENT COMPANY SHALL PROVIDE ACCESS TO UNIT(S) TO VERIFY ALL VIOLATION(S) HAVE BEEN CORRECTED. FAILURE TO PROVIDE ACCESS BY THE COMPLIANCE DATE BELOW MAY RESULT IN A CITATION BEING ISSUED.

- All construction or work for which a permit is required shall be subject to inspection by the building official. It shall be the duty of the permittee to cause the work to be accessible and exposed for inspection purposes. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO, AND EXPOSE ALL CONSTRUCTION WORK FOR THE REQUIRED INSPECTIONS.

- It shall be the duty of the person doing the work authorized by a permit to notify the building official that such is ready for inspection and to provide access to and means for proper inspection of such work. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: REQUEST INSPECTION AND PROVIDE ACCESS TO ALL PERMITTED WORK

Address	Owner	Total Violations
223 E 10TH ST 90813	MEREDITH ET AL., EARL	9

Violations:

- Repair/repaint deteriorated/missing exterior stucco.
 - Repair/repaint/seal exterior wood trim/surfaces where damaged and/or where paint is peeling/missing.
 - Repair and repaint all deteriorated window frames/components/surfaces.
 - Provide mosquito proof screens on all openable windows.
 - Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause to believe that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS. NOTE: PROPERTY OWNER / MANAGEMENT COMPANY SHALL PROVIDE ACCESS TO UNIT(S) TO VERIFY ALL VIOLATION(S) HAVE BEEN CORRECTED. FAILURE TO PROVIDE ACCESS BY THE COMPLIANCE DATE BELOW MAY RESULT IN A CITATION BEING ISSUED.
 - The roof covering is defective. Replace the defective and deteriorated roof covering.
 - It shall be the duty of responsible person(s) to prevent accumulation and storage of abandoned, wrecked, dismantled, or inoperative vehicles or parts thereof, except for those vehicles or parts thereof exempted pursuant to Long Beach Municipal Code Section 10.46.030. Remove all inoperative vehicles or vehicle parts from the property or bring vehicle(s) to an operative condition including current registration status.
 - Repair/replace missing or deteriorated garage door.
 - Repair/replace all deteriorated/broken/missing light fixtures.
-

Address**921 E 10TH ST 90813****Owner****HAROUNI PARTNERS LLC,****Total Violations****25****Violations:**

- Repair/replace deteriorated kitchen drawers.
- Exterminate cockroaches at all units where infestation is present. Seal all cracks, gaps, and holes in walls, floors, and cupboards, and around piping insertions. Remove or paint over all spotting in unit. Provide pest control service to all infested units and surrounding units sharing common floors, ceilings, and walls with infested units. NOTE: Treatment is most effective when all units are treated on the same day, treatment is repeated to target hatching young in two weeks or every two weeks until infestation is removed.
- Exterminate rodents at unit/building. Remove all rodent droppings. Weather strip entry doors, and seal all holes at walls, floors and ceilings.
- Repair/Replace deteriorated kitchen cabinet and/or doors.
- Repair/replace all deteriorated kitchen counters and/or edge banding.
- Repair/replace leaking/inoperable kitchen faucet hardware.
- Repair/re-glaze kitchen sink.
- Repair/replace and paint all deteriorated roof fascia, eaves and rafter tails.
- Repair/replace/remove deteriorated rain gutters and/or down spouts so as to direct rain water runoff away from buildings.
- Repair/repaint/seal exterior wood trim/surfaces where damaged and/or where paint is peeling/missing.
- Replace/secure all deteriorated/missing exterior siding.
- Provide mosquito proof screens on all openable windows.
- Obtain all required permits and inspections and provide approved unit heater capable of heating unit to 70 degrees Fahrenheit, measured three feet above the floor. NOTE: Space heaters are not approved for permanent use.
- Repair/repaint/replace all deteriorated bathroom cabinets.
- Repair/replace faucet/controls at bathroom sink.
- Resurface/reglaze bathroom sink where surface is deteriorated. Remove any rust on surface of sink. Use proper materials/compounds for resurfacing/reglazing sink.
- Repair/replace all deteriorated/broken/missing light fixtures.
- Repair/replace all deteriorated electrical outlets/switches.
- Repair deteriorated fencing and/or gate(s).

- Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause to believe that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS. NOTE: PROPERTY OWNER / MANAGEMENT COMPANY SHALL PROVIDE ACCESS TO UNIT(S) TO VERIFY ALL VIOLATION(S) HAVE BEEN CORRECTED. FAILURE TO PROVIDE ACCESS BY THE COMPLIANCE DATE BELOW MAY RESULT IN A CITATION BEING ISSUED.

- Route dryer exhaust to exterior of building. Maintain dryer duct free of accumulated lint on a regular basis.

- The exterior balcony and guardrails are deteriorated. Repair the deteriorated balcony and guardrails to meet minimum code requirements.

- Repair/resurface/repaint deteriorated balcony/landing.

- Repair/replace all missing or damaged electrical outlet and switch plates.

- Repair/replace missing or deteriorated garage door.

Address	Owner	Total Violations
931 E 10TH ST 90813	HAROUNI PARTNERS LLC,	5

Violations:

- Repair/Provide bathroom ventilation fan. Obtain any required permits and inspections.

- Repair/unclog specified drain.

- Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause to believe that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS. NOTE: PROPERTY OWNER / MANAGEMENT COMPANY SHALL PROVIDE ACCESS TO UNIT(S) TO VERIFY ALL VIOLATION(S) HAVE BEEN CORRECTED. FAILURE TO PROVIDE ACCESS BY THE COMPLIANCE DATE BELOW MAY RESULT IN A CITATION BEING ISSUED.

- Repair/Replace deteriorated kitchen cabinet and/or doors.

- Repair/replace deteriorated kitchen drawers.

Address	Owner	Total Violations
1235 E 20TH ST 90806	KHMER BUDDHIST ASSOCIATION,	3

Violations:

- No person shall commence, do, install, erect, construct, remove, add to or change any plumbing, water piping, gas piping, water heater, water heater vents, water treating equipment, or any appliance or device regulated by this chapter without obtaining a permit approving the proposed quality and character of workmanship and materials." PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: OBTAIN A PLUMBING PERMIT FROM THE DEVELOPMENT SERVICES DEPARTMENT FOR THE CODE ENFORCEMENT DIVISION FOR ALL UNPERMITTED PLUMBING WORK OR EQUIPMENT INCLUDING, BUT NOT LIMITED TO, THE FOLLOWING ITEMS OR DESCRIBED WORK:

- Discontinue using cord wiring.

- A. General. No person shall erect, construct, enlarge, alter, repair, remodel, move or demolish any building or part of a building or structure, or change the character or occupancy or use of any building or structure, or part of a building or structure or perform site grading in the city without first obtaining a permit covering such work from the building official. Whenever a building permit is required to abate a substandard condition as defined in LBMC 18.08.200S, code enforcement fees shall be paid in addition to the permit fees. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice:OBTAIN BUILDING PERMITS FROM THE DEVELOPMENT SERVICES DEPARTMENT FOR THE CODE ENFORCEMENT DIVISION FOR ALL UNPERMITTED CONSTRUCTION, REMODELING, OR OCCUPANCY CHANGE INCLUDING, BUT NOT LIMITED TO, THE FOLLOWING ITEMS OR DESCRIBED WORK:

Address	Owner	Total Violations
1239 E 20TH ST 90806	KHMER BUDDHIST ASSOCIATION,	6

Violations:

- Repair/repaint/secure deteriorated exterior stairway.

- Repair/repaint all deteriorated handrails and/or guardrails.

- A. General. No person shall erect, construct, enlarge, alter, repair, remodel, move or demolish any building or part of a building or structure, or change the character or occupancy or use of any building or structure, or part of a building or structure or perform site grading in the city without first obtaining a permit covering such work from the building official. Whenever a building permit is required to abate a substandard condition as defined in LBMC 18.08.200S, code enforcement fees shall be paid in addition to the permit fees. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice:OBTAIN BUILDING PERMITS FROM THE DEVELOPMENT SERVICES DEPARTMENT FOR THE CODE ENFORCEMENT DIVISION FOR ALL UNPERMITTED CONSTRUCTION, REMODELING, OR OCCUPANCY CHANGE INCLUDING, BUT NOT LIMITED TO, THE FOLLOWING ITEMS OR DESCRIBED WORK:

- All construction or work for which a permit is required shall be subject to inspection by the building official. It shall be the duty of the permit tee to cause the work to be accessible and exposed for inspection purposes.PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice:PROVIDE ACCESS TO, AND EXPOSE ALL CONSTRUCTION WORK FOR THE REQUIRED INSPECTIONS.

- It shall be the duty of the person doing the work authorized by a permit to notify the building official that such is ready for inspection and to provide access to and means for proper inspection of such work.PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice:REQUEST INSPECTION AND PROVIDE ACCESS TO ALL PERMITTED WORK

- No work shall be done on any part of the building or structure beyond the point indicated each successive inspection without first obtaining the written approval of the building official. There shall be a final inspection and approval on all buildings when completed and ready for occupancy.PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice:REQUEST AND OBTAIN ALL THE SUCCESSIVE AND REQUIRED INSPECTIONSAND WRITTEN APPROVALS ON ALL WORK AND OBTAIN WRITTEN APPROVAL PRIOR TO OCCUPANCY.

Address	Owner	Total Violations
1067 E 4TH ST 90802	FOURTH ST SANDS APARTMENTS LLC,	7

Violations:

- Repair/repaint deteriorated stair landings as directed. Obtain all required permits and inspections.

- Repair/replace all deteriorated/broken/missing light fixtures.

- Repair/repaint deteriorated/missing exterior stucco.
- Provide trash facilities adequate enough to handle trash load of tenants on a calendar week basis. Ensure that all containers have closeable lids and are kept closed at all times. Note: Increased frequency of pick up and/or additional containers may be required to accomplish this task.
- Sanitize trash facilities on a routine basis to prevent potential insect/rodent harborage.
- Remove scattered trash, castoff items and debris around premises.
- There is graffiti painted on the premises. Remove all graffiti from the premises.

Address	Owner	Total Violations
1073 E 4TH ST 90802	FOURTH ST SANDS APARTMENTS LLC,	18

Violations:

- Repair/repaint deteriorated stair landings as directed. Obtain all required permits and inspections.
- Repair/replace all deteriorated/broken/missing light fixtures.
- Repair/replace/remove deteriorated rain gutters and/or down spouts so as to direct rain water runoff away from buildings.
- There is graffiti painted on the premises. Remove all graffiti from the premises.
- Replace all broken window glass.
- Provide/secure cap on open sewer cleanout and repair all plumbing problems causing sewage flow/backup.
- Repair all holes on the exterior of the building.
- Repair/repaint/seal exterior wood trim/surfaces where damaged and/or where paint is peeling/missing.
- Repair/repaint deteriorated/missing exterior stucco.
- Repair/repaint/secure deteriorated exterior stairway.
- Repair/repaint all deteriorated handrails and/or guardrails.
- Provide smooth, trip free surfaces at all walkways.
- Provide hot water under pressure to this complex/unit to a temperature of at least 120 degrees Fahrenheit.
- Provide water service to this occupied complex. All plumbing fixtures shall be connected to an approved system of water supply and provided with hot and cold running water necessary for its normal operation.
- Repair/replace all missing or damaged electrical outlet and switch plates.
- Remove scattered trash, castoff items and debris around premises.
- Provide mosquito proof screens on all openable windows.

- Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause to believe that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS.

Address	Owner	Total Violations
1711 E 4TH ST REAR 90802	MULLIO, RAY	20

Violations:

- No new electrical installation shall be made nor any alteration or addition performed to any existing wiring, nor shall any wiring for the placing or installation of any electric light, power or heating device, or any apparatus which generates, transmits, transforms or utilizes electricity operating at a voltage exceeding twenty-five volts between conductors or capable of supplying more than fifty watts, be made without first obtaining an electrical permit. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: OBTAIN AN ELECTRICAL PERMIT FROM THE DEVELOPMENT SERVICES DEPARTMENT FOR THE CODE ENFORCEMENT DIVISION FOR ALL UNPERMITTED ELECTRICAL WORK OR EQUIPMENT INCLUDING, BUT NOT LIMITED TO, THE FOLLOWING ITEMS OR DESCRIBED WORK:

- No person shall install, alter, reconstruct or repair any heating, ventilating, cooling, or refrigeration equipment unless a permit therefore has been obtained from the building official except as otherwise provided in this code. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: OBTAIN A MECHANICAL PERMIT FROM THE DEVELOPMENT SERVICES DEPARTMENT FOR THE CODE ENFORCEMENT DIVISION FOR ALL UNPERMITTED MECHANICAL WORK OR EQUIPMENT INCLUDING, BUT NOT LIMITED TO, THE FOLLOWING ITEMS OR DESCRIBED WORK:

- No person shall commence, do, install, erect, construct, remove, add to or change any plumbing, water piping, gas piping, water heater, water heater vents, water treating equipment, or any appliance or device regulated by this chapter without obtaining a permit approving the proposed quality and character of workmanship and materials." PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: OBTAIN A PLUMBING PERMIT FROM THE DEVELOPMENT SERVICES DEPARTMENT FOR THE CODE ENFORCEMENT DIVISION FOR ALL UNPERMITTED PLUMBING WORK OR EQUIPMENT INCLUDING, BUT NOT LIMITED TO, THE FOLLOWING ITEMS OR DESCRIBED WORK:

- All construction or work for which a permit is required shall be subject to inspection by the building official. It shall be the duty of the permit tee to cause the work to be accessible and exposed for inspection purposes. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO, AND EXPOSE ALL CONSTRUCTION WORK FOR THE REQUIRED INSPECTIONS.

- It shall be the duty of the person doing the work authorized by a permit to notify the building official that such is ready for inspection and to provide access to and means for proper inspection of such work. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: REQUEST INSPECTION AND PROVIDE ACCESS TO ALL PERMITTED WORK

- No work shall be done on any part of the building or structure beyond the point indicated each successive inspection without first obtaining the written approval of the building official. There shall be a final inspection and approval on all buildings when completed and ready for occupancy. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: REQUEST AND OBTAIN ALL THE SUCCESSIVE AND REQUIRED INSPECTIONS AND WRITTEN APPROVALS ON ALL WORK AND OBTAIN WRITTEN APPROVAL PRIOR TO OCCUPANCY.

- Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause to believe that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS. NOTE: PROPERTY OWNER / MANAGEMENT COMPANY SHALL PROVIDE ACCESS TO UNIT(S) TO VERIFY ALL VIOLATION(S) HAVE BEEN CORRECTED. FAILURE TO PROVIDE ACCESS BY THE COMPLIANCE DATE BELOW MAY RESULT IN A CITATION BEING ISSUED.

- A. General. No person shall erect, construct, enlarge, alter, repair, remodel, move or demolish any building or part of a building or structure, or change the character or occupancy or use of any building or structure, or part of a building or structure or perform site grading in the city without first obtaining a permit covering such work from the building official. Whenever a building permit is required to abate a substandard condition as defined in LBMC 18.08.200S, code enforcement fees shall be paid in addition to the permit fees. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: OBTAIN BUILDING PERMITS FROM THE DEVELOPMENT SERVICES DEPARTMENT FOR THE CODE ENFORCEMENT DIVISION FOR ALL UNPERMITTED CONSTRUCTION, REMODELING, OR OCCUPANCY CHANGE INCLUDING, BUT NOT LIMITED TO, THE FOLLOWING ITEMS OR DESCRIBED WORK:

- The mortar surrounding the brick masonry units along the exterior walls of the structure is in an advance state of deterioration, partially missing and structurally suspect. Replace the missing mortar around the brick units to provide the adequate support and adhesion for all the brick masonry units along the exterior walls. NOTE: The above deficiency may be repaired by applying a 1/2" of plaster over the existing brick and mortar areas along the wall. All painted surfaces are required to be sandblasted free from paint prior to the application of the plaster.

- Plans, engineering calculations, diagrams and other data shall be submitted in one or more sets with each application for a permit. The building official may require plans, computations and specifications to be prepared and designed by an engineer or architect licensed by the state of California to practice as such. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE THREE SETS OF PLANS, SPECIFICATIONS OR OTHER DETAILS AS REQUIRED BY THE DEPARTMENT OF DEVELOPMENT SERVICES WITH THE APPLICATION FOR THE REQUIRED PERMIT.

- No new electrical installation shall be made nor any alteration or addition performed to any existing wiring, nor shall any wiring for the placing or installation of any electric light, power or heating device, or any apparatus which generates, transmits, transforms or utilizes electricity operating at a voltage exceeding twenty-five volts between conductors or capable of supplying more than fifty watts, be made without first obtaining an electrical permit. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: OBTAIN AN ELECTRICAL PERMIT FROM THE DEVELOPMENT SERVICES DEPARTMENT FOR THE CODE ENFORCEMENT DIVISION FOR ALL UNPERMITTED ELECTRICAL WORK OR EQUIPMENT INCLUDING, BUT NOT LIMITED TO, THE FOLLOWING ITEMS OR DESCRIBED WORK:

- No person shall install, alter, reconstruct or repair any heating, ventilating, cooling, or refrigeration equipment unless a permit therefore has been obtained from the building official except as otherwise provided in this code. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: OBTAIN A MECHANICAL PERMIT FROM THE DEVELOPMENT SERVICES DEPARTMENT FOR THE CODE ENFORCEMENT DIVISION FOR ALL UNPERMITTED MECHANICAL WORK OR EQUIPMENT INCLUDING, BUT NOT LIMITED TO, THE FOLLOWING ITEMS OR DESCRIBED WORK:

- No person shall commence, do, install, erect, construct, remove, add to or change any plumbing, water piping, gas piping, water heater, water heater vents, water treating equipment, or any appliance or device regulated by this chapter without obtaining a permit approving the proposed quality and character of workmanship and materials. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: OBTAIN A PLUMBING PERMIT FROM THE DEVELOPMENT SERVICES DEPARTMENT FOR THE CODE ENFORCEMENT DIVISION FOR ALL UNPERMITTED PLUMBING WORK OR EQUIPMENT INCLUDING, BUT NOT LIMITED TO, THE FOLLOWING ITEMS OR DESCRIBED WORK:

- All construction or work for which a permit is required shall be subject to inspection by the building official. It shall be the duty of the permittee to cause the work to be accessible and exposed for inspection purposes. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO, AND EXPOSE ALL CONSTRUCTION WORK FOR THE REQUIRED INSPECTIONS.

- It shall be the duty of the person doing the work authorized by a permit to notify the building official that such is ready for inspection and to provide access to and means for proper inspection of such work. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: REQUEST INSPECTION AND PROVIDE ACCESS TO ALL PERMITTED WORK

- No work shall be done on any part of the building or structure beyond the point indicated each successive inspection without first obtaining the written approval of the building official. There shall be a final inspection and approval on all buildings when completed and ready for occupancy. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: REQUEST AND OBTAIN ALL THE SUCCESSIVE AND REQUIRED INSPECTIONS AND WRITTEN APPROVALS ON ALL WORK AND OBTAIN WRITTEN APPROVAL PRIOR TO OCCUPANCY.

- Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause to believe that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS. NOTE: PROPERTY OWNER / MANAGEMENT COMPANY SHALL PROVIDE ACCESS TO UNIT(S) TO VERIFY ALL VIOLATION(S) HAVE BEEN CORRECTED. FAILURE TO PROVIDE ACCESS BY THE COMPLIANCE DATE BELOW MAY RESULT IN A CITATION BEING ISSUED.

- A. General. No person shall erect, construct, enlarge, alter, repair, remodel, move or demolish any building or part of a building or structure, or change the character or occupancy or use of any building or structure, or part of a building or structure or perform site grading in the city without first obtaining a permit covering such work from the building official. Whenever a building permit is required to abate a substandard condition as defined in LBMC 18.08.200S, code enforcement fees shall be paid in addition to the permit fees. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: OBTAIN BUILDING PERMITS FROM THE DEVELOPMENT SERVICES DEPARTMENT FOR THE CODE ENFORCEMENT DIVISION FOR ALL UNPERMITTED CONSTRUCTION, REMODELING, OR OCCUPANCY CHANGE INCLUDING, BUT NOT LIMITED TO, THE FOLLOWING ITEMS OR DESCRIBED WORK:

- The mortar surrounding the brick masonry units along the exterior walls of the structure is in an advanced state of deterioration, partially missing and structurally suspect. Replace the missing mortar around the brick units to provide the adequate support and adhesion for all the brick masonry units along the exterior walls. NOTE: The above deficiency may be repaired by applying a 1/2" of plaster over the existing brick and mortar areas along the wall. All painted surfaces are required to be sandblasted free from paint prior to the application of the plaster.

- Plans, engineering calculations, diagrams and other data shall be submitted in one or more sets with each application for a permit. The building official may require plans, computations and specifications to be prepared and designed by an engineer or architect licensed by the state of California to practice as such. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE THREE SETS OF PLANS, SPECIFICATIONS OR OTHER DETAILS AS REQUIRED BY THE DEPARTMENT OF DEVELOPMENT SERVICES WITH THE APPLICATION FOR THE REQUIRED PERMIT.

Address

119 W 52ND ST 90805

Owner

NISHIKAWA, MAKOTO

Total Violations

6

Violations:

- Repair/repaint deteriorated/missing exterior stucco.

- Repair/replace all deteriorated/broken/missing light fixtures.

- Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause to believe that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS. NOTE: PROPERTY OWNER / MANAGEMENT COMPANY SHALL PROVIDE ACCESS TO UNIT(S) TO VERIFY ALL VIOLATION(S) HAVE BEEN CORRECTED. FAILURE TO PROVIDE ACCESS BY THE COMPLIANCE DATE BELOW MAY RESULT IN A CITATION BEING ISSUED.

- Repair/repaint/seal exterior wood trim/surfaces where damaged and/or where paint is peeling/missing.

- Provide mosquito proof screens on all openable windows.

- Repair deteriorated and/or clogged exterior plumbing.

Address**1200 E 52ND ST 90805****Owner****LING, PAUL****Total Violations****14****Violations:**

- Repair/repaint all deteriorated handrails and/or guardrails.
 - Repair/repaint deteriorated stair landings as directed. Obtain all required permits and inspections.
 - Repair deteriorated fencing and/or gate(s).
 - Discarded furniture and household items shall not be stored in yard areas. Remove the discarded furniture and/or household items stored or kept in the yard areas.
 - Provide mosquito proof screens on all openable windows.
 - Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause to believe that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS. NOTE: PROPERTY OWNER / MANAGEMENT COMPANY SHALL PROVIDE ACCESS TO UNIT(S) TO VERIFY ALL VIOLATION(S) HAVE BEEN CORRECTED. FAILURE TO PROVIDE ACCESS BY THE COMPLIANCE DATE BELOW MAY RESULT IN A CITATION BEING ISSUED.
 - Repair/repaint/secure deteriorated exterior stairway.
 - Repair all holes on the exterior of the building.
 - Repair/repaint deteriorated/missing exterior stucco.
 - Repair/repaint/seal exterior wood trim/surfaces where damaged and/or where paint is peeling/missing.
 - No new electrical installation shall be made nor any alteration or addition performed to any existing wiring, nor shall any wiring for the placing or installation of any electric light, power or heating device, or any apparatus which generates, transmits, transforms or utilizes electricity operating at a voltage exceeding twenty-five volts between conductors or capable of supplying more than fifty watts, be made without first obtaining an electrical permit. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: OBTAIN AN ELECTRICAL PERMIT FROM THE DEVELOPMENT SERVICES DEPARTMENT FOR THE CODE ENFORCEMENT DIVISION FOR ALL UNPERMITTED ELECTRICAL WORK OR EQUIPMENT INCLUDING, BUT NOT LIMITED TO, THE FOLLOWING ITEMS OR DESCRIBED WORK:
 - A. General. No person shall erect, construct, enlarge, alter, repair, remodel, move or demolish any building or part of a building or structure, or change the character or occupancy or use of any building or structure, or part of a building or structure or perform site grading in the city without first obtaining a permit covering such work from the building official. Whenever a building permit is required to abate a substandard condition as defined in LBMC 18.08.200S, code enforcement fees shall be paid in addition to the permit fees. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: OBTAIN BUILDING PERMITS FROM THE DEVELOPMENT SERVICES DEPARTMENT FOR THE CODE ENFORCEMENT DIVISION FOR ALL UNPERMITTED CONSTRUCTION, REMODELING, OR OCCUPANCY CHANGE INCLUDING, BUT NOT LIMITED TO, THE FOLLOWING ITEMS OR DESCRIBED WORK:
 - Repair/replace all deteriorated/broken/missing light fixtures.
 - There is graffiti painted on the premises. Remove all graffiti from the premises.
-

Address**1210 E 52ND ST 7 90805****Owner****LING, PAUL****Total Violations****17****Violations:**

- Repair/replace deteriorated unit carpeting.
 - Walls around shower/tub shall have smooth, hard nonabsorbent surfaces made of Portland cement, concrete, ceramic tile or other smooth, hard nonabsorbent surfaces extending to a height of seventy inches and to no less than two feet away from the edge of the tub/shower enclosure.
 - Resurface/reglaze tub where surface is deteriorated. Remove any rust on surface of tub. Use proper materials/compounds for resurfacing/reglazing tub.
 - Repair/resurface/repaint all deteriorated bathroom door(s).
 - Repair/Replace deteriorated kitchen cabinet and/or doors.
 - Repair/replace deteriorated kitchen drawers.
 - Repair/replace inoperative/faulty stove, which may cause fire hazard.
 - Repair toilet to flush properly. Replace all deteriorated/missing components.
 - Caulk around toilet base.
 - Caulk gap between wall and sink/cabinet top behind sink. Remove all old/deteriorated caulking/grout. Perimeter of wall behind sink must be watertight.
 - Caulk perimeter of tub/shower at enclosure walls where caulking/grout is deteriorated/missing. Remove all old/deteriorated caulking/grout at enclosure walls.
 - Caulk perimeter of tub/shower at floor/flooring where caulking/grout is deteriorated/missing. Remove all old/deteriorated caulking at floor/flooring.
 - Repair/Resurface/Repaint bathroom wall(s) where deteriorated/damaged, where holes exist, and/or where paint is peeling/missing.
 - Remove mold/mildew at unit/room and correct condition causing mold growth. Drywall should be replaced when mold has covered the surface. Inadequate sanitation shall include any visible or otherwise demonstrable mold growth, excluding the presence of molds that is caused by inappropriate housekeeping practices or improper use of natural or mechanical ventilation.
 - Repair or replace deteriorated door.
 - Repair/resurface/repaint all deteriorated interior walls and ceiling areas.
 - Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause to believe that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS. NOTE: PROPERTY OWNER / MANAGEMENT COMPANY SHALL PROVIDE ACCESS TO UNIT(S) TO VERIFY ALL VIOLATION(S) HAVE BEEN CORRECTED. FAILURE TO PROVIDE ACCESS BY THE COMPLIANCE DATE BELOW MAY RESULT IN A CITATION BEING ISSUED.
-

Address**465 55TH ST 90805****Owner****451 E 55TH STREET LLC,****Total Violations****17****Violations:**

- Repair/repaint all deteriorated handrails and/or guardrails.
- Remove scattered trash, castoff items and debris around premises.
- The exterior wood trim is deteriorated. Repair or replace and paint the deteriorated wood trim.
- Repair/repaint/secure deteriorated exterior stairway.
- Repair/repaint deteriorated stair landings as directed. Obtain all required permits and inspections.
- Repair/replace all deteriorated/broken/missing light fixtures.
- The exterior stucco is damaged and deteriorated. Repair all the damaged or deteriorated stucco and color coat to match the existing color of the building.
- There is graffiti painted on the premises. Remove all graffiti from the premises.
- All parking facilities and loading areas shall be maintained in a neat and orderly condition and shall be clear of obstructions. Remove all obstructions from the driveway and/or garage which prevent vehicular access.
- Repair/replace missing or deteriorated garage door.
- Repair/replace and paint all deteriorated roof fascia, eaves and rafter tails.
- All construction or work for which a permit is required shall be subject to inspection by the building official. It shall be the duty of the permit tee to cause the work to be accessible and exposed for inspection purposes. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO, AND EXPOSE ALL CONSTRUCTION WORK FOR THE REQUIRED INSPECTIONS.
- It shall be the duty of the person doing the work authorized by a permit to notify the building official that such is ready for inspection and to provide access to and means for proper inspection of such work. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: REQUEST INSPECTION AND PROVIDE ACCESS TO ALL PERMITTED WORK
- No work shall be done on any part of the building or structure beyond the point indicated each successive inspection without first obtaining the written approval of the building official. There shall be a final inspection and approval on all buildings when completed and ready for occupancy. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: REQUEST AND OBTAIN ALL THE SUCCESSIVE AND REQUIRED INSPECTIONS AND WRITTEN APPROVALS ON ALL WORK AND OBTAIN WRITTEN APPROVAL PRIOR TO OCCUPANCY.
- Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause to believe that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS. NOTE: PROPERTY OWNER / MANAGEMENT COMPANY SHALL PROVIDE ACCESS TO UNIT(S) TO VERIFY ALL VIOLATION(S) HAVE BEEN CORRECTED. FAILURE TO PROVIDE ACCESS BY THE COMPLIANCE DATE BELOW MAY RESULT IN A CITATION BEING ISSUED.

- A. General. No person shall erect, construct, enlarge, alter, repair, remodel, move or demolish any building or part of a building or structure, or change the character or occupancy or use of any building or structure, or part of a building or structure or perform site grading in the city without first obtaining a permit covering such work from the building official. Whenever a building permit is required to abate a substandard condition as defined in LBMC 18.08.200S, code enforcement fees shall be paid in addition to the permit fees. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice:OBTAIN BUILDING PERMITS FROM THE DEVELOPMENT SERVICES DEPARTMENT FOR THE CODE ENFORCEMENT DIVISION FOR ALL UNPERMITTED CONSTRUCTION, REMODELING, OR OCCUPANCY CHANGE INCLUDING, BUT NOT LIMITED TO, THE FOLLOWING ITEMS OR DESCRIBED WORK:

- No new electrical installation shall be made nor any alteration or addition performed to any existing wiring, nor shall any wiring for the placing or installation of any electric light, power or heating device, or any apparatus which generates, transmits, transforms or utilizes electricity operating at a voltage exceeding twenty-five volts between conductors or capable of supplying more than fifty watts, be made without first obtaining an electrical permit.PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice:OBTAIN AN ELECTRICAL PERMIT FROM THE DEVELOPMENT SERVICES DEPARTMENT FOR THE CODE ENFORCEMENT DIVISION FOR ALL UNPERMITTED ELECTRICAL WORK OR EQUIPMENT INCLUDING, BUT NOT LIMITED TO, THE FOLLOWING ITEMS OR DESCRIBED WORK:

Address	Owner	Total Violations
489 55TH ST 1 90805	PEDRETTI, MICHAEL	9

Violations:

- Exterminate cockroaches at all units where infestation is present.Seal all cracks, gaps, and holes in walls, floors, and cupboards, and around piping insertions. Remove or paint over all spotting in unit. Provide pest control service to all infested units and surrounding units sharing common floors, ceilings, and walls with infested units. NOTE: Treatment is most effective when all units are treated on the same day, treatment is repeated to target hatching young in two weeks or every two weeks until infestation is removed.
 - Repair/replace all missing or damaged electrical outlet and switch plates.
 - Caulk gap between wall and sink/cabinet top behind sink. Remove all old/deteriorated caulking/grout. Perimeter of wall behind sink must be watertight.
 - Repair/Resurface/Repaint bathroom wall(s) where deteriorated/damaged, where holes exist, and/or where paint is peeling/missing.
 - Repair/replace all deteriorated/broken/missing light fixtures.
 - Provide/maintain/repair mechanical ventilation for fuel burning appliance(s). Obtain any required permits and inspections.
 - Repair/repaint/replace all deteriorated bathroom cabinets.
 - Repair/Replace all plumbing deficiencies.
 - Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause to believe that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed.PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice:PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS.NOTE: PROPERTY OWNER / MANAGEMENT COMPANY SHALL PROVIDE ACCESS TO UNIT(S) TO VERIFY ALL VIOLATION(S) HAVE BEEN CORRECTED. FAILURE TO PROVIDE ACCESS BY THE COMPLIANCE DATE BELOW MAY RESULT IN A CITATION BEING ISSUED.
-

Address	Owner	Total Violations
489 55TH ST 2 90805	PEDRETTI, MICHAEL	8

Violations:

- Repair leaking plumbing under kitchen sink.
- All properties shall be posted with the number or numbers designated for the principal entrance or entrances of a building. Install address numbers, not less than three inches in height, at the principal entrance of the building in plain view from the public right-of-way.
- Exterminate cockroaches at all units where infestation is present. Seal all cracks, gaps, and holes in walls, floors, and cupboards, and around piping insertions. Remove or paint over all spotting in unit. Provide pest control service to all infested units and surrounding units sharing common floors, ceilings, and walls with infested units. NOTE: Treatment is most effective when all units are treated on the same day, treatment is repeated to target hatching young in two weeks or every two weeks until infestation is removed.
- Repair/Replace deteriorated kitchen cabinet and/or doors.
- Caulk around toilet base.
- Remove mold/mildew at unit/room and correct condition causing mold growth. Drywall should be replaced when mold has covered the surface. Inadequate sanitation shall include any visible or otherwise demonstrable mold growth, excluding the presence of molds that is caused by inappropriate housekeeping practices or improper use of natural or mechanical ventilation.
- Bathroom sink.
- Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause to believe that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS. NOTE: PROPERTY OWNER / MANAGEMENT COMPANY SHALL PROVIDE ACCESS TO UNIT(S) TO VERIFY ALL VIOLATION(S) HAVE BEEN CORRECTED. FAILURE TO PROVIDE ACCESS BY THE COMPLIANCE DATE BELOW MAY RESULT IN A CITATION BEING ISSUED.

Address	Owner	Total Violations
489 55TH ST 3 90805	PEDRETTI, MICHAEL	15

Violations:

- Repair/replace all deteriorated electrical outlets/switches.
- Repair/resurface/repaint all deteriorated interior walls and ceiling areas.
- Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause to believe that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS. NOTE: PROPERTY OWNER / MANAGEMENT COMPANY SHALL PROVIDE ACCESS TO UNIT(S) TO VERIFY ALL VIOLATION(S) HAVE BEEN CORRECTED. FAILURE TO PROVIDE ACCESS BY THE COMPLIANCE DATE BELOW MAY RESULT IN A CITATION BEING ISSUED.

- Repair/replace inoperative/faulty stove, which may cause fire hazard.
- Repair toilet to flush properly. Replace all deteriorated/missing components.
- Secure toilet base to floor.
- Caulk around toilet base.
- Repair/replace all deteriorated/broken/missing light fixtures.
- Repair/Replace/Provide approved security locking mechanism for entry door(s). (Note: Do not install deadbolt locks that are keyed on both sides - use only those with thumb latches on entry doors).
- Repair/remove/reinstall closet door(s).
- Repair deteriorated entry door framing and/or jamb.
- Provide/maintain/repair mechanical ventilation for fuel burning appliance(s). Obtain any required permits and inspections.
- Secure toilet base to floor.
- Caulk around toilet base.
- Obtain all required permits and inspections and provide approved unit heater capable of heating unit to 70 degrees Fahrenheit, measured three feet above the floor. A temporary heater must be provided during winter months if a permanent heater cannot be repaired or replaced in a timely manner.

Address	Owner	Total Violations
489 55TH ST 4 90805	PEDRETTI, MICHAEL	12

Violations:

- Repair/replace all missing or damaged electrical outlet and switch plates.
- Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause to believe that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS. NOTE: PROPERTY OWNER / MANAGEMENT COMPANY SHALL PROVIDE ACCESS TO UNIT(S) TO VERIFY ALL VIOLATION(S) HAVE BEEN CORRECTED. FAILURE TO PROVIDE ACCESS BY THE COMPLIANCE DATE BELOW MAY RESULT IN A CITATION BEING ISSUED.
- Repair/Repaint/Weatherproof exterior door.
- Repair/Resurface/Repaint bathroom wall(s) where deteriorated/damaged, where holes exist, and/or where paint is peeling/missing.
- Repair/Replace/Repaint all deteriorated bathroom ceilings.
- Repair/repaint/replace all deteriorated bathroom cabinets.
- Repair/replace all deteriorated/broken/missing light fixtures.

- Repair/replace deteriorated kitchen drawers.
- Repair/Replace deteriorated kitchen cabinet and/or doors.
- Repair/replace deteriorated unit carpeting.
- Remove mold/mildew at unit/room and correct condition causing mold growth. Drywall should be replaced when mold has covered the surface. Inadequate sanitation shall include any visible or otherwise demonstrable mold growth, excluding the presence of molds that is caused by inappropriate housekeeping practices or improper use of natural or mechanical ventilation.
- Repair/replace windows to a weather tight condition.

Address	Owner	Total Violations
489 55TH ST 90805	PEDRETTI, MICHAEL	12

Violations:

- Replace/secure all deteriorated/missing exterior siding.
- Repair/repaint deteriorated electric meter enclosure and/or doors.
- Repair/repaint/seal exterior wood trim/surfaces where damaged and/or where paint is peeling/missing.
- Repair/replace missing or deteriorated garage door.
- The exterior stairs and/or landings are deteriorated, partially missing and unsafe. Rebuild the exterior stairs and/or landings to meet minimum code requirements.
- The exterior stairs are deteriorated. Rebuild the exterior stairs to meet minimum code requirements.
- Repair/repaint all deteriorated handrails and/or guardrails.
- Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause to believe that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS. NOTE: PROPERTY OWNER / MANAGEMENT COMPANY SHALL PROVIDE ACCESS TO UNIT(S) TO VERIFY ALL VIOLATION(S) HAVE BEEN CORRECTED. FAILURE TO PROVIDE ACCESS BY THE COMPLIANCE DATE BELOW MAY RESULT IN A CITATION BEING ISSUED.
- Repair/repaint deteriorated/missing exterior stucco.
- Repair/replace and paint all deteriorated roof fascia, eaves and rafter tails.
- Provide mosquito proof screens on all openable windows.
- The electrical dead front cover(s) of the electrical service/sub panel is missing, damaged or lacking parts which exposes the branch circuit wiring and/or energized parts to human contact. Provide an approved electrical service/sub panel dead front cover(s) for the electrical service/sub panel.

Address**845 E 6TH ST 90802****Owner****FORWARD 6TH STREET INVESTMENTS LLC****Total Violations****16****Violations:**

- Trim trees/shrubs to no less than 18 inches from building and roof to prevent rodent entrance to building(s).
- Remove scattered trash, castoff items and debris around premises.
- Repair/repaint/seal exterior wood trim/surfaces where damaged and/or where paint is peeling/missing.
- Repair/repaint deteriorated/missing exterior stucco.
- Repair all holes on the exterior of the building.
- Replace all broken window glass.
- Repair and repaint all deteriorated window frames/components/surfaces.
- Repair deteriorated entry door framing and/or jamb.
- Repair/Repaint/Weatherproof exterior door.
- Repair/replace deteriorated entry door threshold to provide a proper seal when closed.
- Provide mosquito proof screens on all openable windows.
- Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause to believe that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS. NOTE: PROPERTY OWNER / MANAGEMENT COMPANY SHALL PROVIDE ACCESS TO UNIT(S) TO VERIFY ALL VIOLATION(S) HAVE BEEN CORRECTED. FAILURE TO PROVIDE ACCESS BY THE COMPLIANCE DATE BELOW MAY RESULT IN A CITATION BEING ISSUED.
- Exterminate cockroaches at all units where infestation is present. Seal all cracks, gaps, and holes in walls, floors, and cupboards, and around piping insertions. Remove or paint over all spotting in unit. Provide pest control service to all infested units and surrounding units sharing common floors, ceilings, and walls with infested units. NOTE: Treatment is most effective when all units are treated on the same day, treatment is repeated to target hatching young in two weeks or every two weeks until infestation is removed.
- Provide smooth, trip free surfaces at all walkways.
- Exterminate rodents at unit/building. Remove all rodent droppings. Weather strip entry doors, and seal all holes at walls, floors and ceilings.
- Repair/replace all deteriorated/broken/missing light fixtures.

Address**1838 E 7TH ST 90813****Owner****WSC INVESTMENT PARTNERS LLC,****Total Violations****12****Violations:**

- A. General. No person shall erect, construct, enlarge, alter, repair, remodel, move or demolish any building or part of a building or structure, or change the character or occupancy or use of any building or structure, or part of a building or structure or perform site grading in the city without first obtaining a permit covering such work from the building official. Whenever a building permit is required to abate a substandard condition as defined in LBMC 18.08.200S, code enforcement fees shall be paid in addition to the permit fees. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: OBTAIN BUILDING PERMITS FROM THE DEVELOPMENT SERVICES DEPARTMENT FOR THE CODE ENFORCEMENT DIVISION FOR ALL UNPERMITTED CONSTRUCTION, REMODELING, OR OCCUPANCY CHANGE INCLUDING, BUT NOT LIMITED TO, THE FOLLOWING ITEMS OR DESCRIBED WORK:

- No work shall be done on any part of the building or structure beyond the point indicated each successive inspection without first obtaining the written approval of the building official. There shall be a final inspection and approval on all buildings when completed and ready for occupancy. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: REQUEST AND OBTAIN ALL THE SUCCESSIVE AND REQUIRED INSPECTIONS AND WRITTEN APPROVALS ON ALL WORK AND OBTAIN WRITTEN APPROVAL PRIOR TO OCCUPANCY.

- All construction or work for which a permit is required shall be subject to inspection by the building official. It shall be the duty of the permittee to cause the work to be accessible and exposed for inspection purposes. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO, AND EXPOSE ALL CONSTRUCTION WORK FOR THE REQUIRED INSPECTIONS.

- It shall be the duty of the person doing the work authorized by a permit to notify the building official that such is ready for inspection and to provide access to and means for proper inspection of such work. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: REQUEST INSPECTION AND PROVIDE ACCESS TO ALL PERMITTED WORK

- No new electrical installation shall be made nor any alteration or addition performed to any existing wiring, nor shall any wiring for the placing or installation of any electric light, power or heating device, or any apparatus which generates, transmits, transforms or utilizes electricity operating at a voltage exceeding twenty-five volts between conductors or capable of supplying more than fifty watts, be made without first obtaining an electrical permit. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: OBTAIN AN ELECTRICAL PERMIT FROM THE DEVELOPMENT SERVICES DEPARTMENT FOR THE CODE ENFORCEMENT DIVISION FOR ALL UNPERMITTED ELECTRICAL WORK OR EQUIPMENT INCLUDING, BUT NOT LIMITED TO, THE FOLLOWING ITEMS OR DESCRIBED WORK:

- No person shall install, alter, reconstruct or repair any heating, ventilating, cooling, or refrigeration equipment unless a permit therefore has been obtained from the building official except as otherwise provided in this code. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: OBTAIN A MECHANICAL PERMIT FROM THE DEVELOPMENT SERVICES DEPARTMENT FOR THE CODE ENFORCEMENT DIVISION FOR ALL UNPERMITTED MECHANICAL WORK OR EQUIPMENT INCLUDING, BUT NOT LIMITED TO, THE FOLLOWING ITEMS OR DESCRIBED WORK:

- No person shall commence, do, install, erect, construct, remove, add to or change any plumbing, water piping, gas piping, water heater, water heater vents, water treating equipment, or any appliance or device regulated by this chapter without obtaining a permit approving the proposed quality and character of workmanship and materials. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: OBTAIN A PLUMBING PERMIT FROM THE DEVELOPMENT SERVICES DEPARTMENT FOR THE CODE ENFORCEMENT DIVISION FOR ALL UNPERMITTED PLUMBING WORK OR EQUIPMENT INCLUDING, BUT NOT LIMITED TO, THE FOLLOWING ITEMS OR DESCRIBED WORK:

- Repair and repaint all deteriorated window frames/components/surfaces.

- Repair/repaint/seal exterior wood trim/surfaces where damaged and/or where paint is peeling/missing.

- Repair/repaint deteriorated/missing exterior stucco.

- Repair/replace and paint all deteriorated roof fascia, eaves and rafter tails.

- Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause to believe that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS. NOTE: PROPERTY OWNER / MANAGEMENT COMPANY SHALL PROVIDE ACCESS TO UNIT(S) TO VERIFY ALL VIOLATION(S) HAVE BEEN CORRECTED. FAILURE TO PROVIDE ACCESS BY THE COMPLIANCE DATE BELOW MAY RESULT IN A CITATION BEING ISSUED.

Address	Owner	Total Violations
834 E 8TH ST 90813	OLIVEROS ET AL., CATALINA	3

Violations:

- Repair/resurface/repaint deteriorated balcony/landing.
- Remove scattered trash, castoff items and debris around premises.

- Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause to believe that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS. NOTE: PROPERTY OWNER / MANAGEMENT COMPANY SHALL PROVIDE ACCESS TO UNIT(S) TO VERIFY ALL VIOLATION(S) HAVE BEEN CORRECTED. FAILURE TO PROVIDE ACCESS BY THE COMPLIANCE DATE BELOW MAY RESULT IN A CITATION BEING ISSUED.

Address	Owner	Total Violations
125 E 9TH ST 90813	FRAGOSO, ROBERT	14

Violations:

- Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause to believe that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS. NOTE: PROPERTY OWNER / MANAGEMENT COMPANY SHALL PROVIDE ACCESS TO UNIT(S) TO VERIFY ALL VIOLATION(S) HAVE BEEN CORRECTED. FAILURE TO PROVIDE ACCESS BY THE COMPLIANCE DATE BELOW MAY RESULT IN A CITATION BEING ISSUED.

- Portions of the roof sheathing are deteriorated. Replace all deteriorated portions of the roof sheathing and repair the roof with approved materials installed in an approved manner.
- Route dryer exhaust to exterior of building. Maintain dryer duct free of accumulated lint on a regular basis.

- No work shall be done on any part of the building or structure beyond the point indicated each successive inspection without first obtaining the written approval of the building official. There shall be a final inspection and approval on all buildings when completed and ready for occupancy. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: REQUEST AND OBTAIN ALL THE SUCCESSIVE AND REQUIRED INSPECTIONS AND WRITTEN APPROVALS ON ALL WORK AND OBTAIN WRITTEN APPROVAL PRIOR TO OCCUPANCY.

- It shall be the duty of the person doing the work authorized by a permit to notify the building official that such is ready for inspection and to provide access to and means for proper inspection of such work. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: REQUEST INSPECTION AND PROVIDE ACCESS TO ALL PERMITTED WORK

- All construction or work for which a permit is required shall be subject to inspection by the building official. It shall be the duty of the permit tee to cause the work to be accessible and exposed for inspection purposes. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO, AND EXPOSE ALL CONSTRUCTION WORK FOR THE REQUIRED INSPECTIONS.

- Repair and repaint all deteriorated window frames/components/surfaces.

- Provide mosquito proof screens on all openable windows.

- Repair/replace and paint all deteriorated roof fascia, eaves and rafter tails.

- Repair/repaint/seal exterior wood trim/surfaces where damaged and/or where paint is peeling/missing.

- Replace/secure all deteriorated/missing exterior siding.

- A. General. No person shall erect, construct, enlarge, alter, repair, remodel, move or demolish any building or part of a building or structure, or change the character or occupancy or use of any building or structure, or part of a building or structure or perform site grading in the city without first obtaining a permit covering such work from the building official. Whenever a building permit is required to abate a substandard condition as defined in LBMC 18.08.200S, code enforcement fees shall be paid in addition to the permit fees. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: OBTAIN BUILDING PERMITS FROM THE DEVELOPMENT SERVICES DEPARTMENT FOR THE CODE ENFORCEMENT DIVISION FOR ALL UNPERMITTED CONSTRUCTION, REMODELING, OR OCCUPANCY CHANGE INCLUDING, BUT NOT LIMITED TO, THE FOLLOWING ITEMS OR DESCRIBED WORK:

- Trash and garbage cans cannot be stored in front or side yards visible from public streets. Remove the trash cans and/or trash bins stored or kept in yard areas visible from public streets.

- Provide 1/4 inch hardware mesh on all foundation vent openings for rodent proofing.

Address

771 ALAMITOS AVE 90813

Owner

HARSH INVESTMENT LLC,

Total Violations

16

Violations:

- Repair/repaint deteriorated/missing exterior stucco.

- LBMC 9.65.040. It shall be the duty of responsible person(s) to prevent accumulation and storage of abandoned, wrecked, dismantled, or inoperative vehicles or parts thereof, except for those vehicles or parts thereof exempted pursuant to Long Beach Municipal Code Section 10.46.030. Remove all inoperative vehicles or vehicle parts from the property or bring vehicle(s) to an operative condition including current registration status

- The water heater temperature and pressure relief valve outlet is not piped to the outside of the building. Provide approved piping from the valve outlet to the outside of the building and terminating no more than 2 feet nor less than 6 inches above the ground.

- It shall be the duty of the person doing the work authorized by a permit to notify the building official that such is ready for inspection and to provide access to and means for proper inspection of such work. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: REQUEST INSPECTION AND PROVIDE ACCESS TO ALL PERMITTED WORK

- The water heater is not properly vented. Vent the water heater in an approved manner using approved materials.

- No work shall be done on any part of the building or structure beyond the point indicated each successive inspection without first obtaining the written approval of the building official. There shall be a final inspection and approval on all buildings when completed and ready for occupancy. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: REQUEST AND OBTAIN ALL THE SUCCESSIVE AND REQUIRED INSPECTIONS AND WRITTEN APPROVALS ON ALL WORK AND OBTAIN WRITTEN APPROVAL PRIOR TO OCCUPANCY.

- A. General. No person shall erect, construct, enlarge, alter, repair, remodel, move or demolish any building or part of a building or structure, or change the character or occupancy or use of any building or structure, or part of a building or structure or perform site grading in the city without first obtaining a permit covering such work from the building official. Whenever a building permit is required to abate a substandard condition as defined in LBMC 18.08.200S, code enforcement fees shall be paid in addition to the permit fees. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: OBTAIN BUILDING PERMITS FROM THE DEVELOPMENT SERVICES DEPARTMENT FOR THE CODE ENFORCEMENT DIVISION FOR ALL UNPERMITTED CONSTRUCTION, REMODELING, OR OCCUPANCY CHANGE INCLUDING, BUT NOT LIMITED TO, THE FOLLOWING ITEMS OR DESCRIBED WORK:

- Plans, engineering calculations, diagrams and other data shall be submitted in one or more sets with each application for a permit. The building official may require plans, computations and specifications to be prepared and designed by an engineer or architect licensed by the state of California to practice as such. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE THREE SETS OF PLANS, SPECIFICATIONS OR OTHER DETAILS AS REQUIRED BY THE DEPARTMENT OF DEVELOPMENT SERVICES WITH THE APPLICATION FOR THE REQUIRED PERMIT.

- No person shall commence, do, install, erect, construct, remove, add to or change any plumbing, water piping, gas piping, water heater, water heater vents, water treating equipment, or any appliance or device regulated by this chapter without obtaining a permit approving the proposed quality and character of workmanship and materials. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: OBTAIN A PLUMBING PERMIT FROM THE DEVELOPMENT SERVICES DEPARTMENT FOR THE CODE ENFORCEMENT DIVISION FOR ALL UNPERMITTED PLUMBING WORK OR EQUIPMENT INCLUDING, BUT NOT LIMITED TO, THE FOLLOWING ITEMS OR DESCRIBED WORK:

- The supporting structural frame members are deteriorated. Replace the damaged supporting structural frame members to adequately support the structure.

- Remove scattered trash, castoff items and debris around premises.

- Provide 1/4 inch hardware mesh on all foundation vent openings for rodent proofing.

- Property must be clean and free from all weeds and/or debris at all times. Remove all weeds and/or debris from the property.

- Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause to believe that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS. NOTE: PROPERTY OWNER / MANAGEMENT COMPANY SHALL PROVIDE ACCESS TO UNIT(S) TO VERIFY ALL VIOLATION(S) HAVE BEEN CORRECTED. FAILURE TO PROVIDE ACCESS BY THE COMPLIANCE DATE BELOW MAY RESULT IN A CITATION BEING ISSUED.

- All construction or work for which a permit is required shall be subject to inspection by the building official. It shall be the duty of the permittee to cause the work to be accessible and exposed for inspection purposes. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO, AND EXPOSE ALL CONSTRUCTION WORK FOR THE REQUIRED INSPECTIONS.

- All parking facilities and loading areas shall be maintained in a neat and orderly condition and shall be clear of obstructions. Remove all obstructions from the driveway and/or garage which prevent vehicular access.

Address	Owner	Total Violations
238 E ARTESIA BLVD 90805	FRATOVICH, FERNANDO	11
Violations:		
<ul style="list-style-type: none"> - There is graffiti painted on the premises. Remove all graffiti from the premises. - Remove scattered trash, castoff items and debris around premises. - Repair/repaint deteriorated electric meter enclosure and/or doors. - All construction or work for which a permit is required shall be subject to inspection by the building official. It shall be the duty of the permit tee to cause the work to be accessible and exposed for inspection purposes.PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice:PROVIDE ACCESS TO, AND EXPOSE ALL CONSTRUCTION WORK FOR THE REQUIRED INSPECTIONS. - It shall be the duty of the person doing the work authorized by a permit to notify the building official that such is ready for inspection and to provide access to and means for proper inspection of such work.PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice:REQUEST INSPECTION AND PROVIDE ACCESS TO ALL PERMITTED WORK - No work shall be done on any part of the building or structure beyond the point indicated each successive inspection without first obtaining the written approve of the building official. There shall be a final inspection and approval on all buildings when completed and ready for occupancy.PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice:REQUEST AND OBTAIN ALL THE SUCCESSIVE AND REQUIRED INSPECTIONSAND WRITTEN APPROVALS ON ALL WORK AND OBTAIN WRITTEN APPROVAL PRIOR TO OCCUPANCY. - Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause tobelieve that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed.PROPERTY OWNER: Take the following corrective action in conjunction withany other corrective actions in this Notice:PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS.NOTE: PROPERTY OWNER / MANAGEMENT COMPANY SHALL PROVIDE ACCESS TO UNIT(S) TO VERIFY ALL VIOLATION(S) HAVE BEEN CORRECTED. FAILURE TO PROVIDE ACCESS BY THE COMPLIANCE DATE BELOW MAY RESULT IN A CITATION BEING ISSUED. - Repair/repaint/seal exterior wood trim/surfaces where damaged and/or where paint is peeling/missing. - Repair/repaint/secure deteriorated exterior stairway. - Repair/repaint deteriorated stair landings as directed. Obtain all required permits and inspections. - A. General. No person shall erect, construct, enlarge, alter, repair, remodel, move or demolish any building or part of a building or structure, or change the character or occupancy or use of any building or structure, or part of a building or structure or perform site grading in the city without first obtaining a permit covering such work from the building official. Whenever a building permit is required to abate a substandard condition as defined in LBMC 18.08.200S, code enforcement fees shall be paid in addition to the permit fees. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice:OBTAIN BUILDING PERMITS FROM THE DEVELOPMENT SERVICES DEPARTMENT FOR THE CODE ENFORCEMENT DIVISION FOR ALL UNPERMITTED CONSTRUCTION, REMODELING, OR OCCUPANCY CHANGE INCLUDING, BUT NOT LIMITED TO, THE FOLLOWING ITEMS OR DESCRIBED WORK: 		

Address	Owner	Total Violations
810 BELMONT AVE 90804	ALBERT, RICHARD	17
Violations:		

- Repair/resurface/repaint deteriorated balcony/landing.
- Repair/resurface/repaint deteriorated guardrails; loose/broken components.
- The roof tile is missing. Replace the missing tiles with approved materials installed in an approved manner.
- Several of the exterior stair treads are damaged. Replace the damaged stair treads.
- Trim trees/shrubs to no less than 18 inches from building and roof to prevent rodent entrance to building(s).
- Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause to believe that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS. NOTE: PROPERTY OWNER / MANAGEMENT COMPANY SHALL PROVIDE ACCESS TO UNIT(S) TO VERIFY ALL VIOLATION(S) HAVE BEEN CORRECTED. FAILURE TO PROVIDE ACCESS BY THE COMPLIANCE DATE BELOW MAY RESULT IN A CITATION BEING ISSUED.
- A. General. No person shall erect, construct, enlarge, alter, repair, remodel, move or demolish any building or part of a building or structure, or change the character or occupancy or use of any building or structure, or part of a building or structure or perform site grading in the city without first obtaining a permit covering such work from the building official. Whenever a building permit is required to abate a substandard condition as defined in LBMC 18.08.200S, code enforcement fees shall be paid in addition to the permit fees. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: OBTAIN BUILDING PERMITS FROM THE DEVELOPMENT SERVICES DEPARTMENT FOR THE CODE ENFORCEMENT DIVISION FOR ALL UNPERMITTED CONSTRUCTION, REMODELING, OR OCCUPANCY CHANGE INCLUDING, BUT NOT LIMITED TO, THE FOLLOWING ITEMS OR DESCRIBED WORK:
 - Plans, engineering calculations, diagrams and other data shall be submitted in one or more sets with each application for a permit. The building official may require plans, computations and specifications to be prepared and designed by an engineer or architect licensed by the state of California to practice as such. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE THREE SETS OF PLANS, SPECIFICATIONS OR OTHER DETAILS AS REQUIRED BY THE DEPARTMENT OF DEVELOPMENT SERVICES WITH THE APPLICATION FOR THE REQUIRED PERMIT.
 - No new electrical installation shall be made nor any alteration or addition performed to any existing wiring, nor shall any wiring for the placing or installation of any electric light, power or heating device, or any apparatus which generates, transmits, transforms or utilizes electricity operating at a voltage exceeding twenty-five volts between conductors or capable of supplying more than fifty watts, be made without first obtaining an electrical permit. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: OBTAIN AN ELECTRICAL PERMIT FROM THE DEVELOPMENT SERVICES DEPARTMENT FOR THE CODE ENFORCEMENT DIVISION FOR ALL UNPERMITTED ELECTRICAL WORK OR EQUIPMENT INCLUDING, BUT NOT LIMITED TO, THE FOLLOWING ITEMS OR DESCRIBED WORK:
 - No person shall install, alter, reconstruct or repair any heating, ventilating, cooling, or refrigeration equipment unless a permit therefore has been obtained from the building official except as otherwise provided in this code. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: OBTAIN A MECHANICAL PERMIT FROM THE DEVELOPMENT SERVICES DEPARTMENT FOR THE CODE ENFORCEMENT DIVISION FOR ALL UNPERMITTED MECHANICAL WORK OR EQUIPMENT INCLUDING, BUT NOT LIMITED TO, THE FOLLOWING ITEMS OR DESCRIBED WORK:
 - No person shall commence, do, install, erect, construct, remove, add to or change any plumbing, water piping, gas piping, water heater, water heater vents, water treating equipment, or any appliance or device regulated by this chapter without obtaining a permit approving the proposed quality and character of workmanship and materials. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: OBTAIN A PLUMBING PERMIT FROM THE DEVELOPMENT SERVICES DEPARTMENT FOR THE CODE ENFORCEMENT DIVISION FOR ALL UNPERMITTED PLUMBING WORK OR EQUIPMENT INCLUDING, BUT NOT LIMITED TO, THE FOLLOWING ITEMS OR DESCRIBED WORK:

- No work shall be done on any part of the building or structure beyond the point indicated each successive inspection without first obtaining the written approval of the building official. There shall be a final inspection and approval on all buildings when completed and ready for occupancy. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: REQUEST AND OBTAIN ALL THE SUCCESSIVE AND REQUIRED INSPECTIONS AND WRITTEN APPROVALS ON ALL WORK AND OBTAIN WRITTEN APPROVAL PRIOR TO OCCUPANCY.

- It shall be the duty of the person doing the work authorized by a permit to notify the building official that such is ready for inspection and to provide access to and means for proper inspection of such work. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: REQUEST INSPECTION AND PROVIDE ACCESS TO ALL PERMITTED WORK

- All construction or work for which a permit is required shall be subject to inspection by the building official. It shall be the duty of the permittee to cause the work to be accessible and exposed for inspection purposes. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO, AND EXPOSE ALL CONSTRUCTION WORK FOR THE REQUIRED INSPECTIONS.

- Repair/repaint deteriorated/missing exterior stucco.

- Repair/repaint/seal exterior wood trim/surfaces where damaged and/or where paint is peeling/missing.

- Provide mosquito proof screens on all openable windows.

Address

Owner

Total Violations

120 BONITO AVE 90802

TAYLOR, TIMOTHY

11

Violations:

- Repair and repaint all deteriorated window frames/components/surfaces.

- Repair deteriorated entry door framing and/or jamb.

- Repair/Repaint/Weatherproof exterior door.

- Repair deteriorated fencing and/or gate(s).

- Trim all overgrown foliage/lawns/shrubs at property to prevent vermin/rodent harborage or entrance to units/buildings.

- Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause to believe that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS. NOTE: PROPERTY OWNER / MANAGEMENT COMPANY SHALL PROVIDE ACCESS TO UNIT(S) TO VERIFY ALL VIOLATION(S) HAVE BEEN CORRECTED. FAILURE TO PROVIDE ACCESS BY THE COMPLIANCE DATE BELOW MAY RESULT IN A CITATION BEING ISSUED.

- Repair/repaint deteriorated gas meter enclosure and/or doors.

- Repair/repaint deteriorated electric meter enclosure and/or doors.

- Repair/repaint/seal exterior wood trim/surfaces where damaged and/or where paint is peeling/missing.

- Replace/secure all deteriorated/missing exterior siding.

- Repair/replace and paint all deteriorated roof fascia, eaves and rafter tails.

Address	Owner	Total Violations
5200 E BROADWAY E 90803	WHELAN, ALLAN	11

Violations:

- A. General. No person shall erect, construct, enlarge, alter, repair, remodel, move or demolish any building or part of a building or structure, or change the character or occupancy or use of any building or structure, or part of a building or structure or perform site grading in the city without first obtaining a permit covering such work from the building official. Whenever a building permit is required to abate a substandard condition as defined in LBMC 18.08.200S, code enforcement fees shall be paid in addition to the permit fees. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice:OBTAIN BUILDING PERMITS FROM THE DEVELOPMENT SERVICES DEPARTMENT FOR THE CODE ENFORCEMENT DIVISION FOR ALL UNPERMITTED CONSTRUCTION, REMODELING, OR OCCUPANCY CHANGE INCLUDING, BUT NOT LIMITED TO, THE FOLLOWING ITEMS OR DESCRIBED WORK:
- No new building, structure or addition shall be used or occupied, and no change in the existing occupancy classification of a building, structure or portion thereof shall be made until the building official has issued a certificate of occupancy therefore as provided in this chapter.PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice:OBTAIN A CERTIFICATE OF OCCUPANCY FROM THE BUILDING OFFICIAL FORTHE BUILDING WORK, OR ADDITION, PRIOR TO USING OR OCCUPYING, ORCEASE USE AND VACATE THE UNAPPROVED BUILDING, STRUCTURE OR ADDITION AT ONCE.
- No new electrical installation shall be made nor any alteration or addition performed to any existing wiring, nor shall any wiring for the placing or installation of any electric light, power or heating device, or any apparatus which generates, transmits, transforms or utilizes electricity operating at a voltage exceeding twenty-five volts between conductors or capable of supplying more than fifty watts, be made without first obtaining an electrical permit.PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice:OBTAIN AN ELECTRICAL PERMIT FROM THE DEVELOPMENT SERVICES DEPARTMENT FOR THE CODE ENFORCEMENT DIVISION FOR ALL UNPERMITTED ELECTRICAL WORK OR EQUIPMENT INCLUDING, BUT NOT LIMITED TO, THE FOLLOWING ITEMS OR DESCRIBED WORK:
- No person shall install, alter, reconstruct or repair any heating, ventilating, cooling, or refrigeration equipment unless a permit therefore has been obtained from the building official except as otherwise provided in this code.PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice:OBTAIN A MECHANICAL PERMIT FROM THE DEVELOPMENT SERVICES DEPARTMENT FOR THE CODE ENFORCEMENT DIVISION FOR ALL UNPERMITTED MECHANICAL WORK OR EQUIPMENT INCLUDING, BUT NOTLIMITED TO, THE FOLLOWING ITEMS OR DESCRIBED WORK:
- No person shall commence, do, install, erect, construct, remove, add to or change any plumbing, water piping, gas piping, water heater, water heater vents, water treating equipment, or any appliance or device regulated by this chapter without obtaining a permit approving the proposed quality and character of workmanship and materials."PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice:OBTAIN A PLUMBING PERMIT FROM THE DEVELOPMENT SERVICES DEPARTMENT FOR THE CODE ENFORCEMENT DIVISION FOR ALL UNPERMITTED PLUMBING WORK OR EQUIPMENT INCLUDING, BUT NOT LIMITED TO, THE FOLLOWING ITEMS OR DESCRIBED WORK:
- Plans, engineering calculations, diagrams and other data shall be submitted in one or more sets with each application for a permit. The building official may require plans, computations and specifications to be prepared and designed by an engineer or architect licensed by the state of California to practice as such.PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice:PROVIDE THREE SETS OF PLANS, SPECIFICATIONS OR OTHER DETAILS ASREQUIRED BY THE DEPARTMENT OF DEVELOPMENT SERVICES WITH THE APPLICATION FOR THE REQUIRED PERMIT.
- All construction or work for which a permit is required shall be subject to inspection by the building official. It shall be the duty of the permit tee to cause the work to be accessible and exposed for inspection purposes.PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice:PROVIDE ACCESS TO, AND EXPOSE ALL CONSTRUCTION WORK FOR THE REQUIRED INSPECTIONS.
- The electrical outlets in the bathroom are required to be GFCI protected. Install the required GFCI protected receptacles in the bathrooms.

- There is open wiring throughout the interior of the building. Terminate all open wiring in an approved enclosure.
- The cord wiring in the interior of the building is unapproved. Remove the unapproved cord wiring from the interior of the building.
- Several rooms lack the minimum number of electrical outlets. Install the minimum number of approved electrical outlets in all rooms.

Address	Owner	Total Violations
1043 CERRITOS AVE 90813	PHAN, THOM	15

Violations:

- A. General. No person shall erect, construct, enlarge, alter, repair, remodel, move or demolish any building or part of a building or structure, or change the character or occupancy or use of any building or structure, or part of a building or structure or perform site grading in the city without first obtaining a permit covering such work from the building official. Whenever a building permit is required to abate a substandard condition as defined in LBMC 18.08.200S, code enforcement fees shall be paid in addition to the permit fees. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice:OBTAIN BUILDING PERMITS FROM THE DEVELOPMENT SERVICES DEPARTMENT FOR THE CODE ENFORCEMENT DIVISION FOR ALL UNPERMITTED CONSTRUCTION, REMODELING, OR OCCUPANCY CHANGE INCLUDING, BUT NOT LIMITED TO, THE FOLLOWING ITEMS OR DESCRIBED WORK:
 - Plans, engineering calculations, diagrams and other data shall be submitted in one or more sets with each application for a permit. The building official may require plans, computations and specifications to be prepared and designed by an engineer or architect licensed by the state of California to practice as such.PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice:PROVIDE THREE SETS OF PLANS, SPECIFICATIONS OR OTHER DETAILS ASREQUIRED BY THE DEPARTMENT OF DEVELOPMENT SERVICES WITH THE APPLICATION FOR THE REQUIRED PERMIT.
 - All construction or work for which a permit is required shall be subject to inspection by the building official. It shall be the duty of the permit tee to cause the work to be accessible and exposed for inspection purposes.PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice:PROVIDE ACCESS TO, AND EXPOSE ALL CONSTRUCTION WORK FOR THE REQUIRED INSPECTIONS.
 - It shall be the duty of the person doing the work authorized by a permit to notify the building official that such is ready for inspection and to provide access to and means for proper inspection of such work.PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice:REQUEST INSPECTION AND PROVIDE ACCESS TO ALL PERMITTED WORK
 - No work shall be done on any part of the building or structure beyond the point indicated each successive inspection without first obtaining the written approve of the building official. There shall be a final inspection and approval on all buildings when completed and ready for occupancy.PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice:REQUEST AND OBTAIN ALL THE SUCCESSIVE AND REQUIRED INSPECTIONSAND WRITTEN APPROVALS ON ALL WORK AND OBTAIN WRITTEN APPROVAL PRIOR TO OCCUPANCY.
 - All parking facilities and loading areas shall be maintained in a neat and orderly condition and shall be clear of obstructions. Remove all obstructions from the driveway and/or garage which prevent vehicular access.
 - The building lacks the required carbon monoxide alarms. Install carbon monoxide alarms outside of each sleeping area in the immediate vicinity of the bedrooms and on every level of the dwelling unit. The alarms may be powered by battery or building wiring.
 - Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause tobelieve that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed.PROPERTY OWNER: Take the following corrective action in conjunction withany other corrective actions in this Notice:PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS.NOTE: PROPERTY OWNER / MANAGEMENT COMPANY SHALL PROVIDE ACCESS TO UNIT(S) TO VERIFY ALL VIOLATION(S) HAVE BEEN CORRECTED. FAILURE TO PROVIDE ACCESS BY THE COMPLIANCE DATE BELOW MAY RESULT IN A CITATION BEING ISSUED.

- Replace deteriorated water heater. Obtain all required inspections and permits. Properly vent gas water heater. Strap or secure water heater to protect from earthquake hazards.
- Repair/Replace/Provide approved security locking mechanism for entry door(s). (Note: Do not install deadbolt locks that are keyed on both sides - use only those with thumb latches on entry doors).
- Repair/repaint/seal exterior wood trim/surfaces where damaged and/or where paint is peeling/missing.
- Repair/replace and paint all deteriorated roof fascia, eaves and rafter tails.
- Repair and repaint all deteriorated window frames/components/surfaces.
- Remove scattered trash, castoff items and debris around premises.
- Repair/repaint deteriorated/missing exterior stucco.

Address	Owner	Total Violations
1069 CERRITOS AVE 90813	HOPSON, MARK	10

Violations:

- Remove scattered trash, castoff items and debris around premises.
- Trim trees/shrubs to no less than 18 inches from building and roof to prevent rodent entrance to building(s).
- Repair/repaint/seal exterior wood trim/surfaces where damaged and/or where paint is peeling/missing.
- Repair/repaint deteriorated/missing exterior stucco.
- Repair/Replace/Provide approved security locking mechanism for entry door(s). (Note: Do not install deadbolt locks that are keyed on both sides - use only those with thumb latches on entry doors).
- Provide 1/4 inch hardware mesh on all foundation vent openings for rodent proofing.
- Repair/replace all deteriorated/broken/missing light fixtures.
- Repair/replace and paint all deteriorated roof fascia, eaves and rafter tails.
- Repair/replace/remove deteriorated rain gutters and/or down spouts so as to direct rain water runoff away from buildings.
- Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause to believe that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS. NOTE: PROPERTY OWNER / MANAGEMENT COMPANY SHALL PROVIDE ACCESS TO UNIT(S) TO VERIFY ALL VIOLATION(S) HAVE BEEN CORRECTED. FAILURE TO PROVIDE ACCESS BY THE COMPLIANCE DATE BELOW MAY RESULT IN A CITATION BEING ISSUED.

Address	Owner	Total Violations
551 DAISY AVE 90802	SALAZAR, PAUL	7
Violations:		
<p>- A. General. No person shall erect, construct, enlarge, alter, repair, remodel, move or demolish any building or part of a building or structure, or change the character or occupancy or use of any building or structure, or part of a building or structure or perform site grading in the city without first obtaining a permit covering such work from the building official. Whenever a building permit is required to abate a substandard condition as defined in LBMC 18.08.200S, code enforcement fees shall be paid in addition to the permit fees. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice:OBTAIN BUILDING PERMITS FROM THE DEVELOPMENT SERVICES DEPARTMENT FOR THE CODE ENFORCEMENT DIVISION FOR ALL UNPERMITTED CONSTRUCTION, REMODELING, OR OCCUPANCY CHANGE INCLUDING, BUT NOT LIMITED TO, THE FOLLOWING ITEMS OR DESCRIBED WORK:</p> <p>- No new electrical installation shall be made nor any alteration or addition performed to any existing wiring, nor shall any wiring for the placing or installation of any electric light, power or heating device, or any apparatus which generates, transmits, transforms or utilizes electricity operating at a voltage exceeding twenty-five volts between conductors or capable of supplying more than fifty watts, be made without first obtaining an electrical permit.PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice:OBTAIN AN ELECTRICAL PERMIT FROM THE DEVELOPMENT SERVICES DEPARTMENT FOR THE CODE ENFORCEMENT DIVISION FOR ALL UNPERMITTED ELECTRICAL WORK OR EQUIPMENT INCLUDING, BUT NOT LIMITED TO, THE FOLLOWING ITEMS OR DESCRIBED WORK:</p> <p>- It shall be the duty of the person doing the work authorized by a permit to notify the building official that such is ready for inspection and to provide access to and means for proper inspection of such work.PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice:REQUEST INSPECTION AND PROVIDE ACCESS TO ALL PERMITTED WORK</p> <p>- All construction or work for which a permit is required shall be subject to inspection by the building official. It shall be the duty of the permit tee to cause the work to be accessible and exposed for inspection purposes.PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice:PROVIDE ACCESS TO, AND EXPOSE ALL CONSTRUCTION WORK FOR THE REQUIRED INSPECTIONS.</p> <p>- No work shall be done on any part of the building or structure beyond the point indicated each successive inspection without first obtaining the written approval of the building official. There shall be a final inspection and approval on all buildings when completed and ready for occupancy.PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice:REQUEST AND OBTAIN ALL THE SUCCESSIVE AND REQUIRED INSPECTIONSAND WRITTEN APPROVALS ON ALL WORK AND OBTAIN WRITTEN APPROVAL PRIOR TO OCCUPANCY.</p> <p>- Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause to believe that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed.PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS.</p> <p>- NOTE: The subject substandard building(s) is/are located in an historical preservation district. Prior to obtaining any permits or commencing any corrective work contact the Historic Preservation Officer for written approval at (562) 570-6288.</p>		

Address	Owner	Total Violations
3595 ELM AVE 24 90807	M AND G HOLDINGS LLC,	5
Violations:		
<p>- All construction or work for which a permit is required shall be subject to inspection by the building official. It shall be the duty of the permit tee to cause the work to be accessible and exposed for inspection purposes.PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice:PROVIDE ACCESS TO, AND EXPOSE ALL CONSTRUCTION WORK FOR THE REQUIRED INSPECTIONS.</p>		

- It shall be the duty of the person doing the work authorized by a permit to notify the building official that such is ready for inspection and to provide access to and means for proper inspection of such work. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: REQUEST INSPECTION AND PROVIDE ACCESS TO ALL PERMITTED WORK

- No work shall be done on any part of the building or structure beyond the point indicated each successive inspection without first obtaining the written approval of the building official. There shall be a final inspection and approval on all buildings when completed and ready for occupancy. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: REQUEST AND OBTAIN ALL THE SUCCESSIVE AND REQUIRED INSPECTIONS AND WRITTEN APPROVALS ON ALL WORK AND OBTAIN WRITTEN APPROVAL PRIOR TO OCCUPANCY.

- A. General. No person shall erect, construct, enlarge, alter, repair, remodel, move or demolish any building or part of a building or structure, or change the character or occupancy or use of any building or structure, or part of a building or structure or perform site grading in the city without first obtaining a permit covering such work from the building official. Whenever a building permit is required to abate a substandard condition as defined in LBMC 18.08.200S, code enforcement fees shall be paid in addition to the permit fees. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: OBTAIN BUILDING PERMITS FROM THE DEVELOPMENT SERVICES DEPARTMENT FOR THE CODE ENFORCEMENT DIVISION FOR ALL UNPERMITTED CONSTRUCTION, REMODELING, OR OCCUPANCY CHANGE INCLUDING, BUT NOT LIMITED TO, THE FOLLOWING ITEMS OR DESCRIBED WORK:

- Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause to believe that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS. NOTE: PROPERTY OWNER / MANAGEMENT COMPANY SHALL PROVIDE ACCESS TO UNIT(S) TO VERIFY ALL VIOLATION(S) HAVE BEEN CORRECTED. FAILURE TO PROVIDE ACCESS BY THE COMPLIANCE DATE BELOW MAY RESULT IN A CITATION BEING ISSUED.

Address

Owner

Total Violations

1102 GARDENIA AVE 90813

SHAUD, SANDRA

15

Violations:

- Remove scattered trash, castoff items and debris around premises.

- Trim trees/shrubs to no less than 18 inches from building and roof to prevent rodent entrance to building(s).

- Remove trash/debris from roof areas.

- Provide trash facilities adequate enough to handle trash load of tenants on a calendar week basis. Ensure that all containers have closeable lids and are kept closed at all times. Note: Increased frequency of pick up and/or additional containers may be required to accomplish this task.

- All construction or work for which a permit is required shall be subject to inspection by the building official. It shall be the duty of the permittee to cause the work to be accessible and exposed for inspection purposes. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO, AND EXPOSE ALL CONSTRUCTION WORK FOR THE REQUIRED INSPECTIONS.

- It shall be the duty of the person doing the work authorized by a permit to notify the building official that such is ready for inspection and to provide access to and means for proper inspection of such work. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: REQUEST INSPECTION AND PROVIDE ACCESS TO ALL PERMITTED WORK

- No work shall be done on any part of the building or structure beyond the point indicated each successive inspection without first obtaining the written approval of the building official. There shall be a final inspection and approval on all buildings when completed and ready for occupancy. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: REQUEST AND OBTAIN ALL THE SUCCESSIVE AND REQUIRED INSPECTIONS AND WRITTEN APPROVALS ON ALL WORK AND OBTAIN WRITTEN APPROVAL PRIOR TO OCCUPANCY.

- Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause to believe that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS. NOTE: PROPERTY OWNER / MANAGEMENT COMPANY SHALL PROVIDE ACCESS TO UNIT(S) TO VERIFY ALL VIOLATION(S) HAVE BEEN CORRECTED. FAILURE TO PROVIDE ACCESS BY THE COMPLIANCE DATE BELOW MAY RESULT IN A CITATION BEING ISSUED.

- Each receptacle or bundle shall be placed for collection no earlier than the evening preceding, nor later than six a.m. on the day of regular collection. Receptacles placed at the curb shall be removed within twelve hours after the refuse has been collected. Corrective Action: Remove trash cans visible from the public right of way.

- No person shall commence, do, install, erect, construct, remove, add to or change any plumbing, water piping, gas piping, water heater, water heater vents, water treating equipment, or any appliance or device regulated by this chapter without obtaining a permit approving the proposed quality and character of workmanship and materials." PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: OBTAIN A PLUMBING PERMIT FROM THE DEVELOPMENT SERVICES DEPARTMENT FOR THE CODE ENFORCEMENT DIVISION FOR ALL UNPERMITTED PLUMBING WORK OR EQUIPMENT INCLUDING, BUT NOT LIMITED TO, THE FOLLOWING ITEMS OR DESCRIBED WORK:

- Repair deteriorated fencing and/or gate(s).

- Temporary electrical power and lighting installations shall be permitted for a period not to exceed 90 days for holiday decorative lighting and similar purposes. Remove all temporary power/lighting installations.

- Discarded furniture and household items shall not be stored in yard areas. Remove the discarded furniture and/or household items stored or kept in the yard areas.

- Repair/repaint deteriorated/missing exterior stucco.

- Trash and garbage cans cannot be stored in front or side yards visible from public streets. Remove the trash cans and/or trash bins stored or kept in yard areas visible from public streets.

Address

1102 GARDENIA AVE F 90813

Owner

SHAUD, SANDRA

Total Violations

17

Violations:

- Repair/Replace/Repaint all deteriorated bathroom ceilings.

- Properly install weather strip at base of entry door(s) and along sides of door frame to exclude rain water.

- Repair/re-glaze kitchen sink.

- Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause to believe that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS. NOTE: PROPERTY OWNER / MANAGEMENT COMPANY SHALL PROVIDE ACCESS TO UNIT(S) TO VERIFY ALL VIOLATION(S) HAVE BEEN CORRECTED. FAILURE TO PROVIDE ACCESS BY THE COMPLIANCE DATE BELOW MAY RESULT IN A CITATION BEING ISSUED.

- Seal/caulk perimeter/rim of kitchen sink. Caulking/grout must be watertight, smooth and cleanable. Remove old/deteriorated caulking/grout.

- All construction or work for which a permit is required shall be subject to inspection by the building official. It shall be the duty of the permit tee to cause the work to be accessible and exposed for inspection purposes.PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice:PROVIDE ACCESS TO, AND EXPOSE ALL CONSTRUCTION WORK FOR THE REQUIRED INSPECTIONS.
- It shall be the duty of the person doing the work authorized by a permit to notify the building official that such is ready for inspection and to provide access to and means for proper inspection of such work.PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice:REQUEST INSPECTION AND PROVIDE ACCESS TO ALL PERMITTED WORK
- No work shall be done on any part of the building or structure beyond the point indicated each successive inspection without first obtaining the written approve of the building official. There shall be a final inspection and approval on all buildings when completed and ready for occupancy.PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice:REQUEST AND OBTAIN ALL THE SUCCESSIVE AND REQUIRED INSPECTIONSAND WRITTEN APPROVALS ON ALL WORK AND OBTAIN WRITTEN APPROVAL PRIOR TO OCCUPANCY.
- No person shall install, alter, reconstruct or repair any heating, ventilating, cooling, or refrigeration equipment unless a permit therefore has been obtained from the building official except as otherwise provided in this code.PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice:OBTAIN A MECHANICAL PERMIT FROM THE DEVELOPMENT SERVICES DEPARTMENT FOR THE CODE ENFORCEMENT DIVISION FOR ALL UNPERMITTED MECHANICAL WORK OR EQUIPMENT INCLUDING, BUT NOTLIMITED TO, THE FOLLOWING ITEMS OR DESCRIBED WORK:
 - Repair/replace deteriorated entry door threshold to provide a proper seal when closed.
 - Repair/replace all damaged/missing floor coverings throughout the dwelling.
 - Repair/replace/repaint damaged/deteriorated wall/base/doors of cabinet under kitchen sink, including holes around pipe penetrations.
 - Remove mold/mildew at unit/room and correct condition causing mold growth. Drywall should be replaced when mold has covered the surface. Inadequate sanitation shall include any visible or otherwise demonstrable mold growth, excluding the presence of molds that is caused by inappropriate housekeeping practices or improper use of natural or mechanical ventilation.
 - Resurface/reglaze tub where surface is deteriorated. Remove any rust on surface of tub. Use proper materials/compounds for resurfacing/reglazing tub.
 - Caulk perimeter of tub/shower at enclosure walls where caulking/grout is deteriorated/missing. Remove all old/deteriorated caulking/grout at enclosure walls.
 - Obtain all required permits and inspections and provide approved unit heater capable of heating unit to 70 degrees Fahrenheit, measured three feet above the floor. NOTE: Space heaters are not approved for permanent use.
 - Repair/resurface/repaint all deteriorated interior walls and ceiling areas.

Address	Owner	Total Violations
836 GARDENIA AVE 4 90813	KINGS, SIMON	6

Violations:

- The building lacks the required carbon monoxide alarms. Install carbon monoxide alarms outside of each sleeping area in the immediate vicinity of the bedrooms and on every level of the dwelling unit. The alarms may be powered by battery or building wiring.
- The building lacks the required smoke detectors. Install smoke detectors in the bedrooms and hallways. The detectors maybe powered by battery or building wiring.
- Obtain all required permits and inspections and provide approved unit heater capable of heating unit to 70 degrees Fahrenheit, measured three feet above the floor. A temporary heater must be provided during winter months if a permanent heater cannot be repaired or replaced in a timely manner.

- Exterminate cockroaches at all units where infestation is present. Seal all cracks, gaps, and holes in walls, floors, and cupboards, and around piping insertions. Remove or paint over all spotting in unit. Provide pest control service to all infested units and surrounding units sharing common floors, ceilings, and walls with infested units. NOTE: Treatment is most effective when all units are treated on the same day, treatment is repeated to target hatching young in two weeks or every two weeks until infestation is removed.

- Exterminate rodents at unit/building. Remove all rodent droppings. Weather strip entry doors, and seal all holes at walls, floors and ceilings.

- Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause to believe that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS. NOTE: PROPERTY OWNER / MANAGEMENT COMPANY SHALL PROVIDE ACCESS TO UNIT(S) TO VERIFY ALL VIOLATION(S) HAVE BEEN CORRECTED. FAILURE TO PROVIDE ACCESS BY THE COMPLIANCE DATE BELOW MAY RESULT IN A CITATION BEING ISSUED.

Address

Owner

Total Violations

1620 GUNDRY AVE 90813

MCMILLIN, JOSHUA

9

Violations:

- Repair/replace all deteriorated/broken/missing light fixtures.

- Repair/repaint deteriorated/missing exterior stucco.

- Provide mosquito proof screens on all openable windows.

- There is graffiti painted on the premises. Remove all graffiti from the premises.

- A. General. No person shall erect, construct, enlarge, alter, repair, remodel, move or demolish any building or part of a building or structure, or change the character or occupancy or use of any building or structure, or part of a building or structure or perform site grading in the city without first obtaining a permit covering such work from the building official. Whenever a building permit is required to abate a substandard condition as defined in LBMC 18.08.200S, code enforcement fees shall be paid in addition to the permit fees. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: OBTAIN BUILDING PERMITS FROM THE DEVELOPMENT SERVICES DEPARTMENT FOR THE CODE ENFORCEMENT DIVISION FOR ALL UNPERMITTED CONSTRUCTION, REMODELING, OR OCCUPANCY CHANGE INCLUDING, BUT NOT LIMITED TO, THE FOLLOWING ITEMS OR DESCRIBED WORK:

- No work shall be done on any part of the building or structure beyond the point indicated each successive inspection without first obtaining the written approval of the building official. There shall be a final inspection and approval on all buildings when completed and ready for occupancy. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: REQUEST AND OBTAIN ALL THE SUCCESSIVE AND REQUIRED INSPECTIONS AND WRITTEN APPROVALS ON ALL WORK AND OBTAIN WRITTEN APPROVAL PRIOR TO OCCUPANCY.

- It shall be the duty of the person doing the work authorized by a permit to notify the building official that such is ready for inspection and to provide access to and means for proper inspection of such work. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: REQUEST INSPECTION AND PROVIDE ACCESS TO ALL PERMITTED WORK

- All construction or work for which a permit is required shall be subject to inspection by the building official. It shall be the duty of the permittee to cause the work to be accessible and exposed for inspection purposes. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO, AND EXPOSE ALL CONSTRUCTION WORK FOR THE REQUIRED INSPECTIONS.

- Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause to believe that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS. NOTE: PROPERTY OWNER / MANAGEMENT COMPANY SHALL PROVIDE ACCESS TO UNIT(S) TO VERIFY ALL VIOLATION(S) HAVE BEEN CORRECTED. FAILURE TO PROVIDE ACCESS BY THE COMPLIANCE DATE BELOW MAY RESULT IN A CITATION BEING ISSUED.

Address

1438 HELLMAN ST 90813

Owner

VISTA PROPERTY SOLUTIONS LLC,

Total Violations

10

Violations:

- All construction or work for which a permit is required shall be subject to inspection by the building official. It shall be the duty of the permittee to cause the work to be accessible and exposed for inspection purposes. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO, AND EXPOSE ALL CONSTRUCTION WORK FOR THE REQUIRED INSPECTIONS.
- LBMC 9.65.040. It shall be the duty of responsible person(s) to prevent accumulation and storage of abandoned, wrecked, dismantled, or inoperative vehicles or parts thereof, except for those vehicles or parts thereof exempted pursuant to Long Beach Municipal Code Section 10.46.030. Remove all inoperative vehicles or vehicle parts from the property or bring vehicle(s) to an operative condition including current registration status
- There is an open cleanout/waste inlet to the sewer. Cap the open cleanout/waste inlet.
- It shall be the duty of the person doing the work authorized by a permit to notify the building official that such is ready for inspection and to provide access to and means for proper inspection of such work. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: REQUEST INSPECTION AND PROVIDE ACCESS TO ALL PERMITTED WORK
- No work shall be done on any part of the building or structure beyond the point indicated each successive inspection without first obtaining the written approval of the building official. There shall be a final inspection and approval on all buildings when completed and ready for occupancy. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: REQUEST AND OBTAIN ALL THE SUCCESSIVE AND REQUIRED INSPECTIONS AND WRITTEN APPROVALS ON ALL WORK AND OBTAIN WRITTEN APPROVAL PRIOR TO OCCUPANCY.
- Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause to believe that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS. NOTE: PROPERTY OWNER / MANAGEMENT COMPANY SHALL PROVIDE ACCESS TO UNIT(S) TO VERIFY ALL VIOLATION(S) HAVE BEEN CORRECTED. FAILURE TO PROVIDE ACCESS BY THE COMPLIANCE DATE BELOW MAY RESULT IN A CITATION BEING ISSUED.
- Repair/repaint/seal exterior wood trim/surfaces where damaged and/or where paint is peeling/missing.
- Repair/repaint deteriorated/missing exterior stucco.
- A. General. No person shall erect, construct, enlarge, alter, repair, remodel, move or demolish any building or part of a building or structure, or change the character or occupancy or use of any building or structure, or part of a building or structure or perform site grading in the city without first obtaining a permit covering such work from the building official. Whenever a building permit is required to abate a substandard condition as defined in LBMC 18.08.200S, code enforcement fees shall be paid in addition to the permit fees. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: OBTAIN BUILDING PERMITS FROM THE DEVELOPMENT SERVICES DEPARTMENT FOR THE CODE ENFORCEMENT DIVISION FOR ALL UNPERMITTED CONSTRUCTION, REMODELING, OR OCCUPANCY CHANGE INCLUDING, BUT NOT LIMITED TO, THE FOLLOWING ITEMS OR DESCRIBED WORK:

- Plans, engineering calculations, diagrams and other data shall be submitted in one or more sets with each application for a permit. The building official may require plans, computations and specifications to be prepared and designed by an engineer or architect licensed by the state of California to practice as such. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE THREE SETS OF PLANS, SPECIFICATIONS OR OTHER DETAILS AS REQUIRED BY THE DEPARTMENT OF DEVELOPMENT SERVICES WITH THE APPLICATION FOR THE REQUIRED PERMIT.

Address	Owner	Total Violations
1211 HOFFMAN AVE 90813	CONTI, RICHARD	13

Violations:

- All construction or work for which a permit is required shall be subject to inspection by the building official. It shall be the duty of the permit tee to cause the work to be accessible and exposed for inspection purposes. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO, AND EXPOSE ALL CONSTRUCTION WORK FOR THE REQUIRED INSPECTIONS.

- Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause to believe that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS. NOTE: PROPERTY OWNER / MANAGEMENT COMPANY SHALL PROVIDE ACCESS TO UNIT(S) TO VERIFY ALL VIOLATION(S) HAVE BEEN CORRECTED. FAILURE TO PROVIDE ACCESS BY THE COMPLIANCE DATE BELOW MAY RESULT IN A CITATION BEING ISSUED.

- No new electrical installation shall be made nor any alteration or addition performed to any existing wiring, nor shall any wiring for the placing or installation of any electric light, power or heating device, or any apparatus which generates, transmits, transforms or utilizes electricity operating at a voltage exceeding twenty-five volts between conductors or capable of supplying more than fifty watts, be made without first obtaining an electrical permit. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: OBTAIN AN ELECTRICAL PERMIT FROM THE DEVELOPMENT SERVICES DEPARTMENT FOR THE CODE ENFORCEMENT DIVISION FOR ALL UNPERMITTED ELECTRICAL WORK OR EQUIPMENT INCLUDING, BUT NOT LIMITED TO, THE FOLLOWING ITEMS OR DESCRIBED WORK:

- Remove scattered trash, castoff items and debris around premises.

- Replace all damaged or missing light fixtures with approved fixtures.

- A. General. No person shall erect, construct, enlarge, alter, repair, remodel, move or demolish any building or part of a building or structure, or change the character or occupancy or use of any building or structure, or part of a building or structure or perform site grading in the city without first obtaining a permit covering such work from the building official. Whenever a building permit is required to abate a substandard condition as defined in LBMC 18.08.200S, code enforcement fees shall be paid in addition to the permit fees. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: OBTAIN BUILDING PERMITS FROM THE DEVELOPMENT SERVICES DEPARTMENT FOR THE CODE ENFORCEMENT DIVISION FOR ALL UNPERMITTED CONSTRUCTION, REMODELING, OR OCCUPANCY CHANGE INCLUDING, BUT NOT LIMITED TO, THE FOLLOWING ITEMS OR DESCRIBED WORK:

- Discarded furniture and household items shall not be stored in yard areas. Remove the discarded furniture and/or household items stored or kept in the yard areas.

- Replace all broken window glass.

- It shall be the duty of the person doing the work authorized by a permit to notify the building official that such is ready for inspection and to provide access to and means for proper inspection of such work. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: REQUEST INSPECTION AND PROVIDE ACCESS TO ALL PERMITTED WORK

- No work shall be done on any part of the building or structure beyond the point indicated each successive inspection without first obtaining the written approval of the building official. There shall be a final inspection and approval on all buildings when completed and ready for occupancy. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: REQUEST AND OBTAIN ALL THE SUCCESSIVE AND REQUIRED INSPECTIONS AND WRITTEN APPROVALS ON ALL WORK AND OBTAIN WRITTEN APPROVAL PRIOR TO OCCUPANCY.

- Provide mosquito proof screens on all openable windows.

- Plans, engineering calculations, diagrams and other data shall be submitted in one or more sets with each application for a permit. The building official may require plans, computations and specifications to be prepared and designed by an engineer or architect licensed by the state of California to practice as such. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE THREE SETS OF PLANS, SPECIFICATIONS OR OTHER DETAILS AS REQUIRED BY THE DEPARTMENT OF DEVELOPMENT SERVICES WITH THE APPLICATION FOR THE REQUIRED PERMIT.

- No person shall commence, do, install, erect, construct, remove, add to or change any plumbing, water piping, gas piping, water heater, water heater vents, water treating equipment, or any appliance or device regulated by this chapter without obtaining a permit approving the proposed quality and character of workmanship and materials. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: OBTAIN A PLUMBING PERMIT FROM THE DEVELOPMENT SERVICES DEPARTMENT FOR THE CODE ENFORCEMENT DIVISION FOR ALL UNPERMITTED PLUMBING WORK OR EQUIPMENT INCLUDING, BUT NOT LIMITED TO, THE FOLLOWING ITEMS OR DESCRIBED WORK:

Address	Owner	Total Violations
4117 JACINTO WAY 90815	BEACH, JUDY	7

Violations:

- Repair/replace all deteriorated/broken/missing light fixtures.

- The water heater temperature and pressure relief valve outlet is not piped to the outside of the building. Provide approved piping from the valve outlet to the outside of the building and terminating between 2 feet and 6 inches above the ground.

- A. General. No person shall erect, construct, enlarge, alter, repair, remodel, move or demolish any building or part of a building or structure, or change the character or occupancy or use of any building or structure, or part of a building or structure or perform site grading in the city without first obtaining a permit covering such work from the building official. Whenever a building permit is required to abate a substandard condition as defined in LBMC 18.08.200S, code enforcement fees shall be paid in addition to the permit fees. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: OBTAIN BUILDING PERMITS FROM THE DEVELOPMENT SERVICES DEPARTMENT FOR THE CODE ENFORCEMENT DIVISION FOR ALL UNPERMITTED CONSTRUCTION, REMODELING, OR OCCUPANCY CHANGE INCLUDING, BUT NOT LIMITED TO, THE FOLLOWING ITEMS OR DESCRIBED WORK:

- All construction or work for which a permit is required shall be subject to inspection by the building official. It shall be the duty of the permittee to cause the work to be accessible and exposed for inspection purposes. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO, AND EXPOSE ALL CONSTRUCTION WORK FOR THE REQUIRED INSPECTIONS.

- No work shall be done on any part of the building or structure beyond the point indicated each successive inspection without first obtaining the written approval of the building official. There shall be a final inspection and approval on all buildings when completed and ready for occupancy. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: REQUEST AND OBTAIN ALL THE SUCCESSIVE AND REQUIRED INSPECTIONS AND WRITTEN APPROVALS ON ALL WORK AND OBTAIN WRITTEN APPROVAL PRIOR TO OCCUPANCY.

- Repair/Repaint all deteriorated laundry room walls and/or ceilings. Seal all holes, including holes at pipe penetrations, and paint all unpainted surfaces.

- Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause to believe that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS. NOTE: PROPERTY OWNER / MANAGEMENT COMPANY SHALL PROVIDE ACCESS TO UNIT(S) TO VERIFY ALL VIOLATION(S) HAVE BEEN CORRECTED. FAILURE TO PROVIDE ACCESS BY THE COMPLIANCE DATE BELOW MAY RESULT IN A CITATION BEING ISSUED.

Address	Owner	Total Violations
1443 LINDEN AVE 90813	SIMAS, MANUEL	22

Violations:

- Exterminate cockroaches at all units where infestation is present. Seal all cracks, gaps, and holes in walls, floors, and cupboards, and around piping insertions. Remove or paint over all spotting in unit. Provide pest control service to all infested units and surrounding units sharing common floors, ceilings, and walls with infested units. NOTE: Treatment is most effective when all units are treated on the same day, treatment is repeated to target hatching young in two weeks or every two weeks until infestation is removed.
- Exterminate rodents at unit/building. Remove all rodent droppings. Weather strip entry doors, and seal all holes at walls, floors and ceilings.
- No work shall be done on any part of the building or structure beyond the point indicated each successive inspection without first obtaining the written approval of the building official. There shall be a final inspection and approval on all buildings when completed and ready for occupancy. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: REQUEST AND OBTAIN ALL THE SUCCESSIVE AND REQUIRED INSPECTIONS AND WRITTEN APPROVALS ON ALL WORK AND OBTAIN WRITTEN APPROVAL PRIOR TO OCCUPANCY.
- It shall be the duty of the person doing the work authorized by a permit to notify the building official that such is ready for inspection and to provide access to and means for proper inspection of such work. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: REQUEST INSPECTION AND PROVIDE ACCESS TO ALL PERMITTED WORK
- All construction or work for which a permit is required shall be subject to inspection by the building official. It shall be the duty of the permittee to cause the work to be accessible and exposed for inspection purposes. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO, AND EXPOSE ALL CONSTRUCTION WORK FOR THE REQUIRED INSPECTIONS.
- Repair and repaint all deteriorated window frames/components/surfaces.
- Replace all broken window glass.
- Repair/replace all inoperative sash balances on openable windows to operate correctly. Windows must be openable to the exterior of the building and must be closeable.
- Remove scattered trash, castoff items and debris around premises.
- Provide/secure cap on open sewer cleanout and repair all plumbing problems causing sewage flow/backup.
- It shall be the duty of responsible person(s) to prevent accumulation and storage of abandoned, wrecked, dismantled, or inoperative vehicles or parts thereof, except for those vehicles or parts thereof exempted pursuant to Long Beach Municipal Code Section 10.46.030. Remove all inoperative vehicles or vehicle parts from the property or bring vehicle(s) to an operative condition including current registration status.

- Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause to believe that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS. NOTE: PROPERTY OWNER / MANAGEMENT COMPANY SHALL PROVIDE ACCESS TO UNIT(S) TO VERIFY ALL VIOLATION(S) HAVE BEEN CORRECTED. FAILURE TO PROVIDE ACCESS BY THE COMPLIANCE DATE BELOW MAY RESULT IN A CITATION BEING ISSUED.

- A. General. No person shall erect, construct, enlarge, alter, repair, remodel, move or demolish any building or part of a building or structure, or change the character or occupancy or use of any building or structure, or part of a building or structure or perform site grading in the city without first obtaining a permit covering such work from the building official. Whenever a building permit is required to abate a substandard condition as defined in LBMC 18.08.200S, code enforcement fees shall be paid in addition to the permit fees. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: OBTAIN BUILDING PERMITS FROM THE DEVELOPMENT SERVICES DEPARTMENT FOR THE CODE ENFORCEMENT DIVISION FOR ALL UNPERMITTED CONSTRUCTION, REMODELING, OR OCCUPANCY CHANGE INCLUDING, BUT NOT LIMITED TO, THE FOLLOWING ITEMS OR DESCRIBED WORK:

- The exterior stairs and/or landings are deteriorated, partially missing and unsafe. Rebuild the exterior stairs and/or landings to meet minimum code requirements.

- Repair all holes on the exterior of the building.

- Repair/repaint/seal exterior wood trim/surfaces where damaged and/or where paint is peeling/missing.

- Replace/secure all deteriorated/missing exterior siding.

- The exterior door(s) is/are damaged and not properly fitted. Replace or repair the exterior door(s) and install in a weathertight manner.

- The finish on the exterior door is deteriorated. Refinish or replace and paint the exterior door.

- The screen doors are deteriorated. Replace or repair the deteriorated screen doors to a sound and operable condition.

- Provide mosquito proof screens on all openable windows.

- Repair/resurface/repaint deteriorated balcony/landing.

Address

1445 1/2 LINDEN AVE 90813

Owner

SIMAS, MANUEL

Total Violations

27

Violations:

- Exterminate cockroaches at all units where infestation is present. Seal all cracks, gaps, and holes in walls, floors, and cupboards, and around piping insertions. Remove or paint over all spotting in unit. Provide pest control service to all infested units and surrounding units sharing common floors, ceilings, and walls with infested units. NOTE: Treatment is most effective when all units are treated on the same day, treatment is repeated to target hatching young in two weeks or every two weeks until infestation is removed.

- Exterminate rodents at unit/building. Remove all rodent droppings. Weather strip entry doors, and seal all holes at walls, floors and ceilings.

- Repair/replace deteriorated sub-floor and/or supports as directed and obtain necessary permits and inspections.

- Repair/replace all damaged/missing floor coverings throughout the dwelling.

- Repair/Replace deteriorated kitchen cabinet and/or doors.
- Repair/replace deteriorated kitchen drawers.
- Seal around kitchen faucet to prevent water leaks.
- Repair/replace/repaint damaged/deteriorated wall/base/doors of cabinet under kitchen sink, including holes around pipe penetrations.
- Repair deteriorated entry door framing and/or jamb.
- Repair/Repaint/Weatherproof exterior door.
- Repair/replace deteriorated entry door threshold to provide a proper seal when closed.
- Repair/replace deteriorated/non-operational entry door lock/knob.
- The door(s) is/are deteriorated and the hardware is missing. Repair and paint the deteriorated door(s) and replace the missing hardware.
- Replace deteriorated water heater. Obtain all required inspections and permits. Properly vent gas water heater. Strap or secure water heater to protect from earthquake hazards.
- The water heater temperature and pressure relief valve outlet is not piped to the outside of the building. Provide approved piping from the valve outlet to the outside of the building and terminating no more than 2 feet nor less than 6 inches above the ground.
- Repair/resurface/repaint all deteriorated interior walls and ceiling areas.
- Repair/replace all deteriorated/broken/missing light fixtures.
- The building lacks the required smoke detectors. Install smoke detectors in the bedrooms and hallways. The detectors may be powered by battery or building wiring.
- The building lacks the required carbon monoxide alarms. Install carbon monoxide alarms outside of each sleeping area in the immediate vicinity of the bedrooms and on every level of the dwelling unit. The alarms may be powered by battery or building wiring.
- Replace all deteriorated bathroom floor coverings.
- Resurface/reglaze tub where surface is deteriorated. Remove any rust on surface of tub. Use proper materials/compounds for resurfacing/reglazing tub.
- Repair/replace faucet/controls at bathroom sink.
- Replace deteriorated toilet seat and/or tank lid.
- Caulk around toilet base.
- Repair/Resurface/Repaint bathroom wall(s) where deteriorated/damaged, where holes exist, and/or where paint is peeling/missing.
- Repair/provide bathroom wall coving where deteriorated/peeling/missing.

- Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause to believe that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS. NOTE: PROPERTY OWNER / MANAGEMENT COMPANY SHALL PROVIDE ACCESS TO UNIT(S) TO VERIFY ALL VIOLATION(S) HAVE BEEN CORRECTED. FAILURE TO PROVIDE ACCESS BY THE COMPLIANCE DATE BELOW MAY RESULT IN A CITATION BEING ISSUED.

Address	Owner	Total Violations
1447 LINDEN AVE 90813	SIMAS, MANUEL	9

Violations:

- Obtain all required permits and inspections and provide approved unit heater capable of heating unit to 70 degrees Fahrenheit, measured three feet above the floor. NOTE: Space heaters are not approved for permanent use.
 - The building lacks the required smoke detectors. Install smoke detectors in the bedrooms and hallways. The detectors maybe powered by battery or building wiring.
 - The building lacks the required carbon monoxide alarms. Install carbon monoxide alarms outside of each sleeping area in the immediate vicinity of the bedrooms and on every level of the dwelling unit. The alarms may be powered by battery or building wiring.
 - Repair/replace all deteriorated electrical outlets/switches.
 - Repair/replace all deteriorated/broken/missing light fixtures.
 - Repair/replace faulty/missing fixtures and/or hardware at tub/shower.
 - Repair/Replace/Repaint all deteriorated bathroom ceilings.
 - Repair/replace deteriorated entry door threshold to provide a proper seal when closed.
 - Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause to believe that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS. NOTE: PROPERTY OWNER / MANAGEMENT COMPANY SHALL PROVIDE ACCESS TO UNIT(S) TO VERIFY ALL VIOLATION(S) HAVE BEEN CORRECTED. FAILURE TO PROVIDE ACCESS BY THE COMPLIANCE DATE BELOW MAY RESULT IN A CITATION BEING ISSUED.
-

Address	Owner	Total Violations
1449 LINDEN AVE 90813	SIMAS, MANUEL	28

Violations:

- Repair/replace deteriorated unit carpeting.
- Repair/resurface/repaint all deteriorated interior walls and ceiling areas.

- Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause to believe that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS. NOTE: PROPERTY OWNER / MANAGEMENT COMPANY SHALL PROVIDE ACCESS TO UNIT(S) TO VERIFY ALL VIOLATION(S) HAVE BEEN CORRECTED. FAILURE TO PROVIDE ACCESS BY THE COMPLIANCE DATE BELOW MAY RESULT IN A CITATION BEING ISSUED.

- The door(s) is/are deteriorated and the hardware is missing. Repair and paint the deteriorated door(s) and replace the missing hardware.
- Properly install weather strip at base of entry door(s) and along sides of door frame to exclude rain water.
- The building lacks the required smoke detectors. Install smoke detectors in the bedrooms and hallways. The detectors may be powered by battery or building wiring.
- The building lacks the required carbon monoxide alarms. Install carbon monoxide alarms outside of each sleeping area in the immediate vicinity of the bedrooms and on every level of the dwelling unit. The alarms may be powered by battery or building wiring.
- Repair/Replace deteriorated kitchen cabinet and/or doors.
- Repair/replace deteriorated kitchen drawers.
- Repair/replace all deteriorated kitchen counters and/or edge banding.
- Repair/replace leaking/inoperable kitchen faucet hardware.
- Repair/replace deteriorated/missing kitchen floor covering.
- Seal around kitchen faucet to prevent water leaks.
- Repair/re-glaze kitchen sink.
- Repair/replace/repaint damaged/deteriorated wall/base/doors of cabinet under kitchen sink, including holes around pipe penetrations.
- Replace all broken window glass.
- Caulk perimeter of tub/shower at enclosure walls where caulking/grout is deteriorated/missing. Remove all old/deteriorated caulking/grout at enclosure walls.
- Replace all deteriorated bathroom floor coverings.
- Repair toilet to flush properly. Replace all deteriorated/missing components.
- Caulk around toilet base.
- Repair/replace all missing or damaged electrical outlet and switch plates.
- Repair/replace all deteriorated/broken/missing light fixtures.
- Repair/replace all deteriorated electrical outlets/switches.
- Repair/replace all damaged/missing floor coverings throughout the dwelling.
- The interior stairway handrails are deteriorated and missing. Replace or repair all the required stairway handrails to a sound condition.

- Repair deteriorated entry door framing and/or jamb.
- Repair/replace deteriorated entry door threshold to provide a proper seal when closed.
- Repair/Replace/Provide approved security locking mechanism for entry door(s). (Note: Do not install deadbolt locks that are keyed on both sides - use only those with thumb latches on entry doors).

Address	Owner	Total Violations
4428 LINDEN AVE 90807	SCHAUWEKER, PHILIP	5

Violations:

- Property must be clean and free from all weeds and/or debris at all times. Remove all weeds and/or debris from the property.
- Repair/repaint/seal exterior wood trim/surfaces where damaged and/or where paint is peeling/missing.
- Repair/repaint/secure deteriorated exterior stairway.
- Repair/repaint deteriorated stair landings as directed. Obtain all required permits and inspections.
- Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause to believe that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS. NOTE: PROPERTY OWNER / MANAGEMENT COMPANY SHALL PROVIDE ACCESS TO UNIT(S) TO VERIFY ALL VIOLATION(S) HAVE BEEN CORRECTED. FAILURE TO PROVIDE ACCESS BY THE COMPLIANCE DATE BELOW MAY RESULT IN A CITATION BEING ISSUED.

Address	Owner	Total Violations
838 1/2 LINDEN AVE 90813	FULLMAN, DONALD	25

Violations:

- A. General. No person shall erect, construct, enlarge, alter, repair, remodel, move or demolish any building or part of a building or structure, or change the character or occupancy or use of any building or structure, or part of a building or structure or perform site grading in the city without first obtaining a permit covering such work from the building official. Whenever a building permit is required to abate a substandard condition as defined in LBMC 18.08.200S, code enforcement fees shall be paid in addition to the permit fees. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: OBTAIN BUILDING PERMITS FROM THE DEVELOPMENT SERVICES DEPARTMENT FOR THE CODE ENFORCEMENT DIVISION FOR ALL UNPERMITTED CONSTRUCTION, REMODELING, OR OCCUPANCY CHANGE INCLUDING, BUT NOT LIMITED TO, THE FOLLOWING ITEMS OR DESCRIBED WORK:
- No work shall be done on any part of the building or structure beyond the point indicated each successive inspection without first obtaining the written approval of the building official. There shall be a final inspection and approval on all buildings when completed and ready for occupancy. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: REQUEST AND OBTAIN ALL THE SUCCESSIVE AND REQUIRED INSPECTIONS AND WRITTEN APPROVALS ON ALL WORK AND OBTAIN WRITTEN APPROVAL PRIOR TO OCCUPANCY.
- It shall be the duty of the person doing the work authorized by a permit to notify the building official that such is ready for inspection and to provide access to and means for proper inspection of such work. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: REQUEST INSPECTION AND PROVIDE ACCESS TO ALL PERMITTED WORK

- All construction or work for which a permit is required shall be subject to inspection by the building official. It shall be the duty of the permittee to cause the work to be accessible and exposed for inspection purposes. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO, AND EXPOSE ALL CONSTRUCTION WORK FOR THE REQUIRED INSPECTIONS.
- Repair/Replace deteriorated kitchen cabinet and/or doors.
 - Repair/replace deteriorated kitchen drawers.
 - Repair/replace all deteriorated kitchen counters and/or edge banding.
 - Repair/re-glaze kitchen sink.
 - Remove mold/mildew at unit/room and correct condition causing mold growth. Drywall should be replaced when mold has covered the surface. Inadequate sanitation shall include any visible or otherwise demonstrable mold growth, excluding the presence of molds that is caused by inappropriate housekeeping practices or improper use of natural or mechanical ventilation.
 - Resurface/reglaze tub where surface is deteriorated. Remove any rust on surface of tub. Use proper materials/compounds for resurfacing/reglazing tub.
 - Repair/replace faulty/missing fixtures and/or hardware at tub/shower.
 - Replace all deteriorated/missing bathroom tiles.
 - Resurface/reglaze bathroom sink where surface is deteriorated. Remove any rust on surface of sink. Use proper materials/compounds for resurfacing/reglazing sink.
 - Repair/Resurface/Repaint bathroom wall(s) where deteriorated/damaged, where holes exist, and/or where paint is peeling/missing.
 - Repair/Replace/Repaint all deteriorated bathroom ceilings.
 - Repair/replace and paint all deteriorated roof fascia, eaves and rafter tails.
 - Repair/repaint/seal exterior wood trim/surfaces where damaged and/or where paint is peeling/missing.
 - Repair/resurface/repaint deteriorated guardrails; loose/broken components.
 - Repair/Repaint/Weatherproof exterior door.
 - Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause to believe that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS. NOTE: PROPERTY OWNER / MANAGEMENT COMPANY SHALL PROVIDE ACCESS TO UNIT(S) TO VERIFY ALL VIOLATION(S) HAVE BEEN CORRECTED. FAILURE TO PROVIDE ACCESS BY THE COMPLIANCE DATE BELOW MAY RESULT IN A CITATION BEING ISSUED.
 - Trim trees/shrubs to no less than 18 inches from building and roof to prevent rodent entrance to building(s).
 - Replace all broken window glass.
 - Repair and repaint all deteriorated window frames/components/surfaces.
 - The window awnings are deteriorated and unsightly. Remove or replace the deteriorated window awnings.

- Repair/replace missing or deteriorated garage door.

Address

2128 LOCUST AVE 5 90806

Owner

SCHMIDL, ROBERT

Total Violations

26

Violations:

- Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause to believe that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS. NOTE: PROPERTY OWNER / MANAGEMENT COMPANY SHALL PROVIDE ACCESS TO UNIT(S) TO VERIFY ALL VIOLATION(S) HAVE BEEN CORRECTED. FAILURE TO PROVIDE ACCESS BY THE COMPLIANCE DATE BELOW MAY RESULT IN A CITATION BEING ISSUED.

- Repair/repaint/seal exterior wood trim/surfaces where damaged and/or where paint is peeling/missing.

- Repair/repaint deteriorated/missing exterior stucco.

- Trim all overgrown foliage/lawns/shrubs at property to prevent vermin/rodent harborage or entrance to units/buildings.

- Replace deteriorated water heater. Obtain all required inspections and permits. Properly vent gas water heater. Strap or secure water heater to protect from earthquake hazards.

- The number of existing off-street parking and loading spaces shall not be reduced, or in any other way modified, below the standards required by this Title. Provide the required parking for the subject facility.

- Resurface/reglaze tub where surface is deteriorated. Remove any rust on surface of tub. Use proper materials/compounds for resurfacing/reglazing tub.

- Repair/replace faulty/missing fixtures and/or hardware at tub/shower.

- Resurface/reglaze bathroom sink where surface is deteriorated. Remove any rust on surface of sink. Use proper materials/compounds for resurfacing/reglazing sink.

- Remove scattered trash, castoff items and debris around premises.

- Repair deteriorated fencing and/or gate(s).

- The roof covering is defective. Replace the defective and deteriorated roof covering.

- Repair deteriorated and/or clogged exterior plumbing.

- Repair/repaint/secure deteriorated exterior stairway.

- Repair/replace and paint all deteriorated roof fascia, eaves and rafter tails.

- Repair/replace/remove deteriorated rain gutters and/or down spouts so as to direct rain water runoff away from buildings.

- The water heater temperature and pressure relief valve outlet is not piped to the outside of the building. Provide approved piping from the valve outlet to the outside of the building and terminating no more than 2 feet nor less than 6 inches above the ground.

- Repair/replace all deteriorated/broken/missing light fixtures.
- Unclog kitchen sink drain.
- Repair/replace/remove garbage disposal.
- Repair leaking plumbing under kitchen sink.
- There is graffiti painted on the premises. Remove all graffiti from the premises.
- A. General. No person shall erect, construct, enlarge, alter, repair, remodel, move or demolish any building or part of a building or structure, or change the character or occupancy or use of any building or structure, or part of a building or structure or perform site grading in the city without first obtaining a permit covering such work from the building official. Whenever a building permit is required to abate a substandard condition as defined in LBMC 18.08.200S, code enforcement fees shall be paid in addition to the permit fees. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice:OBTAIN BUILDING PERMITS FROM THE DEVELOPMENT SERVICES DEPARTMENT FOR THE CODE ENFORCEMENT DIVISION FOR ALL UNPERMITTED CONSTRUCTION, REMODELING, OR OCCUPANCY CHANGE INCLUDING, BUT NOT LIMITED TO, THE FOLLOWING ITEMS OR DESCRIBED WORK:
- No work shall be done on any part of the building or structure beyond the point indicated each successive inspection without first obtaining the written approval of the building official. There shall be a final inspection and approval on all buildings when completed and ready for occupancy.PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice:REQUEST AND OBTAIN ALL THE SUCCESSIVE AND REQUIRED INSPECTIONSAND WRITTEN APPROVALS ON ALL WORK AND OBTAIN WRITTEN APPROVAL PRIOR TO OCCUPANCY.
- It shall be the duty of the person doing the work authorized by a permit to notify the building official that such is ready for inspection and to provide access to and means for proper inspection of such work.PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice:REQUEST INSPECTION AND PROVIDE ACCESS TO ALL PERMITTED WORK
- All construction or work for which a permit is required shall be subject to inspection by the building official. It shall be the duty of the permit tee to cause the work to be accessible and exposed for inspection purposes.PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice:PROVIDE ACCESS TO, AND EXPOSE ALL CONSTRUCTION WORK FOR THE REQUIRED INSPECTIONS.

Address	Owner	Total Violations
1082 MARTIN LUTHER KING JR AVE 90813	CHIANG, PAISAN	12

Violations:

- Effectively exterminate for bed bugs using a professional pest control company. Inspect/monitor/treat all surrounding units in building that share common walls, floors, and ceilings with all infected units.
- Exterminate rodents at unit/building. Remove all rodent droppings. Weather strip entry doors, and seal allholesat walls, floors and ceilings.
- Repair/resurface/repaint deteriorated balcony/landing.
- Repair/repaint/seal exterior wood trim/surfaces where damaged and/or where paint is peeling/missing.
- Repair/repaint deteriorated/missing exterior stucco.
- Remove scattered trash, castoff items and debris around premises.
- Repair/Repaint/Weatherproof exterior door.

- Repair/replace deteriorated entry door threshold to provide a proper seal when closed.
 - Provide mosquito proof screens on all openable windows.
 - Repair and repaint all deteriorated window frames/components/surfaces.
 - Repair/replace all deteriorated/broken/missing light fixtures.
- Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause to believe that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS. NOTE: PROPERTY OWNER / MANAGEMENT COMPANY SHALL PROVIDE ACCESS TO UNIT(S) TO VERIFY ALL VIOLATION(S) HAVE BEEN CORRECTED. FAILURE TO PROVIDE ACCESS BY THE COMPLIANCE DATE BELOW MAY RESULT IN A CITATION BEING ISSUED.

Address	Owner	Total Violations
920 MARTIN LUTHER KING JR AVE 311 90813	PHOENIX PROPERTIES PARTNERSHIP,	7

Violations:

- The subfloor is damaged or deteriorated. Repair or replace the subfloor.
 - Repair/Replace deteriorated kitchen cabinet and/or doors.
 - Repair/replace deteriorated kitchen drawers.
 - All properties shall be posted with the number or numbers designated for the principal entrance or entrances of a building. Install address numbers, not less than three inches in height, at the principal entrance of the building in plain view from the public right-of-way.
 - Repair/replace faulty/missing fixtures and/or hardware at tub/shower.
 - Repair/replace all deteriorated/broken/missing light fixtures.
- Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause to believe that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS. NOTE: PROPERTY OWNER / MANAGEMENT COMPANY SHALL PROVIDE ACCESS TO UNIT(S) TO VERIFY ALL VIOLATION(S) HAVE BEEN CORRECTED. FAILURE TO PROVIDE ACCESS BY THE COMPLIANCE DATE BELOW MAY RESULT IN A CITATION BEING ISSUED.

Address	Owner	Total Violations
920 MARTIN LUTHER KING JR AVE 313 90813	PHOENIX PROPERTIES PARTNERSHIP,	10

Violations:

- Repair/repaint/replace all deteriorated bathroom cabinets.

- Replace all deteriorated bathroom floor coverings.
- Repair/Resurface/Repaint bathroom wall(s) where deteriorated/damaged, where holes exist, and/or where paint is peeling/missing.
- Repair deteriorated entry door framing and/or jamb.
- Repair/Repaint/Weatherproof exterior door.
- The ceiling(s) is/are damaged by water. Repair the damaged ceiling(s) and/or leaks and replace with new materials.
- Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause to believe that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS. NOTE: PROPERTY OWNER / MANAGEMENT COMPANY SHALL PROVIDE ACCESS TO UNIT(S) TO VERIFY ALL VIOLATION(S) HAVE BEEN CORRECTED. FAILURE TO PROVIDE ACCESS BY THE COMPLIANCE DATE BELOW MAY RESULT IN A CITATION BEING ISSUED.
- Repair/Replace deteriorated kitchen cabinet and/or doors.
- Repair/replace deteriorated kitchen drawers.
- Repair/replace deteriorated/missing kitchen floor covering.

Address	Owner	Total Violations
920 MARTIN LUTHER KING JR AVE 90813	PHOENIX PROPERTIES PARTNERSHIP,	25

Violations:

- The exterior siding is deteriorated. Repair all the deteriorated siding. After all exterior repairs have been made, paint the entire exterior of the building(s) including the windows, doors, all trim and roof eaves.
- Portions of the exterior electrical wiring are not approved to exterior use. Replace all unapproved electrical materials with approved electrical materials, installed in an approved manner.
- A. General. No person shall erect, construct, enlarge, alter, repair, remodel, move or demolish any building or part of a building or structure, or change the character or occupancy or use of any building or structure, or part of a building or structure or perform site grading in the city without first obtaining a permit covering such work from the building official. Whenever a building permit is required to abate a substandard condition as defined in LBMC 18.08.200S, code enforcement fees shall be paid in addition to the permit fees. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: OBTAIN BUILDING PERMITS FROM THE DEVELOPMENT SERVICES DEPARTMENT FOR THE CODE ENFORCEMENT DIVISION FOR ALL UNPERMITTED CONSTRUCTION, REMODELING, OR OCCUPANCY CHANGE INCLUDING, BUT NOT LIMITED TO, THE FOLLOWING ITEMS OR DESCRIBED WORK:
 - All construction or work for which a permit is required shall be subject to inspection by the building official. It shall be the duty of the permit tee to cause the work to be accessible and exposed for inspection purposes. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO, AND EXPOSE ALL CONSTRUCTION WORK FOR THE REQUIRED INSPECTIONS.
 - It shall be the duty of the person doing the work authorized by a permit to notify the building official that such is ready for inspection and to provide access to and means for proper inspection of such work. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: REQUEST INSPECTION AND PROVIDE ACCESS TO ALL PERMITTED WORK

- No work shall be done on any part of the building or structure beyond the point indicated each successive inspection without first obtaining the written approval of the building official. There shall be a final inspection and approval on all buildings when completed and ready for occupancy. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: REQUEST AND OBTAIN ALL THE SUCCESSIVE AND REQUIRED INSPECTIONS AND WRITTEN APPROVALS ON ALL WORK AND OBTAIN WRITTEN APPROVAL PRIOR TO OCCUPANCY.

- Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause to believe that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS. NOTE: PROPERTY OWNER / MANAGEMENT COMPANY SHALL PROVIDE ACCESS TO UNIT(S) TO VERIFY ALL VIOLATION(S) HAVE BEEN CORRECTED. FAILURE TO PROVIDE ACCESS BY THE COMPLIANCE DATE BELOW MAY RESULT IN A CITATION BEING ISSUED.

- Repair deteriorated fencing and/or gate(s).

- The stairway, landings and railings are defective. Replace the defective and deteriorated stairway, landings, and railings.

- The exterior stairs are deteriorated. Rebuild the exterior stairs to meet minimum code requirements.

- Remove animal fecal material from premises on a daily basis, placing it in a sealed plastic bag for disposal with the regular trash. Wash down or mop urine with a small amount of diluted sanitizer to eliminate odor. Do not hose off balconies onto other balconies, street, alley, or common areas.

- Provide mosquito proof screens on all openable windows.

- Repair/replace and paint all deteriorated roof fascia, eaves and rafter tails.

- Repair/replace/remove deteriorated rain gutters and/or down spouts so as to direct rain water runoff away from buildings.

- Provide trash facilities adequate enough to handle trash load of tenants on a calendar week basis. Ensure that all containers have closeable lids and are kept closed at all times. Note: Increased frequency of pick up and/or additional containers may be required to accomplish this task.

- The exterior balconies lack the required approved exterior waterproof covering. Install a weatherproof covering approved for a walking surface on the balconies.

- The exterior stucco is damaged and deteriorated. Repair all the damaged or deteriorated stucco and color coat to match the existing color of the building.

- Repair/replace all deteriorated/broken/missing light fixtures.

- There is graffiti painted on the premises. Remove all graffiti from the premises.

- Repair deteriorated entry door framing and/or jamb.

- Route dryer exhaust to exterior of building. Maintain dryer duct free of accumulated lint on a regular basis.

- Exterminate cockroaches at all units where infestation is present. Seal all cracks, gaps, and holes in walls, floors, and cupboards, and around piping insertions. Remove or paint over all spotting in unit. Provide pest control service to all infested units and surrounding units sharing common floors, ceilings, and walls with infested units. NOTE: Treatment is most effective when all units are treated on the same day, treatment is repeated to target hatching young in two weeks or every two weeks until infestation is removed.

- Exterminate rodents at unit/building. Remove all rodent droppings. Weather strip entry doors, and seal all holes at walls, floors and ceilings.

- Properties must be maintained in a condition so as not to become defective, unsightly or in a state of deterioration or disrepair. Remove all items which render the property unsightly and in a state of disrepair.

- Repair/replace missing or deteriorated garage door.

Address

526 NEW YORK ST 90813

Owner

HUIZAR, NICOLAS

Total Violations

21

Violations:

- Replace all broken window glass.
- Provide mosquito proof screens on all openable windows.
- Repair and repaint all deteriorated window frames/components/surfaces.
- Provide smooth, trip free surfaces at all walkways.
- Repair all holes on the exterior of the building.
- Repair/repaint/seal exterior wood trim/surfaces where damaged and/or where paint is peeling/missing.
- Repair/repaint deteriorated/missing exterior stucco.
- Repair/Replace all windows to a weathertight condition.
- Resurface/reglaze tub where surface is deteriorated. Remove any rust on surface of tub. Use proper materials/compounds for resurfacing/reglazing tub.
- Repair/replace faulty/missing fixtures and/or hardware at tub/shower.
- Caulk gap between wall and sink/cabinet top behind sink. Remove all old/deteriorated caulking/grout. Perimeter of wall behind sink must be watertight.
- Caulk perimeter of tub/shower at floor/flooring where caulking/grout is deteriorated/missing. Remove all old/deteriorated caulking at floor/flooring.
- Caulk perimeter of tub/shower at enclosure walls where caulking/grout is deteriorated/missing. Remove all old/deteriorated caulking/grout at enclosure walls.
- Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause to believe that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS. NOTE: PROPERTY OWNER / MANAGEMENT COMPANY SHALL PROVIDE ACCESS TO UNIT(S) TO VERIFY ALL VIOLATION(S) HAVE BEEN CORRECTED. FAILURE TO PROVIDE ACCESS BY THE COMPLIANCE DATE BELOW MAY RESULT IN A CITATION BEING ISSUED.
- The building lacks the required carbon monoxide alarms. Install carbon monoxide alarms outside of each sleeping area in the immediate vicinity of the bedrooms and on every level of the dwelling unit. The alarms may be powered by battery or building wiring.
- The building lacks the required smoke detectors. Install smoke detectors in the bedrooms and hallways. The detectors may be powered by battery or building wiring.
- Repair/re-glaze kitchen sink.
- Repair and/or repaint kitchen walls/ceiling where damaged/deteriorated or where paint is peeling/missing. Paint all areas of walls/ceiling that are unpainted.

- Repair/replace and paint all deteriorated roof fascia, eaves and rafter tails.
- There is graffiti painted on the premises. Remove all graffiti from the premises.
- Repair/replace all damaged/missing floor coverings throughout the dwelling.

Address	Owner	Total Violations
528 1/2 NEW YORK ST 90813	HUIZAR, NICOLAS	5

Violations:

- Repair/repaint/secure deteriorated exterior stairway.
- Repair/repaint deteriorated stair landings as directed. Obtain all required permits and inspections.
- Repair/repaint all deteriorated handrails and/or guardrails.
- Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause to believe that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS. NOTE: PROPERTY OWNER / MANAGEMENT COMPANY SHALL PROVIDE ACCESS TO UNIT(S) TO VERIFY ALL VIOLATION(S) HAVE BEEN CORRECTED. FAILURE TO PROVIDE ACCESS BY THE COMPLIANCE DATE BELOW MAY RESULT IN A CITATION BEING ISSUED.
- The electrical service equipment is deteriorated. Replace the service or remove all rust, corrosion and foreign materials and paint the service equipment to prevent further deterioration.

Address	Owner	Total Violations
528 NEW YORK ST 90813	HUIZAR, NICOLAS	3

Violations:

- Repair/repaint deteriorated gas meter enclosure and/or doors.
- Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause to believe that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS. NOTE: PROPERTY OWNER / MANAGEMENT COMPANY SHALL PROVIDE ACCESS TO UNIT(S) TO VERIFY ALL VIOLATION(S) HAVE BEEN CORRECTED. FAILURE TO PROVIDE ACCESS BY THE COMPLIANCE DATE BELOW MAY RESULT IN A CITATION BEING ISSUED.
- The electrical service is deteriorated. Install a new electrical service.

Address**1600 E OCEAN BLVD 90802****Owner****JANKOWSKI SOLIG, PAMELA****Total Violations****21****Violations:**

- No work shall be done on any part of the building or structure beyond the point indicated each successive inspection without first obtaining the written approval of the building official. There shall be a final inspection and approval on all buildings when completed and ready for occupancy. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: REQUEST AND OBTAIN ALL THE SUCCESSIVE AND REQUIRED INSPECTIONS AND WRITTEN APPROVALS ON ALL WORK AND OBTAIN WRITTEN APPROVAL PRIOR TO OCCUPANCY.
- It shall be the duty of the person doing the work authorized by a permit to notify the building official that such is ready for inspection and to provide access to and means for proper inspection of such work. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: REQUEST INSPECTION AND PROVIDE ACCESS TO ALL PERMITTED WORK
- All construction or work for which a permit is required shall be subject to inspection by the building official. It shall be the duty of the permittee to cause the work to be accessible and exposed for inspection purposes. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO, AND EXPOSE ALL CONSTRUCTION WORK FOR THE REQUIRED INSPECTIONS.
- Repair/replace all deteriorated electrical outlets/switches.
- Remove scattered trash, castoff items and debris around premises.
- Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause to believe that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS. NOTE: PROPERTY OWNER / MANAGEMENT COMPANY SHALL PROVIDE ACCESS TO UNIT(S) TO VERIFY ALL VIOLATION(S) HAVE BEEN CORRECTED. FAILURE TO PROVIDE ACCESS BY THE COMPLIANCE DATE BELOW MAY RESULT IN A CITATION BEING ISSUED.
- A. General. No person shall erect, construct, enlarge, alter, repair, remodel, move or demolish any building or part of a building or structure, or change the character or occupancy or use of any building or structure, or part of a building or structure or perform site grading in the city without first obtaining a permit covering such work from the building official. Whenever a building permit is required to abate a substandard condition as defined in LBMC 18.08.200S, code enforcement fees shall be paid in addition to the permit fees. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: OBTAIN BUILDING PERMITS FROM THE DEVELOPMENT SERVICES DEPARTMENT FOR THE CODE ENFORCEMENT DIVISION FOR ALL UNPERMITTED CONSTRUCTION, REMODELING, OR OCCUPANCY CHANGE INCLUDING, BUT NOT LIMITED TO, THE FOLLOWING ITEMS OR DESCRIBED WORK:
 - Repair/repaint deteriorated/missing exterior stucco.
 - Replace/secure all deteriorated/missing exterior siding.
 - Repair/repaint/seal exterior wood trim/surfaces where damaged and/or where paint is peeling/missing.
 - Repair and repaint all deteriorated window frames/components/surfaces.
 - Repair/replace windows to a weather tight condition.
 - Provide 1/4 inch hardware mesh on all foundation vent openings for rodent proofing.
 - Provide mosquito proof screens on all openable windows.

- Repair/replace and paint all deteriorated roof fascia, eaves and rafter tails.
- Repair/replace/remove deteriorated rain gutters and/or down spouts so as to direct rain water runoff away from buildings.
- Repair/repaint/secure deteriorated exterior stairway.
- Repair/repaint deteriorated stair landings as directed. Obtain all required permits and inspections.
- Repair/repaint all deteriorated handrails and/or guardrails.
- Repair/replace all missing or damaged electrical outlet and switch plates.
- Discontinue using cord wiring.

Address	Owner	Total Violations
1201 OLIVE AVE 90813	REDWOOD, ANGELA	5

Violations:

- The water heater enclosure is deteriorated. Repair the required enclosure and secure it to the building wall and to a concrete pad.
 - Replace/secure all deteriorated/missing exterior siding.
 - Repair/Replace deteriorated porches and/or steps.
 - Repair all holes on the exterior of the building.
- Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause to believe that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS. NOTE: PROPERTY OWNER / MANAGEMENT COMPANY SHALL PROVIDE ACCESS TO UNIT(S) TO VERIFY ALL VIOLATION(S) HAVE BEEN CORRECTED. FAILURE TO PROVIDE ACCESS BY THE COMPLIANCE DATE BELOW MAY RESULT IN A CITATION BEING ISSUED.

Address	Owner	Total Violations
1203 1/2 OLIVE AVE 90813	REDWOOD, ANGELA	17

Violations:

- Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause to believe that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS. NOTE: PROPERTY OWNER / MANAGEMENT COMPANY SHALL PROVIDE ACCESS TO UNIT(S) TO VERIFY ALL VIOLATION(S) HAVE BEEN CORRECTED. FAILURE TO PROVIDE ACCESS BY THE COMPLIANCE DATE BELOW MAY RESULT IN A CITATION BEING ISSUED.

- The building lacks the required carbon monoxide alarms. Install carbon monoxide alarms outside of each sleeping area in the immediate vicinity of the bedrooms and on every level of the dwelling unit. The alarms may be powered by battery or building wiring.
- The building lacks the required smoke detectors. Install smoke detectors in the bedrooms and hallways. The detectors maybe powered by battery or building wiring.
- Caulk perimeter of tub/shower at enclosure walls where caulking/grout is deteriorated/missing. Remove all old/deteriorated caulking/grout at enclosure walls.
- Caulk perimeter of sink at rim/cabinet top where caulking/grout is deteriorated/missing. Perimeter of sink must be watertight.
- Caulk gap between wall and sink/cabinet top behind sink. Remove all old/deteriorated caulking/grout. Perimeter of wall behind sink must be watertight.
- Replace all deteriorated bathroom floor coverings.
- Resurface/reglaze tub where surface is deteriorated. Remove any rust on surface of tub. Use proper materials/compounds for resurfacing/reglazing tub.
- Repair/replace faulty/missing fixtures and/or hardware at tub/shower.
- Replace all deteriorated/missing bathroom tiles.
- Walls around shower/tub shall have smooth, hard nonabsorbent surfaces made of Portland cement, concrete, ceramic tile or other smooth, hard nonabsorbent surfaces extending to a height of seventy inches and to no less than two feet away from the edge of the tub/shower enclosure.
- Repair toilet to flush properly. Replace all deteriorated/missing components.
- Secure toilet base to floor.
- Caulk around toilet base.
- Repair/Resurface/Repaint bathroom wall(s) where deteriorated/damaged, where holes exist, and/or where paint is peeling/missing.
- Repair/provide bathroom wall coving where deteriorated/peeling/missing.
- Repair/Replace/Repaint all deteriorated bathroom ceilings.

Address	Owner	Total Violations
1203 OLIVE AVE 90813	REDWOOD, ANGELA	23

Violations:

- The garage area lacks the required access. Provide access to the required parking area.
- Replace all deteriorated bathroom floor coverings.
- Resurface/reglaze tub where surface is deteriorated. Remove any rust on surface of tub. Use proper materials/compounds for resurfacing/reglazing tub.
- Repair/replace faulty/missing fixtures and/or hardware at tub/shower.
- Walls around shower/tub shall have smooth, hard nonabsorbent surfaces made of Portland cement, concrete, ceramic tile or other smooth, hard nonabsorbent surfaces extending to a height of seventy inches and to no less than two feet away from the edge of the tub/shower enclosure.
- Repair/Resurface/Repaint bathroom wall(s) where deteriorated/damaged, where holes exist, and/or where paint is peeling/missing.

- Repair/provide bathroom wall coving where deteriorated/peeling/missing.
- Repair/Replace/Repaint all deteriorated bathroom ceilings.
- Install weather stripping materials around entry door(s) to exclude rodents.
- Properly install weather strip at base of entry door(s) and along sides of door frame to exclude rain water.
- Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause to believe that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS. NOTE: PROPERTY OWNER / MANAGEMENT COMPANY SHALL PROVIDE ACCESS TO UNIT(S) TO VERIFY ALL VIOLATION(S) HAVE BEEN CORRECTED. FAILURE TO PROVIDE ACCESS BY THE COMPLIANCE DATE BELOW MAY RESULT IN A CITATION BEING ISSUED.
- Repair all holes on the exterior of the building.
- Repair/repaint/seal exterior wood trim/surfaces where damaged and/or where paint is peeling/missing.
- Replace/secure all deteriorated/missing exterior siding.
- There is graffiti painted on the premises. Remove all graffiti from the premises.
- The building lacks the required carbon monoxide alarms. Install carbon monoxide alarms outside of each sleeping area in the immediate vicinity of the bedrooms and on every level of the dwelling unit. The alarms may be powered by battery or building wiring.
- The building lacks the required smoke detectors. Install smoke detectors in the bedrooms and hallways. The detectors may be powered by battery or building wiring.
- Repair deteriorated fencing and/or gate(s).
- Repair/repaint/secure deteriorated exterior stairway.
- Repair/repaint deteriorated stair landings as directed. Obtain all required permits and inspections.
- Repair/repaint all deteriorated handrails and/or guardrails.
- Exterminate cockroaches at all units where infestation is present. Seal all cracks, gaps, and holes in walls, floors, and cupboards, and around piping insertions. Remove or paint over all spotting in unit. Provide pest control service to all infested units and surrounding units sharing common floors, ceilings, and walls with infested units. NOTE: Treatment is most effective when all units are treated on the same day, treatment is repeated to target hatching young in two weeks or every two weeks until infestation is removed.
- Repair/resurface/repaint all deteriorated interior walls and ceiling areas.

Address	Owner	Total Violations
848 OLIVE AVE 90813	WALSH, ESSIE	6

Violations:

- Provide mosquito proof screens on all openable windows.

- Repair/replace missing or deteriorated garage door.
- Repair/repaint deteriorated/missing exterior stucco.
- Repair/repaint/seal exterior wood trim/surfaces where damaged and/or where paint is peeling/missing.
- Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause to believe that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS. NOTE: PROPERTY OWNER / MANAGEMENT COMPANY SHALL PROVIDE ACCESS TO UNIT(S) TO VERIFY ALL VIOLATION(S) HAVE BEEN CORRECTED. FAILURE TO PROVIDE ACCESS BY THE COMPLIANCE DATE BELOW MAY RESULT IN A CITATION BEING ISSUED.
- Replace all broken window glass.

Address	Owner	Total Violations
1450 ORANGE AVE 90813	STEWART, JAMES	23

Violations:

- Several areas of the foundation appear to be deteriorated. Repair all the deteriorated areas of the foundation. Note: Access for inspection of the foundation was limited. Further inspection will be necessary and may reveal that major portions or the entire foundation may need to be repaired.
- The underfloor framing is inadequate to support the floor. Provide an approved system of concrete piers, posts and girders to support the floor load.
- A. General. No person shall erect, construct, enlarge, alter, repair, remodel, move or demolish any building or part of a building or structure, or change the character or occupancy or use of any building or structure, or part of a building or structure or perform site grading in the city without first obtaining a permit covering such work from the building official. Whenever a building permit is required to abate a substandard condition as defined in LBMC 18.08.200S, code enforcement fees shall be paid in addition to the permit fees. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: OBTAIN BUILDING PERMITS FROM THE DEVELOPMENT SERVICES DEPARTMENT FOR THE CODE ENFORCEMENT DIVISION FOR ALL UNPERMITTED CONSTRUCTION, REMODELING, OR OCCUPANCY CHANGE INCLUDING, BUT NOT LIMITED TO, THE FOLLOWING ITEMS OR DESCRIBED WORK:
- No work shall be done on any part of the building or structure beyond the point indicated each successive inspection without first obtaining the written approval of the building official. There shall be a final inspection and approval on all buildings when completed and ready for occupancy. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: REQUEST AND OBTAIN ALL THE SUCCESSIVE AND REQUIRED INSPECTIONS AND WRITTEN APPROVALS ON ALL WORK AND OBTAIN WRITTEN APPROVAL PRIOR TO OCCUPANCY.
- Repair and repaint all deteriorated window frames/components/surfaces.
- Repair/Replace all windows to a weathertight condition.
- The ceiling(s) is/are damaged by water. Repair the damaged ceiling(s) and/or leaks and replace with new materials.
- Repair/replace deteriorated sub-floor and/or supports as directed and obtain necessary permits and inspections.
- Repair/replace all damaged/missing floor coverings throughout the dwelling.
- Caulk perimeter of tub/shower at enclosure walls where caulking/grout is deteriorated/missing. Remove all old/deteriorated caulking/grout at enclosure walls.

- Resurface/reglaze tub where surface is deteriorated. Remove any rust on surface of tub. Use proper materials/compounds for resurfacing/reglazing tub.
- The exterior light fixtures lack the protective globes and covers. Replace or provide protective globes and covers for the exterior light fixtures.
- The exit balconies lack adequate lighting. Provide lighting exit balconies to meet minimum code requirements.
- Obtain all required permits and inspections and provide approved unit heater capable of heating unit to 70 degrees Fahrenheit, measured three feet above the floor. A temporary heater must be provided during winter months if a permanent heater cannot be repaired or replaced in a timely manner.
- The building lacks the required carbon monoxide alarms. Install carbon monoxide alarms outside of each sleeping area in the immediate vicinity of the bedrooms and on every level of the dwelling unit. The alarms may be powered by battery or building wiring.
- The building lacks the required smoke detectors. Install smoke detectors in the bedrooms and hallways. The detectors maybe powered by battery or building wiring.
- No person shall install, alter, reconstruct or repair any heating, ventilating, cooling, or refrigeration equipment unless a permit therefore has been obtained from the building official except as otherwise provided in this code. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: OBTAIN A MECHANICAL PERMIT FROM THE DEVELOPMENT SERVICES DEPARTMENT FOR THE CODE ENFORCEMENT DIVISION FOR ALL UNPERMITTED MECHANICAL WORK OR EQUIPMENT INCLUDING, BUT NOT LIMITED TO, THE FOLLOWING ITEMS OR DESCRIBED WORK:
- There is open wiring on the exterior of the building. Terminate all open wiring in an approved enclosure.
- Repair/resurface/repaint all deteriorated interior walls and ceiling areas.
- The floor joists, girders and posts are defective and deteriorated. Replace the defective, deteriorated and missing, floor joists, girders posts.
- Provide 1/4 inch hardware mesh on all foundation vent openings for rodent proofing.
- Property must be clean and free from all weeds and/or debris at all times. Remove all weeds and/or debris from the property.
- Remove scattered trash, castoff items and debris around premises.

Address	Owner	Total Violations
5875 ORANGE AVE 90805	BRAVO, EARL	13

Violations:

- Provide mosquito proof screens on all openable windows.
- The rise and run of the steps/stairs do not comply with code requirements. Reconstruct the steps/stairs to conform to minimum code requirements. Please obtain all required building permit.
- Repair/repaint/seal exterior wood trim/surfaces where damaged and/or where paint is peeling/missing.
- Repair/repaint deteriorated/missing exterior stucco.
- Repair/remove/reinstall closet door(s).
- Provide 1/4 inch hardware mesh on all foundation vent openings for rodent proofing.
- Repair/repaint deteriorated stair landings as directed. Obtain all required permits and inspections.

- Repair/repaint/secure deteriorated exterior stairway.
- The water heater is not properly vented. Vent the water heater in an approved manner using approved materials.
- All construction or work for which a permit is required shall be subject to inspection by the building official. It shall be the duty of the permit tee to cause the work to be accessible and exposed for inspection purposes.PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice:PROVIDE ACCESS TO, AND EXPOSE ALL CONSTRUCTION WORK FOR THE REQUIRED INSPECTIONS.
- It shall be the duty of the person doing the work authorized by a permit to notify the building official that such is ready for inspection and to provide access to and means for proper inspection of such work.PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice:REQUEST INSPECTION AND PROVIDE ACCESS TO ALL PERMITTED WORK
- No work shall be done on any part of the building or structure beyond the point indicated each successive inspection without first obtaining the written approve of the building official. There shall be a final inspection and approval on all buildings when completed and ready for occupancy.PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice:REQUEST AND OBTAIN ALL THE SUCCESSIVE AND REQUIRED INSPECTIONSAND WRITTEN APPROVALS ON ALL WORK AND OBTAIN WRITTEN APPROVAL PRIOR TO OCCUPANCY.
- Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause tobelieve that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed.PROPERTY OWNER: Take the following corrective action in conjunction withany other corrective actions in this Notice:PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS.NOTE: PROPERTY OWNER / MANAGEMENT COMPANY SHALL PROVIDE ACCESS TO UNIT(S) TO VERIFY ALL VIOLATION(S) HAVE BEEN CORRECTED. FAILURE TO PROVIDE ACCESS BY THE COMPLIANCE DATE BELOW MAY RESULT IN A CITATION BEING ISSUED.

Address	Owner	Total Violations
6655 ORANGE AVE 90805	LANE, SHALAMAR	9

Violations:

- Repair/repaint/seal exterior wood trim/surfaces where damaged and/or where paint is peeling/missing.
- Discarded furniture and household items shall not be stored in yard areas. Remove the discarded furniture and/or household items stored or kept in the yard areas.
- Provide smooth, trip free surfaces at all walkways.
- Provide trash facilities adequate enough to handle trash load of tenants on a calendar week basis. Ensure that all containers have closeable lids and are kept closed at all times. Note: Increased frequency of pick up and/or additional containers may be required to accomplish this task.
- Sanitize trash facilities on a routine basis to prevent potential insect/rodent harborage.
- Remove scattered trash, castoff items and debris around premises.
- Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause tobelieve that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed.PROPERTY OWNER: Take the following corrective action in conjunction withany other corrective actions in this Notice:PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS.NOTE: PROPERTY OWNER / MANAGEMENT COMPANY SHALL PROVIDE ACCESS TO UNIT(S) TO VERIFY ALL VIOLATION(S) HAVE BEEN CORRECTED. FAILURE TO PROVIDE ACCESS BY THE COMPLIANCE DATE BELOW MAY RESULT IN A CITATION BEING ISSUED.

- LBMC 9.65.040. It shall be the duty of responsible person(s) to prevent accumulation and storage of abandoned, wrecked, dismantled, or inoperative vehicles or parts thereof, except for those vehicles or parts thereof exempted pursuant to Long Beach Municipal Code Section 10.46.030. Remove all inoperative vehicles or vehicle parts from the property or bring vehicle(s) to an operative condition including current registration status
- There is graffiti painted on the premises. Remove all graffiti from the premises.

Address	Owner	Total Violations
6959 ORCUTT AVE 90805	ROMO, IGNACIO	17

Violations:

- Repair/repaint/secure deteriorated exterior stairway.
- Repair/repaint deteriorated stair landings as directed. Obtain all required permits and inspections.
- Repair/repaint all deteriorated handrails and/or guardrails.
- Discarded furniture and household items shall not be stored in yard areas. Remove the discarded furniture and/or household items stored or kept in the yard areas.
- A. General. No person shall erect, construct, enlarge, alter, repair, remodel, move or demolish any building or part of a building or structure, or change the character or occupancy or use of any building or structure, or part of a building or structure or perform site grading in the city without first obtaining a permit covering such work from the building official. Whenever a building permit is required to abate a substandard condition as defined in LBMC 18.08.200S, code enforcement fees shall be paid in addition to the permit fees. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice:OBTAIN BUILDING PERMITS FROM THE DEVELOPMENT SERVICES DEPARTMENT FOR THE CODE ENFORCEMENT DIVISION FOR ALL UNPERMITTED CONSTRUCTION, REMODELING, OR OCCUPANCY CHANGE INCLUDING, BUT NOT LIMITED TO, THE FOLLOWING ITEMS OR DESCRIBED WORK:
 - All construction or work for which a permit is required shall be subject to inspection by the building official. It shall be the duty of the permit tee to cause the work to be accessible and exposed for inspection purposes.PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice:PROVIDE ACCESS TO, AND EXPOSE ALL CONSTRUCTION WORK FOR THE REQUIRED INSPECTIONS.
 - It shall be the duty of the person doing the work authorized by a permit to notify the building official that such is ready for inspection and to provide access to and means for proper inspection of such work.PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice:REQUEST INSPECTION AND PROVIDE ACCESS TO ALL PERMITTED WORK
 - No work shall be done on any part of the building or structure beyond the point indicated each successive inspection without first obtaining the written approve of the building official. There shall be a final inspection and approval on all buildings when completed and ready for occupancy.PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice:REQUEST AND OBTAIN ALL THE SUCCESSIVE AND REQUIRED INSPECTIONSAND WRITTEN APPROVALS ON ALL WORK AND OBTAIN WRITTEN APPROVAL PRIOR TO OCCUPANCY.
 - Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause tobelieve that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed.PROPERTY OWNER: Take the following corrective action in conjunction withany other corrective actions in this Notice:PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS.NOTE: PROPERTY OWNER / MANAGEMENT COMPANY SHALL PROVIDE ACCESS TO UNIT(S) TO VERIFY ALL VIOLATION(S) HAVE BEEN CORRECTED. FAILURE TO PROVIDE ACCESS BY THE COMPLIANCE DATE BELOW MAY RESULT IN A CITATION BEING ISSUED.
- Replace all broken window glass.

- Provide mosquito proof screens on all openable windows.
- Repair/resurface/repaint all deteriorated interior walls and ceiling areas.
- There is graffiti painted on the premises. Remove all graffiti from the premises.
- Remove scattered trash, castoff items and debris around premises.
- LBMC 9.65.040. It shall be the duty of responsible person(s) to prevent accumulation and storage of abandoned, wrecked, dismantled, or inoperative vehicles or parts thereof, except for those vehicles or parts thereof exempted pursuant to Long Beach Municipal Code Section 10.46.030. Remove all inoperative vehicles or vehicle parts from the property or bring vehicle(s) to an operative condition including current registration status
- Repair/repaint/seal exterior wood trim/surfaces where damaged and/or where paint is peeling/missing.
- Repair/repaint deteriorated/missing exterior stucco.

Address	Owner	Total Violations
1047 PACIFIC AVE 90813	ZIRCON INVESTMENT INC,	20

Violations:

- Replace deteriorated water heater. Obtain all required inspections and permits. Properly vent gas water heater. Strap or secure water heater to protect from earthquake hazards.
- Repair/repaint deteriorated/missing exterior stucco.
- Repair deteriorated fencing and/or gate(s).
- Repair/replace all deteriorated/broken/missing light fixtures.
- All parking facilities and loading areas shall be maintained in a neat and orderly condition and shall be clear of obstructions. Remove all obstructions from the driveway and/or garage which prevent vehicular access.
- Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause to believe that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS.
- A. General. No person shall erect, construct, enlarge, alter, repair, remodel, move or demolish any building or part of a building or structure, or change the character or occupancy or use of any building or structure, or part of a building or structure or perform site grading in the city without first obtaining a permit covering such work from the building official. Whenever a building permit is required to abate a substandard condition as defined in LBMC 18.08.200S, code enforcement fees shall be paid in addition to the permit fees. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: OBTAIN BUILDING PERMITS FROM THE DEVELOPMENT SERVICES DEPARTMENT FOR THE CODE ENFORCEMENT DIVISION FOR ALL UNPERMITTED CONSTRUCTION, REMODELING, OR OCCUPANCY CHANGE INCLUDING, BUT NOT LIMITED TO, THE FOLLOWING ITEMS OR DESCRIBED WORK:
- Repair/resurface/repaint all deteriorated interior walls and ceiling areas.

- LBMC 9.65.040. It shall be the duty of responsible person(s) to prevent accumulation and storage of abandoned, wrecked, dismantled, or inoperative vehicles or parts thereof, except for those vehicles or parts thereof exempted pursuant to Long Beach Municipal Code Section 10.46.030. Remove all inoperative vehicles or vehicle parts from the property or bring vehicle(s) to an operative condition including current registration status

- No new electrical installation shall be made nor any alteration or addition performed to any existing wiring, nor shall any wiring for the placing or installation of any electric light, power or heating device, or any apparatus which generates, transmits, transforms or utilizes electricity operating at a voltage exceeding twenty-five volts between conductors or capable of supplying more than fifty watts, be made without first obtaining an electrical permit. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: OBTAIN AN ELECTRICAL PERMIT FROM THE DEVELOPMENT SERVICES DEPARTMENT FOR THE CODE ENFORCEMENT DIVISION FOR ALL UNPERMITTED ELECTRICAL WORK OR EQUIPMENT INCLUDING, BUT NOT LIMITED TO, THE FOLLOWING ITEMS OR DESCRIBED WORK:

- The electrical outlets on the exterior of the building are required to be GFCI protected. Install the required GFCI protected receptacles on the exterior of the building.
- The exterior light fixtures lack the protective globes and covers. Replace or provide protective globes and covers for the exterior light fixtures.
- Remove scattered trash, castoff items and debris around premises.
- Replace all damaged or missing light fixtures with approved fixtures.
- Repair/replace all missing or damaged electrical outlet and switch plates.
- Repair/Provide bathroom ventilation fan. Obtain any required permits and inspections.
- Replace all broken window glass.
- Repair/replace all deteriorated electrical outlets/switches.
- Provide adequate clean supply of sheets. pillow cases, blankets/comforters. Mattresses shall be kept in good condition free from filth, urine, lice, bedbugs or other insects.
- Temporary electrical power and lighting installations shall be permitted for a period not to exceed 90 days for holiday decorative lighting and similar purposes. Remove all temporary power/lighting installations.

Address	Owner	Total Violations
1630 PARADE ST 90810	MAROVIC, MARIJA	8

Violations:

- Provide mosquito proof screens on all openable windows.
- Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause to believe that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS. NOTE: PROPERTY OWNER / MANAGEMENT COMPANY SHALL PROVIDE ACCESS TO UNIT(S) TO VERIFY ALL VIOLATION(S) HAVE BEEN CORRECTED. FAILURE TO PROVIDE ACCESS BY THE COMPLIANCE DATE BELOW MAY RESULT IN A CITATION BEING ISSUED.
- Provide 1/4 inch hardware mesh on all foundation vent openings for rodent proofing.
- The exterior wall covering is deteriorated. Repair or replace and paint the deteriorated wall covering to a sound and weathertight condition on the structure.

- Properties must be maintained in a condition so as not to become defective, unsightly or in a state of deterioration or disrepair. Remove all items which render the property unsightly and in a state of disrepair.
- The paint covering of all buildings shall be maintained in such a manner so as not to become deteriorated to a condition that would permit decay, discoloration, excessive checking, cracking or warping which would render the building unsightly or in a state of disrepair. Repair and paint all deteriorated exterior portions of the building(s). (Note: If this property is located in a historic district, approval of materials and colors should be obtained from the Historic Preservation Officer at (562) 570-6288.)
- The water heater temperature and pressure relief valve outlet is not piped to the outside of the building. Provide approved piping from the valve outlet to the outside of the building and terminating no more than 2 feet nor less than 6 inches above the ground.
- The underfloor access door is deteriorated. Repair or replace the underfloor access door.

Address	Owner	Total Violations
1630 PARADE ST 90810	MAROVIC, MARIJA	15

Violations:

- Repair/Resurface/Repaint bathroom wall(s) where deteriorated/damaged, where holes exist, and/or where paint is peeling/missing.
- Repair/Replace/Repaint all deteriorated bathroom ceilings.
- Replace all deteriorated bathroom floor coverings.
- Repair and/or repaint kitchen walls/ceiling where damaged/deteriorated or where paint is peeling/missing. Paint all areas of walls/ceiling that are unpainted.
- Repair/replace/repaint damaged/deteriorated wall/base/doors of cabinet under kitchen sink, including holes around pipe penetrations.
- The bathroom lacks the required ventilation. Install a window in the exterior wall of the bathroom or an approved exhaust fan vented to the outside of the building.
- Caulk around toilet base.
- Repair/replace all damaged/missing floor coverings throughout the dwelling.
- The bathroom sink trap and trap arm are not of approved materials. Replace the trap and trap arm with approved material.
- Several aluminum window frames are broken or damaged. Repair or replace the deteriorated aluminum window frames in an approved manner.
- Replace all deteriorated bathroom floor coverings.
- The room heater is inoperative. Replace or repair the room heater to an operative condition.
- Repair/replace deteriorated/missing kitchen floor covering.
- The interior wall and ceiling coverings are deteriorated through out the dwelling. Repair and paint the deteriorated ceiling and wall coverings. 18.45.050 UHC Sec. 1702 (e) Note: if your building was built before 1978, it is likely to contain lead-based paint. Lead-based paint poses a serious health risk when disturbed. To speak with someone about lead-based paint hazards and worker safety, please call the City of Long Beach Lead Poisoning Prevention Program at 562-570-8875 or the National Lead Information Center at 1-800-424-LEAD.

- Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause to believe that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS. NOTE: PROPERTY OWNER / MANAGEMENT COMPANY SHALL PROVIDE ACCESS TO UNIT(S) TO VERIFY ALL VIOLATION(S) HAVE BEEN CORRECTED. FAILURE TO PROVIDE ACCESS BY THE COMPLIANCE DATE BELOW MAY RESULT IN A CITATION BEING ISSUED.

Address	Owner	Total Violations
1630 PARADE ST 90810	MAROVIC, MARIJA	15

Violations:

- Repair/replace all missing or damaged electrical outlet and switch plates.
 - Resurface/reglaze tub where surface is deteriorated. Remove any rust on surface of tub. Use proper materials/compounds for resurfacing/reglazing tub.
 - Caulk perimeter of tub/shower at enclosure walls where caulking/grout is deteriorated/missing. Remove all old/deteriorated caulking/grout at enclosure walls.
 - Exterminate rodents at unit/building. Remove all rodent droppings. Weather strip entry doors, and seal all holes at walls, floors and ceilings.
 - Install weather stripping materials around entry door(s) to exclude rodents.
 - Repair/replace all damaged/missing floor coverings throughout the dwelling.
 - Repair/Resurface/Repaint bathroom wall(s) where deteriorated/damaged, where holes exist, and/or where paint is peeling/missing.
 - Several windows have deteriorated window frames. Repair and paint all the window frames.
- Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause to believe that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS. NOTE: PROPERTY OWNER / MANAGEMENT COMPANY SHALL PROVIDE ACCESS TO UNIT(S) TO VERIFY ALL VIOLATION(S) HAVE BEEN CORRECTED. FAILURE TO PROVIDE ACCESS BY THE COMPLIANCE DATE BELOW MAY RESULT IN A CITATION BEING ISSUED.
- The bathtub surround is deteriorated and unsanitary. Repair, paint and reseal the bathtub surround.
 - The bathtub surround is deteriorated and unsanitary. Repair, paint and reseal the bathtub surround.
 - The interior wall and ceiling coverings are deteriorated through-out the unit. Repair and paint the deteriorated ceiling and wall coverings throughout the dwelling unit. 18.45.050 UHC Sec. 1702 (e) Note: If your building was built before 1978, it is likely to contain lead-based paint. Lead-based paint poses a serious health risk when disturbed. To speak with someone about lead-based paint hazards and worker safety, please call the City of Long Beach Lead Poisoning Prevention Program at 562-570-8875 or the National Lead Information Center at 1-800-424-LEAD.
 - The water heater temperature and pressure relief valve outlet is not piped to the outside of the building. Provide approved piping from the valve outlet to the outside of the building and terminating no more than 2 feet nor less than 6 inches above the ground.
 - The water heater(s) lack the required earthquake straps. Install the required earthquake straps on the water heater(s).

- Remove mold/mildew at unit/room and correct condition causing mold growth. Drywall should be replaced when mold has covered the surface. Inadequate sanitation shall include any visible or otherwise demonstrable mold growth, excluding the presence of molds that is caused by inappropriate housekeeping practices or improper use of natural or mechanical ventilation.

Address

1630 PARADE ST 90810

Owner

MAROVIC, MARIJA

Total Violations

27

Violations:

- Resurface/reglaze tub where surface is deteriorated. Remove any rust on surface of tub. Use proper materials/compounds for resurfacing/reglazing tub.
- Caulk perimeter of tub/shower at enclosure walls where caulking/grout is deteriorated/missing. Remove all old/deteriorated caulking/grout at enclosure walls.
- Replace all deteriorated/missing bathroom tiles.
- Replace all deteriorated bathroom floor coverings.
- Repair/replace deteriorated/non-operational entry door lock/knob.
- Remove mold/mildew at unit/room and correct condition causing mold growth. Drywall should be replaced when mold has covered the surface. Inadequate sanitation shall include any visible or otherwise demonstrable mold growth, excluding the presence of molds that is caused by inappropriate housekeeping practices or improper use of natural or mechanical ventilation.
- The building lacks the required smoke detectors. Install smoke detectors in the bedrooms and hallways. The detectors maybe powered by battery or building wiring.
- The room heater is inoperative. Replace or repair the room heater to an operative condition.
- Repair/Resurface/Repaint bathroom wall(s) where deteriorated/damaged, where holes exist, and/or where paint is peeling/missing.
- Repair/replace all missing or damaged electrical outlet and switch plates.
- Repair/replace all deteriorated electrical outlets/switches.
- The water heater temperature and pressure relief valve outlet is not piped to the outside of the building. Provide approved piping from the valve outlet to the outside of the building and terminating no more than 2 feet nor less than 6 inches above the ground.
- The exterior light fixtures lack the protective globes and covers. Replace or provide protective globes and covers for the exterior light fixtures.
- Repair/replace all damaged/missing floor coverings throughout the dwelling.
- The interior wall and ceiling coverings are deteriorated through out the dwelling. Repair and paint the deteriorated ceiling and wall coverings. 18.45.050 UHC Sec. 1702 (e) Note: if your building was built before 1978, it is likely to contain lead-based paint. Lead-based paint poses a serious health risk when disturbed. To speak with someone about lead-based paint hazards and worker safety, please call the City of Long Beach Lead Poisoning Prevention Program at 562-570-8875 or the National Lead Information Center at 1-800-424-LEAD.
- Repair/replace deteriorated entry door threshold to provide a proper seal when closed.
- Exterminate cockroaches at all units where infestation is present. Seal all cracks, gaps, and holes in walls, floors, and cupboards, and around piping insertions. Remove or paint over all spotting in unit. Provide pest control service to all infested units and surrounding units sharing common floors, ceilings, and walls with infested units. NOTE: Treatment is most effective when all units are treated on the same day, treatment is repeated to target hatching young in two weeks or every two weeks until infestation is removed.

- Exterminate rodents at unit/building. Remove all rodent droppings. Weather strip entry doors, and seal allholesat walls, floors and ceilings.
- Install weather stripping materials aroundentry door(s) to exclude rodents.
- Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause tobelieve that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed.**PROPERTY OWNER: Take the following corrective action in conjunction withany other corrective actions in this Notice:PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS.NOTE: PROPERTY OWNER / MANAGEMENT COMPANY SHALL PROVIDE ACCESS TO UNIT(S) TO VERIFY ALL VIOLATION(S) HAVE BEEN CORRECTED. FAILURE TO PROVIDE ACCESS BY THE COMPLIANCE DATE BELOW MAY RESULT IN A CITATION BEING ISSUED.**
- Caulk around toilet base.
- Repair/Replace deteriorated kitchen cabinet and/or doors.
- Repair/replace/repaint damaged/deteriorated wall/base/doors of cabinet under kitchen sink, including holes around pipe penetrations.
- Repair and/or repaint kitchen walls/ceiling where damaged/deteriorated or where paint is peeling/missing. Paint all areas of walls/ceiling that are unpainted.
- Seal/caulk kitchen counter top at sink to prevent water intrusion/damage at kitchen walls/floors/cabinet.
- Seal/caulk perimeter/rim of kitchen sink. Caulking/grout must be watertight, smooth and cleanable. Remove old/deteriorated caulking/grout.
- Repair/replace deteriorated/missing kitchen floor covering.

Address	Owner	Total Violations
912 PARK CIR A 90813	MCCAFFERTY, CAROL	19

Violations:

- Obtain all required permits and inspections and provide approved unit heater capable of heating unit to 70 degrees Fahrenheit, measured three feet above the floor. NOTE: Space heaters are not approved for permanent use.
- A. General. No person shall erect, construct, enlarge, alter, repair, remodel, move or demolish any building or part of a building or structure, or change the character or occupancy or use of any building or structure, or part of a building or structure or perform site grading in the city without first obtaining a permit covering such work from the building official. Whenever a building permit is required to abate a substandard condition as defined in LBMC 18.08.200S, code enforcement fees shall be paid in addition to the permit fees. **PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice:OBTAIN BUILDING PERMITS FROM THE DEVELOPMENT SERVICES DEPARTMENT FOR THE CODE ENFORCEMENT DIVISION FOR ALL UNPERMITTED CONSTRUCTION, REMODELING, OR OCCUPANCY CHANGE INCLUDING, BUT NOT LIMITED TO, THE FOLLOWING ITEMS OR DESCRIBED WORK:**
- Repair/repaint/seal exterior wood trim/surfaces where damaged and/or where paint is peeling/missing.
- Replace/secure all deteriorated/missing exterior siding.

- Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause to believe that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS. NOTE: PROPERTY OWNER / MANAGEMENT COMPANY SHALL PROVIDE ACCESS TO UNIT(S) TO VERIFY ALL VIOLATION(S) HAVE BEEN CORRECTED. FAILURE TO PROVIDE ACCESS BY THE COMPLIANCE DATE BELOW MAY RESULT IN A CITATION BEING ISSUED.

- No work shall be done on any part of the building or structure beyond the point indicated each successive inspection without first obtaining the written approval of the building official. There shall be a final inspection and approval on all buildings when completed and ready for occupancy. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: REQUEST AND OBTAIN ALL THE SUCCESSIVE AND REQUIRED INSPECTIONS AND WRITTEN APPROVALS ON ALL WORK AND OBTAIN WRITTEN APPROVAL PRIOR TO OCCUPANCY.

- It shall be the duty of the person doing the work authorized by a permit to notify the building official that such is ready for inspection and to provide access to and means for proper inspection of such work. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: REQUEST INSPECTION AND PROVIDE ACCESS TO ALL PERMITTED WORK

- All construction or work for which a permit is required shall be subject to inspection by the building official. It shall be the duty of the permittee to cause the work to be accessible and exposed for inspection purposes. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO, AND EXPOSE ALL CONSTRUCTION WORK FOR THE REQUIRED INSPECTIONS.

- Repair and repaint all deteriorated window frames/components/surfaces.

- The stairway, landings and railings are defective. Replace the defective and deteriorated stairway, landings, and railings.

- Provide 1/4 inch hardware mesh on all foundation vent openings for rodent proofing.

- Provide 1/4 inch hardware mesh on all attic vents to prevent rodent entry. Use 1/8 inch hardware mesh to eliminate potential for bee hives.

- The ceiling(s) is/are damaged by water. Repair the damaged ceiling(s) and/or leaks and replace with new materials.

- Repair all holes on the exterior of the building.

- The roof covering is defective. Replace the defective and deteriorated roof covering.

- Portions of the roof sheathing are deteriorated. Replace all deteriorated portions of the roof sheathing and repair the roof with approved materials installed in an approved manner.

- Repair/replace and paint all deteriorated roof fascia, eaves and rafter tails.

- Take immediate action to repair/replace roof to be watertight.

- The stairway, landings and railings are defective. Replace the defective and deteriorated stairway, landings, and railings.

Address

2336 PASADENA AVE 90806

Owner

WELLS FARGO BANK TR,

Total Violations

9

Violations:

- Repair/replace all deteriorated/broken/missing light fixtures.

- Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause to believe that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS. NOTE: PROPERTY OWNER / MANAGEMENT COMPANY SHALL PROVIDE ACCESS TO UNIT(S) TO VERIFY ALL VIOLATION(S) HAVE BEEN CORRECTED. FAILURE TO PROVIDE ACCESS BY THE COMPLIANCE DATE BELOW MAY RESULT IN A CITATION BEING ISSUED.

- Repair/replace and paint all deteriorated roof fascia, eaves and rafter tails.

- Remove animal fecal material from premises on a daily basis, placing it in a sealed plastic bag for disposal with the regular trash. Wash down or mop urine with a small amount of diluted sanitizer to eliminate odor. Do not hose off balconies onto other balconies, street, alley, or common areas.

- Trim all overgrown foliage/lawns/shrubs at property to prevent vermin/rodent harborage or entrance to units/buildings.

- Remove scattered trash, castoff items and debris around premises.

- Repair/repaint/seal exterior wood trim/surfaces where damaged and/or where paint is peeling/missing.

- There is graffiti painted on the premises. Remove all graffiti from the premises.

- It shall be the duty of responsible person(s) to prevent accumulation and storage of abandoned, wrecked, dismantled, or inoperative vehicles or parts thereof, except for those vehicles or parts thereof exempted pursuant to Long Beach Municipal Code Section 10.46.030. Remove all inoperative vehicles or vehicle parts from the property or bring vehicle(s) to an operative condition including current registration status.

Address	Owner	Total Violations
1135 RAYMOND AVE 90804	1135 RAYMOND APTS LLC,	4

Violations:

- Remove scattered trash, castoff items and debris around premises.

- Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause to believe that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS. NOTE: PROPERTY OWNER / MANAGEMENT COMPANY SHALL PROVIDE ACCESS TO UNIT(S) TO VERIFY ALL VIOLATION(S) HAVE BEEN CORRECTED. FAILURE TO PROVIDE ACCESS BY THE COMPLIANCE DATE BELOW MAY RESULT IN A CITATION BEING ISSUED.

- Discarded furniture and household items shall not be stored in yard areas. Remove the discarded furniture and/or household items stored or kept in the yard areas.

- Replace/secure all deteriorated/missing exterior siding.

Address	Owner	Total Violations
1371 REDONDO AVE 14 90804	CHANG, GRACE	33

Violations:

- Repair deteriorated entry door framing and/or jamb.
- Repair/Repaint/Weatherproof exterior door.
- Repair/replace deteriorated entry door threshold to provide a proper seal when closed.
- Repair/replace deteriorated/non-operational entry door lock/knob.
- Repair/Replace/Provide approved security locking mechanism for entry door(s). (Note: Do not install deadbolt locks that are keyed on both sides - use only those with thumb latches on entry doors).
- Repair/resurface/repaint interior door(s).
- Exterminate cockroaches at all units where infestation is present. Seal all cracks, gaps, and holes in walls, floors, and cupboards, and around piping insertions. Remove or paint over all spotting in unit. Provide pest control service to all infested units and surrounding units sharing common floors, ceilings, and walls with infested units. NOTE: Treatment is most effective when all units are treated on the same day, treatment is repeated to target hatching young in two weeks or every two weeks until infestation is removed.
- Exterminate rodents at unit/building. Remove all rodent droppings. Weather strip entry doors, and seal all holes at walls, floors and ceilings.
- Repair/replace and paint all deteriorated roof fascia, eaves and rafter tails.
- Repair/replace/remove deteriorated rain gutters and/or down spouts so as to direct rain water runoff away from buildings.
- All properties shall be posted with the number or numbers designated for the principal entrance or entrances of a building. Install address numbers, not less than three inches in height, at the principal entrance of the building in plain view from the public right-of-way.
- Repair/replace faulty/missing fixtures and/or hardware at tub/shower.
- Repair/provide bathroom wall coving where deteriorated/peeling/missing.
- Several areas of the foundation appear to be deteriorated. Repair all the deteriorated areas of the foundation. Note: Access for inspection of the foundation was limited. Further inspection will be necessary and may reveal that major portions or the entire foundation may need to be repaired.
- The water heater is not properly vented. Vent the water heater in an approved manner using approved materials.
- The water heater is not properly vented. Vent the water heater in an approved manner using approved materials.
- The plumbing waste and vent system is deteriorated and leaks. Repair or replace the waste and vent system.
- Provide 1/4 inch hardware mesh on all foundation vent openings for rodent proofing.
- No work shall be done on any part of the building or structure beyond the point indicated each successive inspection without first obtaining the written approval of the building official. There shall be a final inspection and approval on all buildings when completed and ready for occupancy. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: REQUEST AND OBTAIN ALL THE SUCCESSIVE AND REQUIRED INSPECTIONS AND WRITTEN APPROVALS ON ALL WORK AND OBTAIN WRITTEN APPROVAL PRIOR TO OCCUPANCY.
- It shall be the duty of the person doing the work authorized by a permit to notify the building official that such is ready for inspection and to provide access to and means for proper inspection of such work. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: REQUEST INSPECTION AND PROVIDE ACCESS TO ALL PERMITTED WORK

- All construction or work for which a permit is required shall be subject to inspection by the building official. It shall be the duty of the permit tee to cause the work to be accessible and exposed for inspection purposes.PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice:PROVIDE ACCESS TO, AND EXPOSE ALL CONSTRUCTION WORK FOR THE REQUIRED INSPECTIONS.

- Repair/repaint deteriorated/missing exterior stucco.

- A. General. No person shall erect, construct, enlarge, alter, repair, remodel, move or demolish any building or part of a building or structure, or change the character or occupancy or use of any building or structure, or part of a building or structure or perform site grading in the city without first obtaining a permit covering such work from the building official. Whenever a building permit is required to abate a substandard condition as defined in LBMC 18.08.200S, code enforcement fees shall be paid in addition to the permit fees. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice:OBTAIN BUILDING PERMITS FROM THE DEVELOPMENT SERVICES DEPARTMENT FOR THE CODE ENFORCEMENT DIVISION FOR ALL UNPERMITTED CONSTRUCTION, REMODELING, OR OCCUPANCY CHANGE INCLUDING, BUT NOT LIMITED TO, THE FOLLOWING ITEMS OR DESCRIBED WORK:

- Repair/repaint/seal exterior wood trim/surfaces where damaged and/or where paint is peeling/missing.

- Trim all overgrown foliage/lawns/shrubs at propertyto prevent vermin/rodent harborage or entrance to units/buildings.

- Remove scattered trash, castoff items and debris around premises.

- Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause tobelieve that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed.PROPERTY OWNER: Take the following corrective action in conjunction withany other corrective actions in this Notice:PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS.NOTE: PROPERTY OWNER / MANAGEMENT COMPANY SHALL PROVIDE ACCESS TO UNIT(S) TO VERIFY ALL VIOLATION(S) HAVE BEEN CORRECTED. FAILURE TO PROVIDE ACCESS BY THE COMPLIANCE DATE BELOW MAY RESULT IN A CITATION BEING ISSUED.

- Replace all broken window glass.

- Repair/replace windows to a weather tight condition.

- Repair and repaint all deteriorated window frames/components/surfaces.

- Repair/replace all deteriorated/broken/missing light fixtures.

- Repair/replace inoperative/faulty stove, which may cause fire hazard.

- The building lacks the required smoke detectors. Install smoke detectors in the bedrooms and hallways. The detectors maybe powered by battery or building wiring.

Address

431 ROSE AVE 90802

Owner

CLEVELAND, CHARLES

Total Violations

5

Violations:

- The electrical dead front cover(s) of the electrical service/sub panel is missing, damaged or lacking parts which exposes the branch circuit wiring and/or energized parts to human contact. Provide an approved electrical service/sub panel dead front cover(s) for the electrical service/sub panel.

- Repair/Repaint/Weatherproof exterior door.

- Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause to believe that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS. NOTE: PROPERTY OWNER / MANAGEMENT COMPANY SHALL PROVIDE ACCESS TO UNIT(S) TO VERIFY ALL VIOLATION(S) HAVE BEEN CORRECTED. FAILURE TO PROVIDE ACCESS BY THE COMPLIANCE DATE BELOW MAY RESULT IN A CITATION BEING ISSUED.

- All properties shall be posted with the number or numbers designated for the principal entrance or entrances of a building. Install address numbers, not less than three inches in height, at the principal entrance of the building in plain view from the public right-of-way.

- Provide mosquito proof screens on all openable windows.

Address	Owner	Total Violations
445 ROSE AVE 3 90802	445 APARTMENTS LLC,	5

Violations:

- Exterminate cockroaches at all units where infestation is present. Seal all cracks, gaps, and holes in walls, floors, and cupboards, and around piping insertions. Remove or paint over all spotting in unit. Provide pest control service to all infested units and surrounding units sharing common floors, ceilings, and walls with infested units. NOTE: Treatment is most effective when all units are treated on the same day, treatment is repeated to target hatching young in two weeks or every two weeks until infestation is removed.

- The building lacks the required carbon monoxide alarms. Install carbon monoxide alarms outside of each sleeping area in the immediate vicinity of the bedrooms and on every level of the dwelling unit. The alarms may be powered by battery or building wiring.

- Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause to believe that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS. NOTE: PROPERTY OWNER / MANAGEMENT COMPANY SHALL PROVIDE ACCESS TO UNIT(S) TO VERIFY ALL VIOLATION(S) HAVE BEEN CORRECTED. FAILURE TO PROVIDE ACCESS BY THE COMPLIANCE DATE BELOW MAY RESULT IN A CITATION BEING ISSUED.

- Repair/replace/remove garbage disposal.

- Seal/caulk perimeter/rim of kitchen sink. Caulking/grout must be watertight, smooth and cleanable. Remove old/deteriorated caulking/grout.

Address	Owner	Total Violations
445 ROSE AVE 8 90802	445 APARTMENTS LLC,	4

Violations:

- Repair/resurface/repaint all deteriorated interior walls and ceiling areas.

- Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause to believe that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS. NOTE: PROPERTY OWNER / MANAGEMENT COMPANY SHALL PROVIDE ACCESS TO UNIT(S) TO VERIFY ALL VIOLATION(S) HAVE BEEN CORRECTED. FAILURE TO PROVIDE ACCESS BY THE COMPLIANCE DATE BELOW MAY RESULT IN A CITATION BEING ISSUED.

- Repair/Replace deteriorated kitchen cabinet and/or doors.

- Repair/replace faucet/controls at bathroom sink.

Address	Owner	Total Violations
445 ROSE AVE 90802	445 APARTMENTS LLC,	3

Violations:

- Seal all holes at garage walls/ceiling/floor where garages are attached to residential units to prevent vermin/rodent entry into units. All holes greater than 1/4 inch must be sealed, including holes at pipe penetrations.

- Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause to believe that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS. NOTE: PROPERTY OWNER / MANAGEMENT COMPANY SHALL PROVIDE ACCESS TO UNIT(S) TO VERIFY ALL VIOLATION(S) HAVE BEEN CORRECTED. FAILURE TO PROVIDE ACCESS BY THE COMPLIANCE DATE BELOW MAY RESULT IN A CITATION BEING ISSUED.

- All properties shall be posted with the number or numbers designated for the principal entrance or entrances of a building. Install address numbers, not less than three inches in height, at the principal entrance of the building in plain view from the public right-of-way.

Address	Owner	Total Violations
455 ROSE AVE 6 90802	455 APARTMENTS LLC,	4

Violations:

- Repair/replace all damaged/missing floor coverings throughout the dwelling.

- The building lacks the required carbon monoxide alarms. Install carbon monoxide alarms outside of each sleeping area in the immediate vicinity of the bedrooms and on every level of the dwelling unit. The alarms may be powered by battery or building wiring.

- The building lacks the required smoke detectors. Install smoke detectors in the bedrooms and hallways. The detectors may be powered by battery or building wiring.

- Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause to believe that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS. NOTE: PROPERTY OWNER / MANAGEMENT COMPANY SHALL PROVIDE ACCESS TO UNIT(S) TO VERIFY ALL VIOLATION(S) HAVE BEEN CORRECTED. FAILURE TO PROVIDE ACCESS BY THE COMPLIANCE DATE BELOW MAY RESULT IN A CITATION BEING ISSUED.

Address	Owner	Total Violations
455 ROSE AVE 7 90802	455 APARTMENTS LLC,	4

Violations:

- Repair/replace all damaged/missing floor coverings throughout the dwelling.

- Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause to believe that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS. NOTE: PROPERTY OWNER / MANAGEMENT COMPANY SHALL PROVIDE ACCESS TO UNIT(S) TO VERIFY ALL VIOLATION(S) HAVE BEEN CORRECTED. FAILURE TO PROVIDE ACCESS BY THE COMPLIANCE DATE BELOW MAY RESULT IN A CITATION BEING ISSUED.

- The building lacks the required carbon monoxide alarms. Install carbon monoxide alarms outside of each sleeping area in the immediate vicinity of the bedrooms and on every level of the dwelling unit. The alarms may be powered by battery or building wiring.

- The building lacks the required smoke detectors. Install smoke detectors in the bedrooms and hallways. The detectors may be powered by battery or building wiring.

Address	Owner	Total Violations
455 ROSE AVE 90802	455 APARTMENTS LLC,	9

Violations:

- No new electrical installation shall be made nor any alteration or addition performed to any existing wiring, nor shall any wiring for the placing or installation of any electric light, power or heating device, or any apparatus which generates, transmits, transforms or utilizes electricity operating at a voltage exceeding twenty-five volts between conductors or capable of supplying more than fifty watts, be made without first obtaining an electrical permit. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: OBTAIN AN ELECTRICAL PERMIT FROM THE DEVELOPMENT SERVICES DEPARTMENT FOR THE CODE ENFORCEMENT DIVISION FOR ALL UNPERMITTED ELECTRICAL WORK OR EQUIPMENT INCLUDING, BUT NOT LIMITED TO, THE FOLLOWING ITEMS OR DESCRIBED WORK:

- A. General. No person shall erect, construct, enlarge, alter, repair, remodel, move or demolish any building or part of a building or structure, or change the character or occupancy or use of any building or structure, or part of a building or structure or perform site grading in the city without first obtaining a permit covering such work from the building official. Whenever a building permit is required to abate a substandard condition as defined in LBMC 18.08.200S, code enforcement fees shall be paid in addition to the permit fees. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: OBTAIN BUILDING PERMITS FROM THE DEVELOPMENT SERVICES DEPARTMENT FOR THE CODE ENFORCEMENT DIVISION FOR ALL UNPERMITTED CONSTRUCTION, REMODELING, OR OCCUPANCY CHANGE INCLUDING, BUT NOT LIMITED TO, THE FOLLOWING ITEMS OR DESCRIBED WORK:

- Plans, engineering calculations, diagrams and other data shall be submitted in one or more sets with each application for a permit. The building official may require plans, computations and specifications to be prepared and designed by an engineer or architect licensed by the state of California to practice as such. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE THREE SETS OF PLANS, SPECIFICATIONS OR OTHER DETAILS AS REQUIRED BY THE DEPARTMENT OF DEVELOPMENT SERVICES WITH THE APPLICATION FOR THE REQUIRED PERMIT.

- All construction or work for which a permit is required shall be subject to inspection by the building official. It shall be the duty of the permittee to cause the work to be accessible and exposed for inspection purposes. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO, AND EXPOSE ALL CONSTRUCTION WORK FOR THE REQUIRED INSPECTIONS.

- It shall be the duty of the person doing the work authorized by a permit to notify the building official that such is ready for inspection and to provide access to and means for proper inspection of such work. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: REQUEST INSPECTION AND PROVIDE ACCESS TO ALL PERMITTED WORK

- Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause to believe that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS. NOTE: PROPERTY OWNER / MANAGEMENT COMPANY SHALL PROVIDE ACCESS TO UNIT(S) TO VERIFY ALL VIOLATION(S) HAVE BEEN CORRECTED. FAILURE TO PROVIDE ACCESS BY THE COMPLIANCE DATE BELOW MAY RESULT IN A CITATION BEING ISSUED.

- No person shall commence, do, install, erect, construct, remove, add to or change any plumbing, water piping, gas piping, water heater, water heater vents, water treating equipment, or any appliance or device regulated by this chapter without obtaining a permit approving the proposed quality and character of workmanship and materials." PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: OBTAIN A PLUMBING PERMIT FROM THE DEVELOPMENT SERVICES DEPARTMENT FOR THE CODE ENFORCEMENT DIVISION FOR ALL UNPERMITTED PLUMBING WORK OR EQUIPMENT INCLUDING, BUT NOT LIMITED TO, THE FOLLOWING ITEMS OR DESCRIBED WORK:

- No work shall be done on any part of the building or structure beyond the point indicated each successive inspection without first obtaining the written approval of the building official. There shall be a final inspection and approval on all buildings when completed and ready for occupancy. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: REQUEST AND OBTAIN ALL THE SUCCESSIVE AND REQUIRED INSPECTIONS AND WRITTEN APPROVALS ON ALL WORK AND OBTAIN WRITTEN APPROVAL PRIOR TO OCCUPANCY.

- All properties shall be posted with the number or numbers designated for the principal entrance or entrances of a building. Install address numbers, not less than three inches in height, at the principal entrance of the building in plain view from the public right-of-way.

Address	Owner	Total Violations
491 ROSE AVE 90802	CRAIG, IAN	9

Violations:

- Provide 1/4 inch hardware mesh on all foundation vent openings for rodent proofing.
- Trim trees/shrubs to no less than 18 inches from building and roof to prevent rodent entrance to building(s).

- Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause to believe that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS. NOTE: PROPERTY OWNER / MANAGEMENT COMPANY SHALL PROVIDE ACCESS TO UNIT(S) TO VERIFY ALL VIOLATION(S) HAVE BEEN CORRECTED. FAILURE TO PROVIDE ACCESS BY THE COMPLIANCE DATE BELOW MAY RESULT IN A CITATION BEING ISSUED.

- Remove scattered trash, castoff items and debris around premises.

- All parking facilities and loading areas shall be maintained in a neat and orderly condition and shall be clear of obstructions. Remove all obstructions from the driveway and/or garage which prevent vehicular access.

- Trim all overgrown foliage/lawns/shrubs at property to prevent vermin/rodent harborage or entrance to units/buildings.

- No person shall commence, do, install, erect, construct, remove, add to or change any plumbing, water piping, gas piping, water heater, water heater vents, water treating equipment, or any appliance or device regulated by this chapter without obtaining a permit approving the proposed quality and character of workmanship and materials." PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: OBTAIN A PLUMBING PERMIT FROM THE DEVELOPMENT SERVICES DEPARTMENT FOR THE CODE ENFORCEMENT DIVISION FOR ALL UNPERMITTED PLUMBING WORK OR EQUIPMENT INCLUDING, BUT NOT LIMITED TO, THE FOLLOWING ITEMS OR DESCRIBED WORK:

- All construction or work for which a permit is required shall be subject to inspection by the building official. It shall be the duty of the permittee to cause the work to be accessible and exposed for inspection purposes. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO, AND EXPOSE ALL CONSTRUCTION WORK FOR THE REQUIRED INSPECTIONS.

- No work shall be done on any part of the building or structure beyond the point indicated each successive inspection without first obtaining the written approval of the building official. There shall be a final inspection and approval on all buildings when completed and ready for occupancy. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: REQUEST AND OBTAIN ALL THE SUCCESSIVE AND REQUIRED INSPECTIONS AND WRITTEN APPROVALS ON ALL WORK AND OBTAIN WRITTEN APPROVAL PRIOR TO OCCUPANCY.

Address

Owner

Total Violations

2264 SAN ANSELIN AVE 6 90815

G AND R PARK LLC,

9

Violations:

- Repair deteriorated fencing and/or gate(s).

- Repair/replace deteriorated sub-floor and/or supports as directed and obtain necessary permits and inspections.

- The roof covering is defective. Replace the defective and deteriorated roof covering.

- No new electrical installation shall be made nor any alteration or addition performed to any existing wiring, nor shall any wiring for the placing or installation of any electric light, power or heating device, or any apparatus which generates, transmits, transforms or utilizes electricity operating at a voltage exceeding twenty-five volts between conductors or capable of supplying more than fifty watts, be made without first obtaining an electrical permit. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: OBTAIN AN ELECTRICAL PERMIT FROM THE DEVELOPMENT SERVICES DEPARTMENT FOR THE CODE ENFORCEMENT DIVISION FOR ALL UNPERMITTED ELECTRICAL WORK OR EQUIPMENT INCLUDING, BUT NOT LIMITED TO, THE FOLLOWING ITEMS OR DESCRIBED WORK:

- All construction or work for which a permit is required shall be subject to inspection by the building official. It shall be the duty of the permittee to cause the work to be accessible and exposed for inspection purposes. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO, AND EXPOSE ALL CONSTRUCTION WORK FOR THE REQUIRED INSPECTIONS.

- No person shall commence, do, install, erect, construct, remove, add to or change any plumbing, water piping, gas piping, water heater, water heater vents, water treating equipment, or any appliance or device regulated by this chapter without obtaining a permit approving the proposed quality and character of workmanship and materials."PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice:OBTAIN A PLUMBING PERMIT FROM THE DEVELOPMENT SERVICES DEPARTMENT FOR THE CODE ENFORCEMENT DIVISION FOR ALL UNPERMITTED PLUMBING WORK OR EQUIPMENT INCLUDING, BUT NOT LIMITED TO, THE FOLLOWING ITEMS OR DESCRIBED WORK:

- A. General. No person shall erect, construct, enlarge, alter, repair, remodel, move or demolish any building or part of a building or structure, or change the character or occupancy or use of any building or structure, or part of a building or structure or perform site grading in the city without first obtaining a permit covering such work from the building official. Whenever a building permit is required to abate a substandard condition as defined in LBMC 18.08.200S, code enforcement fees shall be paid in addition to the permit fees. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice:OBTAIN BUILDING PERMITS FROM THE DEVELOPMENT SERVICES DEPARTMENT FOR THE CODE ENFORCEMENT DIVISION FOR ALL UNPERMITTED CONSTRUCTION, REMODELING, OR OCCUPANCY CHANGE INCLUDING, BUT NOT LIMITED TO, THE FOLLOWING ITEMS OR DESCRIBED WORK:

- No work shall be done on any part of the building or structure beyond the point indicated each successive inspection without first obtaining the written approval of the building official. There shall be a final inspection and approval on all buildings when completed and ready for occupancy.PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice:REQUEST AND OBTAIN ALL THE SUCCESSIVE AND REQUIRED INSPECTIONSAND WRITTEN APPROVALS ON ALL WORK AND OBTAIN WRITTEN APPROVAL PRIOR TO OCCUPANCY.

- Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause to believe that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed.PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice:PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS.NOTE: PROPERTY OWNER / MANAGEMENT COMPANY SHALL PROVIDE ACCESS TO UNIT(S) TO VERIFY ALL VIOLATION(S) HAVE BEEN CORRECTED. FAILURE TO PROVIDE ACCESS BY THE COMPLIANCE DATE BELOW MAY RESULT IN A CITATION BEING ISSUED.

Address	Owner	Total Violations
2232 SANTA FE AVE 14 90810	RSR PARTNERS LLC,	5

Violations:

- Exterminate cockroaches at all units where infestation is present.Seal all cracks, gaps, and holes in walls, floors, and cupboards, and around piping insertions. Remove or paint over all spotting in unit. Provide pest control service to all infested units and surrounding units sharing common floors, ceilings, and walls with infested units. NOTE: Treatment is most effective when all units are treated on the same day, treatment is repeated to target hatching young in two weeks or every two weeks until infestation is removed.

- The building lacks the required carbon monoxide alarms. Install carbon monoxide alarms outside of each sleeping area in the immediate vicinity of the bedrooms and on every level of the dwelling unit. The alarms may be powered by battery or building wiring.

- Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause to believe that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed.PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice:PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS.NOTE: PROPERTY OWNER / MANAGEMENT COMPANY SHALL PROVIDE ACCESS TO UNIT(S) TO VERIFY ALL VIOLATION(S) HAVE BEEN CORRECTED. FAILURE TO PROVIDE ACCESS BY THE COMPLIANCE DATE BELOW MAY RESULT IN A CITATION BEING ISSUED.

- Repair/resurface/repaint all deteriorated interior walls and ceiling areas.

- The building lacks the required smoke detectors. Install smoke detectors in the bedrooms and hallways. The detectors maybe powered by battery or building wiring.

Address

1719 SHERMAN PL 90804

Owner

LARIOS, JUAN

Total Violations

16

Violations:

- A. General. No person shall erect, construct, enlarge, alter, repair, remodel, move or demolish any building or part of a building or structure, or change the character or occupancy or use of any building or structure, or part of a building or structure or perform site grading in the city without first obtaining a permit covering such work from the building official. Whenever a building permit is required to abate a substandard condition as defined in LBMC 18.08.200S, code enforcement fees shall be paid in addition to the permit fees. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice:OBTAIN BUILDING PERMITS FROM THE DEVELOPMENT SERVICES DEPARTMENT FOR THE CODE ENFORCEMENT DIVISION FOR ALL UNPERMITTED CONSTRUCTION, REMODELING, OR OCCUPANCY CHANGE INCLUDING, BUT NOT LIMITED TO, THE FOLLOWING ITEMS OR DESCRIBED WORK:

- Plans, engineering calculations, diagrams and other data shall be submitted in one or more sets with each application for a permit. The building official may require plans, computations and specifications to be prepared and designed by an engineer or architect licensed by the state of California to practice as such.PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice:PROVIDE THREE SETS OF PLANS, SPECIFICATIONS OR OTHER DETAILS ASREQUIRED BY THE DEPARTMENT OF DEVELOPMENT SERVICES WITH THE APPLICATION FOR THE REQUIRED PERMIT.

- Repair/repaint all deteriorated handrails and/or guardrails.

- Each room, hallway, passageway, stairway, wall, partition, ceiling, floor, skylight, glass window, door, carpet rug, matting, window curtain, water closet, compartment, or room, toilet room, bathroom, slop sink room, washroom, plumbing fixtures, drain, roof, closet, cellar,basement, yard, court, lot and the premises of every building shall be kept in every part clean, sanitary, and free from all accumulation of debris, abandoned or inoperative motorvehicles and vehicle parts, filth, rubbish, garbage, rodents, insects and other vermin, excessive vegetation and other offensive matter. Remove all unsanitary items from the premises.

- All construction or work for which a permit is required shall be subject to inspection by the building official. It shall be the duty of the permit tee to cause the work to be accessible and exposed for inspection purposes.PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice:PROVIDE ACCESS TO, AND EXPOSE ALL CONSTRUCTION WORK FOR THE REQUIRED INSPECTIONS.

- It shall be the duty of the person doing the work authorized by a permit to notify the building official that such is ready for inspection and to provide access to and means for proper inspection of such work.PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice:REQUEST INSPECTION AND PROVIDE ACCESS TO ALL PERMITTED WORK

- Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause tobelieve that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed.PROPERTY OWNER: Take the following corrective action in conjunction withany other corrective actions in this Notice:PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS.NOTE: PROPERTY OWNER / MANAGEMENT COMPANY SHALL PROVIDE ACCESS TO UNIT(S) TO VERIFY ALL VIOLATION(S) HAVE BEEN CORRECTED. FAILURE TO PROVIDE ACCESS BY THE COMPLIANCE DATE BELOW MAY RESULT IN A CITATION BEING ISSUED.

- Repair/repaint deteriorated/missing exterior stucco.

- Repair/Repaint all deteriorated laundry room walls and/or ceilings. Seal all holes, including holes at pipe penetrations, and paint all unpainted surfaces.

- Repair/Replace all plumbing deficiencies.

- Repair/repaint deteriorated electric meter enclosure and/or doors.
- Several of the exterior stair treads are damaged. Replace the damaged stair treads.
- The exterior balcony and guardrails are deteriorated. Repair the deteriorated balcony and guardrails to meet minimum code requirements.
- No work shall be done on any part of the building or structure beyond the point indicated each successive inspection without first obtaining the written approval of the building official. There shall be a final inspection and approval on all buildings when completed and ready for occupancy. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: REQUEST AND OBTAIN ALL THE SUCCESSIVE AND REQUIRED INSPECTIONS AND WRITTEN APPROVALS ON ALL WORK AND OBTAIN WRITTEN APPROVAL PRIOR TO OCCUPANCY.
- The water heater temperature and pressure relief valve outlet is not piped to the outside of the building. Provide approved piping from the valve outlet to the outside of the building and terminating no more than 2 feet nor less than 6 inches above the ground.
- The roof fascia, eaves and rafter tails are deteriorated. Replace or repair and paint the roof fascia, eaves and rafter tails.

Address	Owner	Total Violations
1430 SOUTH ST 90805	SOUTH PALM APARTMENTS,	13

Violations:

- A. General. No person shall erect, construct, enlarge, alter, repair, remodel, move or demolish any building or part of a building or structure, or change the character or occupancy or use of any building or structure, or part of a building or structure or perform site grading in the city without first obtaining a permit covering such work from the building official. Whenever a building permit is required to abate a substandard condition as defined in LBMC 18.08.200S, code enforcement fees shall be paid in addition to the permit fees. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: OBTAIN BUILDING PERMITS FROM THE DEVELOPMENT SERVICES DEPARTMENT FOR THE CODE ENFORCEMENT DIVISION FOR ALL UNPERMITTED CONSTRUCTION, REMODELING, OR OCCUPANCY CHANGE INCLUDING, BUT NOT LIMITED TO, THE FOLLOWING ITEMS OR DESCRIBED WORK:
 - All construction or work for which a permit is required shall be subject to inspection by the building official. It shall be the duty of the permittee to cause the work to be accessible and exposed for inspection purposes. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO, AND EXPOSE ALL CONSTRUCTION WORK FOR THE REQUIRED INSPECTIONS.
 - It shall be the duty of the person doing the work authorized by a permit to notify the building official that such is ready for inspection and to provide access to and means for proper inspection of such work. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: REQUEST INSPECTION AND PROVIDE ACCESS TO ALL PERMITTED WORK
 - No work shall be done on any part of the building or structure beyond the point indicated each successive inspection without first obtaining the written approval of the building official. There shall be a final inspection and approval on all buildings when completed and ready for occupancy. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: REQUEST AND OBTAIN ALL THE SUCCESSIVE AND REQUIRED INSPECTIONS AND WRITTEN APPROVALS ON ALL WORK AND OBTAIN WRITTEN APPROVAL PRIOR TO OCCUPANCY.
- Repair deteriorated fencing and/or gate(s).
- Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause to believe that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS. NOTE: PROPERTY OWNER / MANAGEMENT COMPANY SHALL PROVIDE ACCESS TO UNIT(S) TO VERIFY ALL VIOLATION(S) HAVE BEEN CORRECTED. FAILURE TO PROVIDE ACCESS BY THE COMPLIANCE DATE BELOW MAY RESULT IN A CITATION BEING ISSUED.

- No new electrical installation shall be made nor any alteration or addition performed to any existing wiring, nor shall any wiring for the placing or installation of any electric light, power or heating device, or any apparatus which generates, transmits, transforms or utilizes electricity operating at a voltage exceeding twenty-five volts between conductors or capable of supplying more than fifty watts, be made without first obtaining an electrical permit. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: OBTAIN AN ELECTRICAL PERMIT FROM THE DEVELOPMENT SERVICES DEPARTMENT FOR THE CODE ENFORCEMENT DIVISION FOR ALL UNPERMITTED ELECTRICAL WORK OR EQUIPMENT INCLUDING, BUT NOT LIMITED TO, THE FOLLOWING ITEMS OR DESCRIBED WORK:

- No person shall commence, do, install, erect, construct, remove, add to or change any plumbing, water piping, gas piping, water heater, water heater vents, water treating equipment, or any appliance or device regulated by this chapter without obtaining a permit approving the proposed quality and character of workmanship and materials. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: OBTAIN A PLUMBING PERMIT FROM THE DEVELOPMENT SERVICES DEPARTMENT FOR THE CODE ENFORCEMENT DIVISION FOR ALL UNPERMITTED PLUMBING WORK OR EQUIPMENT INCLUDING, BUT NOT LIMITED TO, THE FOLLOWING ITEMS OR DESCRIBED WORK:

- Repair/repaint deteriorated/missing exterior stucco.

- Repair/replace and paint all deteriorated roof fascia, eaves and rafter tails.

- Replace all broken window glass.

- Trim trees/shrubs to no less than 18 inches from building and roof to prevent rodent entrance to building(s).

- Property must be clean and free from all weeds and/or debris at all times. Remove all weeds and/or debris from the property.

Address	Owner	Total Violations
5720 WALNUT AVE 90805	GLADIEUX, KEITH	8

Violations:

- LBMC 9.65.040. It shall be the duty of responsible person(s) to prevent accumulation and storage of abandoned, wrecked, dismantled, or inoperative vehicles or parts thereof, except for those vehicles or parts thereof exempted pursuant to Long Beach Municipal Code Section 10.46.030. Remove all inoperative vehicles or vehicle parts from the property or bring vehicle(s) to an operative condition including current registration status

- Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause to believe that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS. NOTE: PROPERTY OWNER / MANAGEMENT COMPANY SHALL PROVIDE ACCESS TO UNIT(S) TO VERIFY ALL VIOLATION(S) HAVE BEEN CORRECTED. FAILURE TO PROVIDE ACCESS BY THE COMPLIANCE DATE BELOW MAY RESULT IN A CITATION BEING ISSUED.

- Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause to believe that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS. NOTE: PROPERTY OWNER / MANAGEMENT COMPANY SHALL PROVIDE ACCESS TO UNIT(S) TO VERIFY ALL VIOLATION(S) HAVE BEEN CORRECTED. FAILURE TO PROVIDE ACCESS BY THE COMPLIANCE DATE BELOW MAY RESULT IN A CITATION BEING ISSUED.

- A. General. No person shall erect, construct, enlarge, alter, repair, remodel, move or demolish any building or part of a building or structure, or change the character or occupancy or use of any building or structure, or part of a building or structure or perform site grading in the city without first obtaining a permit covering such work from the building official. Whenever a building permit is required to abate a substandard condition as defined in LBMC 18.08.200S, code enforcement fees shall be paid in addition to the permit fees. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice:OBTAIN BUILDING PERMITS FROM THE DEVELOPMENT SERVICES DEPARTMENT FOR THE CODE ENFORCEMENT DIVISION FOR ALL UNPERMITTED CONSTRUCTION, REMODELING, OR OCCUPANCY CHANGE INCLUDING, BUT NOT LIMITED TO, THE FOLLOWING ITEMS OR DESCRIBED WORK:

- No new electrical installation shall be made nor any alteration or addition performed to any existing wiring, nor shall any wiring for the placing or installation of any electric light, power or heating device, or any apparatus which generates, transmits, transforms or utilizes electricity operating at a voltage exceeding twenty-five volts between conductors or capable of supplying more than fifty watts, be made without first obtaining an electrical permit.PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice:OBTAIN AN ELECTRICAL PERMIT FROM THE DEVELOPMENT SERVICES DEPARTMENT FOR THE CODE ENFORCEMENT DIVISION FOR ALL UNPERMITTED ELECTRICAL WORK OR EQUIPMENT INCLUDING, BUT NOT LIMITED TO, THE FOLLOWING ITEMS OR DESCRIBED WORK:

- All construction or work for which a permit is required shall be subject to inspection by the building official. It shall be the duty of the permit tee to cause the work to be accessible and exposed for inspection purposes.PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice:PROVIDE ACCESS TO, AND EXPOSE ALL CONSTRUCTION WORK FOR THE REQUIRED INSPECTIONS.

- It shall be the duty of the person doing the work authorized by a permit to notify the building official that such is ready for inspection and to provide access to and means for proper inspection of such work.PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice:REQUEST INSPECTION AND PROVIDE ACCESS TO ALL PERMITTED WORK

- No work shall be done on any part of the building or structure beyond the point indicated each successive inspection without first obtaining the written approval of the building official. There shall be a final inspection and approval on all buildings when completed and ready for occupancy.PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice:REQUEST AND OBTAIN ALL THE SUCCESSIVE AND REQUIRED INSPECTIONSAND WRITTEN APPROVALS ON ALL WORK AND OBTAIN WRITTEN APPROVAL PRIOR TO OCCUPANCY.

Address**Owner****Total Violations****753 WASHINGTON PL 90813****OLIVEROS ET AL., CATALINA****19****Violations:**

- Remove scattered trash, castoff items and debris around premises.

- It shall be the duty of responsible person(s) to prevent accumulation and storage of abandoned, wrecked, dismantled, or inoperative vehicles or parts thereof, except for those vehicles or parts thereof exempted pursuant to Long Beach Municipal Code Section 10.46.030. Remove all inoperative vehicles or vehicle parts from the property or bring vehicle(s) to an operative condition including current registration status.

- Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause to believe that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed.PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice:PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS.NOTE: PROPERTY OWNER / MANAGEMENT COMPANY SHALL PROVIDE ACCESS TO UNIT(S) TO VERIFY ALL VIOLATION(S) HAVE BEEN CORRECTED. FAILURE TO PROVIDE ACCESS BY THE COMPLIANCE DATE BELOW MAY RESULT IN A CITATION BEING ISSUED.

- Repair/replace and paint all deteriorated roof fascia, eaves and rafter tails.

- Remove trash/debris from roof areas.

- Portions of the roof sheathing are deteriorated. Replace all deteriorated portions of the roof sheathing and repair the roof with approved materials installed in an approved manner.
- The roof covering is defective. Replace the defective and deteriorated roof covering.
- Provide 1/4 inch hardware mesh on all foundation vent openings for rodent proofing.
- Repair all holes on the exterior of the building.
- Repair/repaint/seal exterior wood trim/surfaces where damaged and/or where paint is peeling/missing.
- Repair/repaint deteriorated/missing exterior stucco.
- Repair/resurface/repaint deteriorated guardrails; loose/broken components.
- Provide mosquito proof screens on all openable windows.
- Discontinue using cord wiring.
- The electrical service enclosure is deteriorated and the door is missing. Repair the enclosure to a weathertight condition.
- A. General. No person shall erect, construct, enlarge, alter, repair, remodel, move or demolish any building or part of a building or structure, or change the character or occupancy or use of any building or structure, or part of a building or structure or perform site grading in the city without first obtaining a permit covering such work from the building official. Whenever a building permit is required to abate a substandard condition as defined in LBMC 18.08.200S, code enforcement fees shall be paid in addition to the permit fees. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice:OBTAIN BUILDING PERMITS FROM THE DEVELOPMENT SERVICES DEPARTMENT FOR THE CODE ENFORCEMENT DIVISION FOR ALL UNPERMITTED CONSTRUCTION, REMODELING, OR OCCUPANCY CHANGE INCLUDING, BUT NOT LIMITED TO, THE FOLLOWING ITEMS OR DESCRIBED WORK:
- No work shall be done on any part of the building or structure beyond the point indicated each successive inspection without first obtaining the written approval of the building official. There shall be a final inspection and approval on all buildings when completed and ready for occupancy.PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice:REQUEST AND OBTAIN ALL THE SUCCESSIVE AND REQUIRED INSPECTIONSAND WRITTEN APPROVALS ON ALL WORK AND OBTAIN WRITTEN APPROVAL PRIOR TO OCCUPANCY.
- It shall be the duty of the person doing the work authorized by a permit to notify the building official that such is ready for inspection and to provide access to and means for proper inspection of such work.PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice:REQUEST INSPECTION AND PROVIDE ACCESS TO ALL PERMITTED WORK
- All construction or work for which a permit is required shall be subject to inspection by the building official. It shall be the duty of the permit tee to cause the work to be accessible and exposed for inspection purposes.PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice:PROVIDE ACCESS TO, AND EXPOSE ALL CONSTRUCTION WORK FOR THE REQUIRED INSPECTIONS.

Address	Owner	Total Violations
943 WASHINGTON PL 90813	KESHISHIAN, CLAUDIA	10

Violations:

- The exterior balcony and guardrails are deteriorated. Repair the deteriorated balcony and guardrails to meet minimum code requirements.
- Repair/replace and paint all deterioratedroof fascia, eaves and rafter tails.

- Repair/replace missing or deteriorated garage door.
 - Provide mosquito proof screens on all openable windows.
 - Whenever necessary to make an inspection to enforce any of the provisions of this title, or whenever the building official or his authorized representative has reasonable cause to believe that there exists in any building or upon any condition or code violation which makes such building or premises substandard, unsafe, dangerous or hazardous, the building official or his authorized representative may enter such building or premises at all reasonable times to inspect the same or to perform any duty imposed. PROPERTY OWNER: Take the following corrective action in conjunction with any other corrective actions in this Notice: PROVIDE ACCESS TO THE BUILDING OFFICIAL FOR INSPECTIONS. NOTE: PROPERTY OWNER / MANAGEMENT COMPANY SHALL PROVIDE ACCESS TO UNIT(S) TO VERIFY ALL VIOLATION(S) HAVE BEEN CORRECTED. FAILURE TO PROVIDE ACCESS BY THE COMPLIANCE DATE BELOW MAY RESULT IN A CITATION BEING ISSUED.
 - Repair/Repaint/Weatherproof exterior door.
 - The balcony guardrails do not comply with code requirements. Reconstruct the guardrails to conform to minimum code requirements.
 - Trim trees/shrubs to no less than 18 inches from building and roof to prevent rodent entrance to building(s).
 - Remove scattered trash, castoff items and debris around premises.
 - All properties shall be posted with the number or numbers designated for the principal entrance or entrances of a building. Install address numbers, not less than three inches in height, at the principal entrance of the building in plain view from the public right-of-way.
-